




515 N. Main Street | Hinesville, GA 31313  
PO Box 649 | Hinesville, GA 31310  
912.368.5212  
www.mesack.com  
ME Sack Engineering  
@mesackengineering  
mesack



## MEMORANDUM

DATE: June 24, 2024  
TO: All Bidders  
FROM: Marcus Sack, P.E.   
RE: Flemington Road Improvements  
For City of Flemington  
MES No. 2023-80

The purpose of this memo is to provided clarification on the questions listed below. Please note that this will be the last clarification prior to the bid.

1. *Regarding Wallace Martin do you really want that road to be 4" over the sidewalk that is 2ft away? That's going to put a steep dip to the driveways.*
  - Yes. The shoulder can be 1" below edge of pavement and a 3" shoulder to sidewalk.
2. *Will road closures be allowed to help expedite the Full Depth Roadway Reclamation?*
  - We will work with contractors on traffic control and road closure. We will need to use the loop of the three roads to make traffic flow work.
3. *Can we have more time to complete the bid? Another week to get the 4 addendum to our subs and get any revised pricing if there is?*
  - Unfortunately, we cannot delay the bid. We apologize for the last minute changes and appreciate the contractor participation.