



515 N. Main Street | Hinesville, GA 31313
PO Box 649 | Hinesville, GA 31310
912.368.5212
www.mesack.com
ME Sack Engineering
@mesackengineering
mesack



ADDENDUM No. ONE

Date: January 17, 2025

Project: Sewer and Drainage CDBG, MES No. 2022-15

Engineer: M.E. Sack Engineering
Hinesville, Georgia

The original plans, specifications, and bid documents are amended to include the following:

Bid Document:

- Replace the original Bid Document with the enclosed of the same. Note that the project title has changed, Section 3 Requirements were added, the Invitation for Bids has been revised, and the Bid Form has been revised.

-END-



515 N. Main Street | Hinesville, GA 31313
PO Box 649 | Hinesville, GA 31310
912.368.5212
www.mesack.com
ME Sack Engineering
@mesackengineering
mesack



BID DOCUMENTS

SEWER AND DRAINAGE CDBG
CDBG No. 23p-x-015-2-6352

FOR
CITY OF PEMBROKE

Unofficial



January 6, 2025

MES No. 2022-15

TABLE OF CONTENTS

SECTION I	Invitation for Bids.....	1
SECTION II	Instructions to Bidders	2
	A. Submission of Proposals.....	2
	B. BABA Act Requirements	2
	C. Interpretations	3
	D. Basis of Contract Award	3
	E. Forms and Bonds.....	3
	F. Inspecting and Testing of Materials	3
	G. Construction Schedule	4
	H. Insurance	4
	I. Construction Staking	4
	J. Utility Contractor Licensing Law	4
SECTION III	Bid Submission Forms	5
	A. Bidder Declaration, Part 1	5
	B. Bid Form	6
	C. Bidder Declaration, Part 2	8
	D. Bidder Representation	9
	E. Bonding Agent and Underwriter	10
	F. Addendum Acknowledgement.....	10
	G. Bidder Qualification Form.....	11
	H. Bidder Experience and References.....	12
	I. Site Visit Certification	13
	J. Utility Certification	14
	K. Lawful Presence Affidavit	15
	L. Contractor Affidavit.....	16
	M. Subcontractor Affidavit	17
SECTION IV	Sample Contract.....	18
	A. Payment and Performance Bond	2
SECTION V	Other Conditions of Contract by Attachment	V
	A. CDBG Contract Conditions	V-A
	Davis-Bacon Wages	V-A1
	Build America, Buy America (BABA) Act Requirements	V-A2
	Section 3 Solicitation Package	V-A3
	B. Supplemental Conditions	V-B
	C. General Conditions	V-C
	D. Technical Specifications	V-D
	SECTION 01001 General Requirements	
	SECTION 01150 Measurement and Payment	
	SECTION 02100 Clearing and Grubbing	
	SECTION 02210 Site Grading	
	SECTION 02221 Trench Excavation, Backfill, and Compaction	
	SECTION 02415 Site Demolition	

SECTION 02520	Storm Drainage and Appurtenances
SECTION 02540	Erosion Control
SECTION 02555	Water Distribution System
SECTION 02611	Base and Paving
SECTION 02616	Pavement Removal and Replacement
SECTION 02650	Sanitary Sewers
SECTION 02660	Sewer Line Cleaning and Disinfection
SECTION 02821	Grassing
SECTION 03300	Concrete, General
SECTION 07900	Caulking and Sealants
SECTION 15100	Valves

Unofficial

SECTION I: INVITATION FOR BIDS

Sealed proposals will be received by the City of Pembroke located at 353 N. Main Street, Pembroke, Georgia on February 18, 2025 until 10:30 a.m. local time for the Sewer and Drainage CDBG.

The work to be performed consists of furnishing all labor and materials to complete the Sewer and Drainage CDBG. More specifically, the project will consist of clearing and grubbing, fill and grading, power relocation, structure relocation, traffic control, erosion control, grassing, demolition, asphalt pavement removal and replacement, speed bump removal and replacement, striping, drainage structure removal and replacement, manhole adjustment, wet well tie in, removal and replacement of sewer lines, and pump station abandonment.

Plans, Specifications, and Contract documents are open to public inspection at the Georgia Procurement Registry, ConstructConnect, Dodge Construction Network, and www.mesack.com. Copies of the Plans, Specifications, and Contract Documents may be obtained by contacting M.E. Sack Engineering, biting@mesack.com, 515 North Main Street, P.O. Box 649, Hinesville, Georgia 31310, (912) 368-5212, and by depositing a non-refundable one hundred fifty dollars (\$150.00) for each set of plans requested.

Each Contractor must prequalify for bid by submitting a completed "Statement of Bidder Qualifications" form supplied by the Engineer. Bids will be accepted from prequalified bidders only.

Bids must be accompanied by a certified check or bid bond in an amount equal to at least five percent (5%) of total amount bid for the completed work.

No bids may be withdrawn for a period of sixty (60) days after the closing time schedule for receipt of bids.

The Owner reserves the right to accept or reject any or all bids and to waive informalities. Award of the contract, if it is awarded, will be to the lowest responsible bidder.

This project is subject to the Build America, Buy America (BABA) Act requirements under Title IX of the Infrastructure Investment and Jobs Act ("IIJA), Pub. L. 177-58. Absent an approved waiver, all iron, steel, manufactured products, and construction materials used in this project must be produced in the United States, as further outlined by the Office of Management and Budget's Memorandum M-22-11, Initial Implementation Guidance on Application of Buy America Preference in Federal Financial Assistance Programs for Infrastructure, April 18, 2022.

This project is covered under the requirements of Section 3 of the HUD Act of 1968 and Section 3 Business Concerns are encouraged to apply.

The City is committed to providing all persons with equal access to its services, programs, activities, education and employment regardless of race, color, national origin, religion, sex, familial status, disability or age.

NOTE: Plans and Specifications must be obtained no later than five (5) working days before the bid date. No exceptions.

SECTION II: INSTRUCTIONS TO BIDDERS

A. SUBMISSION OF PROPOSALS:

1. Sealed proposals will be received by the City of Pembroke at 353 N. Main Street, Pembroke, Georgia 31321 until 10:30 a.m. local time, on February 18, 2025 for all labor and materials required to fully complete the work identified in the plans and specifications for the Sewer and Drainage CDBG.
2. At the time and place noted above, the proposals will be publicly opened and read aloud.
3. The proposal (including Statement of Bidder's Qualifications) shall be submitted in duplicate on an exact copy of the proposal form bound herein. Both copies of the Proposal Form must be signed. All blank spaces on the forms shall be filled in and all information called for shall be provided. The terms "NO BID" may be used to fill in a blank space on the Proposal Form. All signatures shall be in ink and in longhand, and the completed forms shall be without alterations or corrections; any interlineations must be initialed by the Bidder.
4. Failure to submit a proposal in the form requested or the inclusion of any alternates, conditions, limitations, or provisions not called for, will render the bid irregular, and shall be considered sufficient cause for rejection of the bid.
5. Proposal shall be in opaque, sealed envelope and marked "Sewer and Drainage CDBG" and shall bear the name of the Bidder. Proposal is to reach the above address no later than the hour and date named above, or authorized extension thereof. No proposal will be received after that time.
6. Proposals, together with the full bid bond, may be withdrawn by Bidders prior to the time set for official opening. After time has been called, no proposal may be withdrawn for a period of sixty (60) days after the time and date of the opening.

B. BABA ACT REQUIREMENTS:

1. Any request for substitute or "or equal" shall include the Manufacturer's Certification of compliance with the Build America, Buy America (BABA) Act requirements mandated by Title IX of the Infrastructure Investment and Jobs Act ("IIJA"), Pub. L. 177-58. BABA Act requirements apply to this project, unless excepted by a waiver.

C. INTERPRETATIONS:

1. Neither Owner nor Engineer will be responsible for any oral instructions or interpretations of the Drawings and Specifications.
2. Requests for interpretations of Drawings and Specifications must be made in writing to the Engineer no later than seven (7) days prior to date set for receipt of bids, and failure on the part of the successful bidder to do so shall not relieve him as Contractor of the obligation to execute such work in accordance with a later interpretation by the Engineer.
3. All interpretations made to bidders will be issued in the form of an addendum to the Plans and Specifications will be sent to all bidders. The requirements of such an addendum are to be included in the bids, and in closing the contract, the addenda will become a part thereof.

D. BASIS OF CONTRACT AWARD:

1. The competency and responsibility of a bidder will be considered in making the award. Owner does not obligate himself to accept the lowest bid or any other bid.
2. The Owner reserves the right to reject any or all proposals and to waive any technicalities.

E. FORMS AND BONDS:

1. The Bidder's attention is directed to the Proposal Form and the Performance and Labor and Materials Payment Bond section.
2. The bond shall be accompanied with the agents and underwriters name, address, and telephone number.

F. INSPECTING AND TESTING OF MATERIALS:

1. Whenever, in these Contract Documents, inspecting, testing, or certification of material(s) is called for, the selection of bureaus, laboratories and/or agencies for such inspecting and testing shall be made by an Independent Testing Laboratory and the character of the test shall be stipulated by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required inspection and test must be furnished in quadruplicate to the Engineer by the bureau, agency, or laboratory selected. Materials satisfactorily meeting the requirements of the inspection or tests shall be approved by the Engineer and the Contractor notified of the results. The cost of such inspecting and testing shall be paid for by the Contractor.

G. CONSTRUCTION SCHEDULE:

1. The Contractor will be required to submit a construction schedule in writing identifying milestones and completion dates at the preconstruction conference. He shall also be required to submit a resume' of the proposed job superintendent for approval by the Engineer.

H. INSURANCE:

1. The Contractor's attention is directed to Article 5 of the Supplemental General Conditions, "Bonds & Insurance." He should review these requirements and be prepared to submit insurance certificates providing the coverage identified. On the insurance certificates, the "Certificate Holder" should be listed as **both** the Owner **and** M.E. Sack Engineering.

I. CONSTRUCTION STAKING:

1. The Owner will provide horizontal and vertical control. The Contractor will be responsible for construction staking.

J. UTILITY CONTRACTOR LICENSING LAW:

1. Effective December 31, 1993, a new law took effect which has an indirect effect on engineers. As of that date all utility contractors must be licensed; a utility contractor is anyone who digs five (5) feet or deeper on a public or private project and where the cost of work exceeds \$100,000.
2. Effective July 1, 2004, the law was modified where the cost of work has no dollar amount therefore anyone who digs five (5) feet or deeper on a public or private project must have a utility license.
3. "It shall be unlawful for any person to contract with any other person for the performance of utility contracting work who is known by such person to not have a current, valid license as a utility contractor pursuant to this chapter." (O.C.G.A. 43-14-8.2(h)) Bids or proposals for utility contracting work will NOT be opened or considered unless the Utility Contractor License number is written on the face of the bid or proposal.

SECTION III: BID SUBMISSION FORMS

A. BIDDER DECLARATION, PART 1

City of Pembroke
353 N. Main Street
Pembroke, Georgia 31321

Submitted: _____, _____

The undersigned, as Bidder, hereby declares that the only person or persons interested in the Proposal as principal or principals is or are named herein and that no other person that herein mentioned has any interest in this Proposal or in the contract to be entered into; that this Proposal is made without connection with any other person, company or parties making a bid or Proposal; and that it is in full respect fair and in good faith without collusion or fraud.

The Bidder further declares that he has examined the site of the work and informed himself fully in regard to all conditions pertaining to the place where the work is to be done; that he has examined the Plans and Specifications for the work and Contractual Documents relative thereto, and has read all Special Provisions and General Conditions furnished prior to the opening of bids; that he has satisfied himself relative to the work to be performed.

The Bidder proposes and agrees, if the Proposal is accepted, to contract with the City of Pembroke in the form of contract specified, to furnish all necessary materials, equipment, machinery, tools, apparatus, means of transportation and labor necessary to complete the construction of the work, in full and in complete accordance with the shown, noted, described, and reasonably intended requirements of the Specifications and Contract Documents, to the full and entire satisfaction of the City of Pembroke with a definite understanding that no money will be allowed for extra work except as set forth in the attached General Conditions and Contract Documents, for prices on the following pages.

B. BID FORM

Bid Item	Quantity	Units	Description	Unit Price	Cost
A. DRAINAGE IMPROVEMENTS					
1	1	LS	Clearing & Grubbing	-	\$
2	1	LS	Fill & Grading	-	\$
3	1	EA	Power Pole Relocation	\$	\$
4	1	LS	Electric Utility Overhead Line Relocation	-	\$
5	1	LS	Structure Relocation	-	\$
6	1	LS	Traffic Control	-	\$
7	1	LS	Erosion Control	-	\$
8	1	LS	Right-of-Way Grassing	-	\$
9	1	LS	Demolition	-	\$
10	6,871	SY	Asphalt Pavement Removal	\$	\$
11	6,871	SY	Aggregate Base Removal	\$	\$
12	4,654	LF	Rolled 24" Concrete Curb & Gutter	\$	\$
13	6,937	SY	1.5" 9.5mm SuperPave	\$	\$
14	6,937	SY	6" Graded Aggregate Base	\$	\$
15	1	LS	Feather Asphalt Paving @ Intersection	-	\$
16	148	SY	4" Concrete Apron w/Smooth Rock Transition	\$	\$
17	370	SY	Gravel Driveway Replacement	\$	\$
18	4	EA	Speed Bump Removal and Reinstallation	\$	\$
19	22	LF	24" Paint & Bead Stop Bar	\$	\$
20	2,010	LF	4" Paint & Bead Double Solid Yellow Line Striping	\$	\$
21	53	LF	4" Paint & Bead Double Dashed Yellow Line Striping	\$	\$
22	177	LF	Culvert Pipe Removal	\$	\$
23	9	EA	Precast Rolled Curb Inlet Structures	\$	\$
24	4	EA	Grated Inlets	\$	\$
25	2	EA	Junction Box	\$	\$

B. BID FORM continued

Bid Item	Quantity	Units	Description	Unit Price	Cost
A. DRAINAGE IMPROVEMENTS continued					
26	1	EA	Headwall – L Shaped	\$	\$
27	150	LF	French Underdrain - 6"	\$	\$
28	1	EA	15" Flared End Section	\$	\$
29	1	EA	12" Flared End Section	\$	\$
30	617	LF	18" HDPE	\$	\$
31	79	LF	15" HDPE	\$	\$
32	204	LF	12" HDPE	\$	\$
B. SEWER IMPROVEMENTS					
33	1	LS	Connection to Existing Sewer System	-	\$
34	2,234	LF	8" Sanitary Sewer Line	\$	\$
35	8	EA	Manhole	\$	\$
36	1	LS	Tie into Existing Wet Well	-	\$
37	21	EA	Reconnect Sanitary Sewer Service Laterals to New Sewer Line	\$	\$
38	2	EA	Sanitary Sewer Laterals and Extension to House Service Connection	\$	\$
39	1,484	LF	Cut, Fill, & Remove Existing Sewer Line	\$	\$
40	2	EA	Demolish & Remove Existing Sewer Manhole	\$	\$
41	612	LF	Fill and Abandon Sewer Line	\$	\$
42	2	EA	Abandon Private Pump Stations	\$	\$
43	75	LF	Cut, Fill, & Remove Water Line	\$	\$
44	70	LF	8" Water Line Relocation	\$	\$
45	1	EA	Gate Valve	\$	\$
46	1	TN	Fittings	\$	\$
47	2	EA	Connect to Existing 8" Water Line	\$	\$
48	1	LS	Mobilization (5% Max)	-	\$
TOTAL BID					\$

C. BIDDER DECLARATION, PART 2

The Bidder further proposes and agrees hereby to commence work under his Contract, with adequate force and equipment, on a date to be specified in written order of the ENGINEER and shall fully complete all work hereunder within one hundred eighty (180) consecutive days from and including said date.

The Bidder declares that he understands that the quantities shown for unit price items, are approximate only, are valid only upon written authorization of the ENGINEER, and are subject to either increase or decrease and that should the quantities of any items of work be increased, the Bidder proposes to do the additional at the unit prices stated herein; and should the quantities be decreased, the Bidder also understands that payment will be made on the basis of actual quantities at the unit price bid and will make no claim for anticipated profits for any decrease in quantities, and that actual quantities will be determined upon completion of the work, at which time adjustment will be made to the Contract amount by direct increase or decrease.

The undersigned further agrees that, in case of failure on his part to execute the Construction Contract and the bond within ten (10) consecutive calendar days after written notice being given of the award of the Contract, the check or bond accompanying this bid, and the monies payable thereon, shall be paid into the funds of the City of Pembroke as liquidated damages for such failure, otherwise the check or bid bond accompanying this proposal shall be returned to the undersigned.

Attached hereto is a certified check on the _____ Bank of _____ or a Bid Bond by the _____ in the amount of _____ Dollars (\$) made payable to the City of Pembroke, in accordance with the conditions of the advertisement and provisions herein.

Submitted:

By:

Title:

D. BIDDER REPRESENTATION

Bidder is familiar with all laws and regulations that may affect cost, progress, and performance of the work, including Build America, Buy America (BABA) Act requirements.

By signing below, the Bidder is certifying that they will comply with all requirements of the BABA Act, 41 USC 8301 note, and all applicable rules and notices, as may be amended, shall be complied with if applicable to the infrastructure project. Contractors must provide manufacturers' certifications of all BABA compliant items to the Engineer before a request for payment is made to the City.

Company Name

By

Title

Date

Unofficial

E. BONDING AGENT AND UNDERWRITER

Bidder's Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Bonding Agent: _____

Physical Address: _____

Telephone Number: _____

Underwriter Name: _____

Physical Address: _____

Telephone Number: _____

FAILURE TO COMPLETE THIS SECTION IS GROUNDS FOR REJECTION

F. ADDENDUM ACKNOWLEDGEMENT

Bidder Acknowledges Receipt of the Following Addendum:

No.: _____

Date: _____

No.: _____

Date: _____

No.: _____

Date: _____

No.: _____

Date: _____

G. BIDDER QUALIFICATION FORM*

*The statements below must be subscribed and sworn to before a Notary Public

Bidder's legal name:	
Business Address:	
Business Phone Number:	
Form of Ownership (Corporation, Partnership, Individual Proprietorship, Other (Specify)):	
Organization Date:	
Incorporation Date:	
In case of Partnership or other association, legal name of each partner:	
Years in business in present form:	
If requested by the Owner, will you furnish to them your most recent Financial Statement within 48 hours after bid taking?	
If yes, give date of statement:	
Credit available for this contract:	\$
Contracts now in hand (gross amount):	\$
Have you ever refused to sign a contract at your original bid? If yes, explain.	
Do you have a Georgia Utility Contractor's License?	
If yes, provide number:	
Have you ever defaulted on a contract? If yes, explain.	

Sworn to and subscribed before me, this _____ day of _____, 20____

(Notary Public)

Firm Name: _____

By: _____

Its: _____

H. BIDDER EXPERIENCE AND REFERENCES

Provide references for work done, minimum of six (6), three (3) within the last twelve (12) months of similar size and nature, and a listing of all jobs performed in the last twelve (12) months. References will afford the Owner opportunity to judge as to capabilities and performance of the contractor.

Provide name, brief description of work performed, address, phone number, and contact person for each project listed. Failure to complete this section in its entirety will be grounds for rejection.

Unofficial

I. SITE VISIT CERTIFICATION

This document is to be executed by the Bidder and submitted with the bid for the construction of the Sewer and Drainage CDBG (Project #2022-15) for the City of Pembroke in order to be considered for award.

Check the option that applies:

I certify that I visited the Site of the proposed Work on (date of visit) and became fully acquainted with the conditions relating to construction and labor. I fully understand the facilities, difficulties, and restrictions attending the execution of Work under contract.

I certify that (Bidder's representative) visited the Site of the proposed Work on (date of visit) and became fully acquainted with the conditions relating to construction and labor. The Bidder's representative fully understood the facilities, difficulties, and restrictions attending the execution of the Work under contract.

Bidder fully indemnifies the City of Pembroke, its Engineer, its Construction Manager, and all of their respective officers, agents, employees, and consultants from any damage or omissions related to conditions that could have been identified during my visit and/or the Bidder's representative's visit to the Site.

I certify under penalty of perjury under the laws of the State of Georgia that the foregoing is true and correct.

Company Name

By

Title

Date

J. UTILITY CERTIFICATION

This document is to be executed by the Bidder and submitted with the bid for the construction of the **Sewer and Drainage CDBG (Project #2022-15)** for the City of Pembroke in order to be considered for award.

Bidder recognizes the supplied plans may not identify all underground improvements or their locations, and the information upon which the Engineer rely may contain errors or may not be complete. Bidder agrees, to the fullest extent permitted by law, to defend, indemnify and hold harmless the City of Pembroke, its Engineer, and all of their respective officers, agents, employees, and consultants from all liability (including reasonable attorneys' fees and court costs) of Bidder, its contractors or all other persons for delay or additional compensation relating to the identification, removal, relocation, or restoration of utilities, or damages to underground improvements resulting from subsurface penetration locations established by the supplied plans.

It shall be the responsibility of the awarded Contractor to have all underground utilities located before any work begins. The repairs of any damaged underground utilities as a result of the work being performed by the awarded Contractor shall be the responsibility of the awarded Contractor. The proper utility company shall be contacted immediately to expedite the repairs if damage has occurred. Awarded Contractor will notify the City of Pembroke and its Engineer, M.E. Sack Engineering, and provide a written explanation of the incident within two (2) days of the damage to any underground utilities.

I certify under penalty of perjury under the laws of the State of Georgia that I have read and will fully comply with the foregoing.

Company Name

By

Title

Date

K. LAWFUL PRESENCE AFFIDAVIT

Pursuant to O.C.G.A. § 50-36-1, all persons who - either on behalf of themselves or on behalf of an individual, business, corporation, partnership, or other private entity - apply for certain public benefits must (1) be eighteen years of age or older and (2) submit an affidavit that they are lawfully present in the United States. Public benefits, as defined by O.C.G.A. § 50-36-1(a)(3)(A), include any grant, contract, loan, professional license, or commercial license provided by an agency of State or local government or by appropriated funds of a State or local government.

I, _____, swear or affirm under penalty of perjury under the laws of the State of Georgia that I am 18 years of age or older and (check one):

- I am a United States citizen, or
- I am a legal Permanent Resident of the United States, or
- I am a qualified alien (other than as a permanent resident) or nonimmigrant in the United States pursuant to Federal law.

The secure and verifiable document provided with this affidavit can best be classified as: _____

I understand that this sworn statement is required by law because I have applied for a public benefit and/or a business license on my behalf as an individual or on behalf of a business, corporation, partnership, or other private entity. I understand that state law required me to provide proof that I am lawfully present in the United States prior to receipt of this public benefit as listed above. I further acknowledge that making a false, fictitious, or fraudulent statement or representation in this sworn affidavit is punishable under the criminal laws of Georgia under O.C.G.A. § 16-10-20 and it shall constitute a separate criminal offense each time a public benefit is fraudulently received.

Signature Date

Title *Alien Registration # for Non-citizens

Business Name TIN or SSN

If this affidavit is not presented in person, applicant must submit a notarized copy of this affidavit.

Notarized this ____ Day of _____, 20____, in the State of _____, County of _____

Notary Commission Expires

*Note: O.C.G.A § 50-36-1(e) (2) requires that aliens under the Federal Immigration and Nationality Act., Title 8 U.S.C., as amended, provide their alien registration number. Because legal permanent residents are included in the federal definition of "alien", legal permanent residents must also provide their alien registration number. Qualified aliens that do not have an alien registration number may supply another identifying number: _____

L. CONTRACTOR AFFIDAVIT under O.C.G.A. § 13-10-91(b)(1)

By executing this affidavit, the undersigned contractor verifies its compliance with O.C.G.A. §13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services on behalf of the City of Pembroke has registered with, is authorized to use and uses the federal work authorization program commonly known as E-verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned contractor will continue to use the federal work authorization program throughout the contract period and the undersigned contractor will contract for the physical performance of services in satisfaction of such contract only with subcontractors who present an affidavit to the contractor with the information required by O.C.G.A. § 13-10-91(b). Contractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number/E-verify User Number

Date of Authorization/Date of contract between Contractor and Public Employer

Legal Name of Contractor (please print)

Legal Address of Contractor

City, State, & Zip Code

Sewer and Drainage CDBG

Name of Project

City of Pembroke

Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, _____, 20__ in _____ (city), _____ (state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME ON THIS ____ DAY OF _____, 20__.

Notary Public

Commission Expires

M. SUBCONTRACTOR AFFIDAVIT under O.C.G.A. § 13-10-91(b)(3)

By executing this affidavit, the undersigned subcontractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services under a contract with _____ (name of contractor) on behalf of the City of Pembroke has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned subcontractor will continue to use the federal work authorization program throughout the contract period and the undersigned subcontractor will contract for the physical performance of services in satisfaction of such contract only with sub-subcontractors who present an affidavit to the subcontractor with the information required by O.C.G.A. § 13-10-91(b). Additionally, the undersigned subcontractor will forward notice of the receipt of an affidavit from a sub-subcontractor to the contractor within five business days of receipt. If the undersigned subcontractor receives notice of receipt of an affidavit from any sub-subcontractor that has contracted with a sub-subcontractor to forward, within five business days of receipt, a copy of such notice to the contractor. Subcontractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

Federal Work Authorization User Identification Number

Date of Authorization

Name of Subcontractor

Sewer and Drainage CDBG

Name of Project

City of Pembroke

Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on _____, _____, 20__ in _____(city), _____(state).

Signature of Authorized Officer or Agent

Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME ON THIS THE _____ DAY OF _____, 20_____.

Notary Public

Commission Expires

SECTION IV: SAMPLE CONTRACT

THIS AGREEMENT, made this _____ day of _____, 20____, by and between the City of Pembroke, herein called "OWNER" acting herein through Tiffany McCoy Zeigler and _____, of _____, County of _____, and State of _____, herein called "CONTRACTOR".

WITNESSETH: that for and in consideration of the payments and agreement hereinafter mentioned, to be made and performed by the OWNER, and the CONTRACTOR hereby agrees with the OWNER to commence and complete the construction described as follows:

SEWER AND DRAINAGE CDBG
FOR
CITY OF PEMBROKE

hereinafter called the project, for the sum of _____ Dollars (\$_____) and all extra work in connection therewith, under the terms as stated in the General and Special Conditions of the Contract; and at his (it's or their) own proper cost and expense to furnish all the materials, supplies, machinery, equipment, tools, superintendence, labor, insurance, and other accessories and services necessary to complete the said project in accordance with the conditions and prices stated in the Proposal; the General Conditions, Supplemental General Conditions and Special Conditions of the Contract, the plans, which include all maps, plats, blue prints and other drawings and printed or written explanatory matter thereof, the specifications and Contract Documents therefore as prepared by M.E. Sack Engineering, herein entitled the ENGINEER, and as enumerated in Paragraph 1 of the Supplementary General Conditions, all of which are made a part hereof and collectively evidence and constitute the Contract.

The Contractor hereby agrees to commence work under this Contract on or before a date to be specified in a written "Notice to Proceed" from the Owner and to fully complete the project within one hundred eighty (180) consecutive calendar days thereafter.

The Contractor further agrees to pay, as liquidated damages, the sum of \$300 for each consecutive calendar day thereafter as hereinafter provided in Section 01001, Paragraph 1.11.

The owner agrees to pay the contractor in current funds for the past performance of the contract subject to additions and deductions as provided in the General Conditions, Article 14 of the contract. Retainage on progress payments shall be ten (10) percent until the project is substantially complete (80% or more) at which point retainage may be reduced to 5% depending on the contractor's progress related to schedule and workmanship.

Unofficial

IN WITNESS WHEREOF, the parties present have executed this contract in four (4) counterparts, each of which shall be deemed an original, in the year and day first above mentioned.

ATTEST:

City of Pembroke

(Owner)

(Secretary)

By _____

(Witness)

Mayor

(Title)

(Contractor)

(Secretary)

By _____

(Witness)

(Title)

(Address and Zip Code)

Unofficial

A. PERFORMANCE BOND AND LABOR AND MATERIAL PAYMENT BOND

1. REFERENCE

By reference, "The Performance Bond and Payment Bond", E.J.C.D.C. Document C-610 and C-615, 2007 Edition, pages 1 through 2 of each inclusive, is a part of this Contract.

Unofficial

SECTION V: OTHER CONDITIONS OF CONTRACT BY ATTACHMENT

Unofficial

A. CDBG CONTRACT CONDITIONS

Unofficial

CDBG Contract Conditions

<i>ITEM</i>	<i>PAGE</i>
Section 3 Clause	2
Provision for Remedies Clause	3
Termination Clause	4
Equal Employment Opportunity (EEO) Clause	5
Standard Federal EEO Specifications (EO 11246)	7
Notice of Requirement for Affirmative Action	12
Certification of Nonsegregated Facilities	15
Standard Federal Labor Standards Provision	16
Contractor Certification Regarding Debarment, etc.	24
Clean Air and Clean Water Act Compliance	25
Performance, Payment and Bid Bonds	26
Contract Review Checklist	27

Section 3 Clause of the Urban Development Act of 1968

- 1.) The work to be performed under this contract is on a project assisted under a program providing direct Federal financial assistance from the Department of Housing and Urban Development and is subject to the requirements of section 3 of the Housing and Urban Development Act of 1968, as amended, 12 U.S.C. 1701u. Section 3 requires that to the greatest extent feasible opportunities for training and employment be given lower income residents of the project area and contracts for work in connection with the project to be awarded to business concerns which are located in, or owned in substantial part by persons residing in the area of the project.
- 2.) The parties to this contract will comply with the provisions of said Section 3 and the regulations issued pursuant thereto by the Secretary of Housing and Urban Development set forth in 24 CFR Part 135, and all applicable rules and orders of the Department issued thereunder prior to the execution of this contract. The parties to this contract certify and agree that they are under no contractual or other disability which would prevent them from complying with these requirements.
- 3.) The contractor will send to each labor organization or representative of workers with which he has a collective bargain-agreement or other contract or understanding, if any, a notice advising the said labor organization or workers' representative of his commitments under this Section 3 clause and shall post copies of the notice in conspicuous places available to employees and applicants for employment or training.
- 4.) The contractor will include this Section 3 clause in every subcontract for work in connection with the project and will, at the direction of the applicant for or recipient of Federal financial assistance, take appropriate action pursuant to the subcontract upon a finding that the subcontractor is in violation of regulations issued by the Secretary of Housing and Urban Development, 24 CFR Part 135. The contractor will not subcontract with any subcontractor where it has notice or knowledge that the letter has been found in violation of regulations under 24 CFR Part 135 and will not let any subcontract unless the subcontractor has first provided it with a preliminary statement of ability to comply with the requirements of these regulations.
- 5.) Compliance with the provisions of Section 3, the regulations set forth in the 24 CFR Part 135, and all applicable rules and orders of the Department issued thereunder prior to the execution of the contract, shall be a condition of the Federal financial assistance provided to the project, binding upon the applicant or recipient for such assistance, its successors, and assigns. Failure to fulfill these requirements shall subject the applicant or recipient, its contractors and subcontractors, its successors, and assigns to those sanctions specified by the grant or loan agreement or contract through which Federal assistance is provided, and to such sanctions as are specified by 24 CFR Part 135.

Provision for Remedies Clause

1.) **Termination:** Unearned payments under this contract may be suspended or terminated upon refusal to accept any additional conditions that may be imposed by City; or if the grant to the City under the Community Development Block Grant Program is suspended or terminated. Moreover, if through any cause, the contractor shall fail to fulfill its obligations under this contract in a timely and proper manner, or if the contractor shall violate any of the covenants, agreements, conditions or obligations of the contract documents; the City may terminate this contract by giving written notice to the contractor and surety of such termination and specifying the effective date of such termination. In such event, the City may take over the work and prosecute the same to completion, by contract or otherwise, and the contractor and his sureties shall be liable to the City for any additional cost incurred by the Owner in its completion of the work and they shall also be liable to the Owner for liquidated damages for any delay in the completion of the work as provided below. Furthermore, the Contractor will be paid an amount which bears the same ratio to the total compensation as the work and services actually performed bear to the total work and services required. Provided, however, that if less than sixty percent of the services required by this Contract have been performed upon the effective date of such termination, the Contractor shall be reimbursed (in addition to the above payment) for that portion of the actual out-of-pocket expenses (not otherwise reimbursed under this Contract) incurred by the Contractor during the Contract period which are directly attributable to the uncompleted portion of the services required by this Contract.

2.) **Liquidated Damages for Delays.** If the work is not completed within the time stipulated, therefore, including any extensions of time for excusable delays as herein provided, the Contractor shall pay to the Owner as fixed and agreed liquidated damages (it being impossible to determine the damages occasioned by the delay) for each working day of delay, until the work is completed, the amount as set forth in General Requirements, Section 01001, Part 1.11 and the Contractor and his sureties shall be liable to the Owner for the amount thereof.

3.) **Excusable Delays.** The right of the Contractor to proceed shall not be terminated nor shall the Contractor be charged with liquidated damages for any delays in the completion of the work due:

(a) To any acts of the Government, including controls or restrictions upon or requisitioning of materials, equipment, tools, or labor by reason of war, National Defense, or any other national emergency;

(b) To any acts of the Owner;

(c) To causes not reasonable foreseeable by the parties to this Contract at the time of the execution of the Contract which are beyond the control and without the fault or negligence of the Contractor, including, but not restricted to, acts of God or of the public enemy, acts of another Contractor in the performance of some other contract with the Owner, fires, floods, epidemics, quarantine, strikes, freight embargoes, and weather of unusual severity such as hurricanes, tornadoes, and cyclones; and

(d) To any delay of any subcontractor occasioned by any of the causes specified in subparagraphs (a) (b) and (c) or this subparagraph "d".

Provided, however, that the Contractor promptly notified the Owner within ten (10) days of the cause of the delay. Upon receipt of such notification, the Owner shall ascertain the facts and the cause and extent of delay. If upon the basis of the terms of this contract the delay is properly excusable, the Owner shall extend the time for completing the work for a period of time commensurate with the period of excusable delay.

Termination for Convenience Clause

1.) Termination for Convenience of the City:

The city may terminate this contract at any time for any reason by giving at least thirty (30) days notice in writing to the contractor. If the contract is terminated by the city as provided herein, the contractor will be paid a fair payment as negotiated with the city for the work completed as of the date of termination.

Unofficial

Equal Employment Opportunity (EEO) Clause

During the performance of this contract, the Contractor agrees as follows:

- 1.) The Contractor will not discriminate against any employee or applicant for employment because of race, color, religion, sex or national origin. The Contractor will take affirmative action to ensure that applicants are employed, and the employees are treated during employment without regard to their race, color, religion, sex or national origin. Such action shall include, but not be limited to the following: Employment, upgrading, demotion, or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship. The Contractor agrees to post in conspicuous places, available to employees and applicants for employment, notices to be provided setting forth the provisions of this nondiscrimination clause.
- 2.) The Contractor will, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, color, religion, sex or national origin.
- 3.) The Contractor will send to each labor union or representative of workers with which he has a collective bargaining agreement or other contract or understanding, a notice to be provided advising the said labor union or workers' representative of the Contractor's commitments under this section, and shall post copies of the notice in conspicuous places available to employees and applicants for employment.
- 4.) The Contractor will comply with all provisions of Executive Order 11246 of September 24, 1965, and of the rules, regulations and relevant orders of the Secretary of Labor.
- 5.) The Contractor will furnish all information and reports required by Executive Order 11246 of September 24, 1965, and by rules, regulations and orders of the Secretary of Labor, or pursuant thereto, and will permit access to his books, records and accounts by the administering agency and the Secretary of Labor for purposes of investigation to ascertain compliance with such rules, regulations and orders.
- 6.) In the event of the Contractor's noncompliance with the nondiscrimination clauses of this contract or with any of the said rules, regulations, or orders, this contract may be canceled, terminated or suspended in whole or in part and the contractor may be declared ineligible for further Government contracts or federally assisted construction contracts in accordance with procedures authorized in Executive Order 11246 of September 24, 1965, and such other sanctions may be imposed and remedies invoked as provided in Executive Order 11246 of September 24, 1965, or by the rule, regulation, or order of the Secretary of Labor, or as otherwise provided by law.
- 7.) The Contractor will include the portion of the sentence immediately preceding paragraph (1) and the provisions of paragraphs (1) through (7) in every subcontract or purchase order unless exempted by rules, regulations, or orders of the Secretary of Labor issued pursuant to Section 204 of Executive Order 11246 of September 24, 1965, so that such provisions will be binding

upon each subcontractor or vendor. The Contractor will take such action with respect to any subcontract or purchase order as the administering agency may direct as a means of enforcing such provisions, including sanctions for noncompliance. Provided, however, that in the event a Contractor becomes involved in, or is threatened with litigation with a subcontractor or vendor as a result of such direction by the administering agency the contractor may request the United States to enter into such litigation to protect the interests of the United States.

Unofficial

**STANDARD FEDERAL EQUAL EMPLOYMENT OPPORTUNITY CONSTRUCTION
CONTRACT SPECIFICATIONS
(EXECUTIVE ORDER 11246)**

1.) As used in these specifications:

a. "Covered area" means the geographical area described in the solicitation from which this contract resulted;

b. "Director" means Director, Office of Federal Contract Compliance Program, United States Department of Labor, or any person to whom the Director delegates authority;

c.. "Employer identification number" means the Federal Social Security Number used on the Employer's Quarterly Federal Tax Return, US. Treasury Department Form 941.

d. "Minority" includes:

(i) Black (all persons having origins in any of the Black African racial groups not of Hispanic origin);

(ii) Hispanic (all persons of Mexican, Puerto Rican, Cuban, Central or South American or other Spanish Culture or origin, regardless of race);

(iii) Asian and Pacific Islander (all persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands); and

(iv) American Indian or Alaskan Native (all persons having origins in any of the original peoples of North America and maintaining identifiable tribal affiliations through membership and participation or community identification).

2.) Whenever the Contractor, or any Subcontractor at any tier, subcontracts a portion of the work involving any construction trade, it shall physically include in each subcontract in excess of \$10,000 the provisions of these specifications and the Notice which contains the applicable goals for minority and female participation and which is set forth in the solicitations from which this contract resulted.

3.) If the Contractor is participating (pursuant to 41 CFR 60-4.5) in a Hometown Plan approved by the US. Department of Labor in the covered area either individually or through an association, its affirmative action obligations on all work in the Plan area (including goals and timetables) shall be in accordance with that Plan for those trade which have unions participating in the Plan. Contractors must be able to demonstrate their participation in and compliance with the provisions of any such Hometown Plan. Each Contractor or Subcontractor participating in an approved Plan is individually required to comply with its obligations under the EEO clause, and to make a good faith effort to achieve each goal under the Plan in each trade in which it has employees. The overall good faith performance by other Contractors or Subcontractors toward a

goal in an approved Plan does not excuse any covered Contractor's or Subcontractor's failure to take good faith efforts to achieve the Plan goals and timetables.

4.) The Contractor shall implement the specific affirmative action standards provided in paragraphs 7a through p of these specifications. The goals set forth in the solicitation from which this contract resulted are expressed as percentages of the total hours of employment and training of minority and female utilization the Contractor should reasonably be able to achieve in each construction trade in which it has employees in the covered area. The Contractor is expected to make substantially uniform progress toward its goals in each craft during the period specified.

5.) Neither the provisions of any collective bargaining agreement, nor the failure by a union with whom the Contractor has a collective bargaining agreement, to refer either minorities or women shall excuse the Contractor's obligations under these specifications. Executive Order 11246, or the regulations promulgated pursuant thereto.

6.) In order for the non-working training hours of apprentices and trainees to be counted in meeting the goals, such apprentices and trainees must be employed by the Contractor during the training period and the Contractor must have made a commitment to employ the apprentices and trainees at the completion of their training, subject to the availability of employment opportunities. Trainees must be trained pursuant to training programs approved by the U. S. Department of Labor.

7.) The Contractor shall take specific affirmative actions to ensure equal employment opportunity. The evaluation of the Contractor's compliance with these specifications shall be based upon its effort to achieve maximum results from its actions. The Contractor shall document these efforts fully, and shall implement affirmative action steps at least as extensive as the following:

a. Ensure and maintain a working environment free of harassment, intimidation and coercion at all sites, and in all facilities at which the Contractor's employees are assigned to work. The Contractor, where possible, will assign two or more women to each construction project. The Contractor shall specifically ensure that all foremen, superintendents and other on-site supervisory personnel are aware of and carry out the Contractor's obligation to maintain such a working environment, with specific attention to minority or female individuals working at such sites or in such facilities.

b. Establish and maintain a current list of minority and female recruitment sources, provide written notification to minority and female recruitment sources and to community organizations when the Contractor or its unions have employment opportunities available, and maintain a record of the organizations' responses.

c. Maintain a current file of the names, addresses and telephone numbers of each minority and female off-the street applicant and minority or female referral from a union, a recruitment source or community organization and of what action was taken with respect to each such individual. If such individual was sent to the union hiring hall for referral and was not referred back to the

Contractor by the union, or if referred, not employed by the Contractor, this shall be documented in the file with the reasons therefor, along with whatever additional actions the Contractor may have taken.

d. Provide immediate written notification to the Director when the union or unions with which the Contractor has a collective bargaining agreement has not referred to the Contractor a minority person or woman sent by the Contractor, or when the Contractor has other information that the union referral process has impeded the Contractor's efforts to meet its obligations.

e. Develop on-the-job training opportunities and/or participate in training programs for the area which expressly include minorities and women, including upgrading programs and apprenticeship and trainee programs relevant to the Contractor's employment needs, especially those programs funded or approved by the Department of Labor. The Contractor shall provide notice of these programs to the sources compiled under 7b above.

f. Disseminate the contractor's EEO policy by providing notice of the policy to unions and training programs and requesting their cooperation in assisting the Contractor in meeting its EEO obligations; by including it in any policy manual and collective bargaining agreement; by publicizing it in the company newspaper, annual report, etc.; by specific review of the policy with all management personnel and with all minority and female employees at least once a year; and by posting the company EEO policy on bulletin boards accessible to all employees at each location where construction work is performed.

g. Review, at least annually, the company's EEO policy and affirmative action obligations under these specifications with all employees having any responsibility for hiring, assignment, lay-off, termination or other employment decisions including specific review of these items with on-site supervisory personnel such as Superintendents, General Foremen, etc., prior to the initiation of construction work at any job site. A written record shall be made and maintained identifying the time and place of these meetings, persons attending, subject matter discussed and disposition of the subject matter.

h. Disseminate the Contractor's EEO policy externally by including it in any advertising in the news media, specifically including minority and female news media, and providing written notification to and discussing the contractor's EEO policy with other contractors and Subcontractors with whom the Contractor does or anticipates doing business.

i. Directs its recruitment efforts, both oral and written, to minority, female and community organizations, to schools with minority and female students and to minority and female recruitment and training organizations serving the Contractor's recruitment area and employment needs. Not later than one month prior to the date for the acceptance of applications for apprenticeship or other training by any recruitment source. The Contractor shall send written notification to organizations such as the above, describing the openings, screening procedures, and tests to be used in the selection process.

j. Encourage present minority and female employees to recruit other minority persons and women and, where reasonable, provide after school, summer and vacation employment of minority and female youth both on the site and in other areas of a Contractor's workforce.

k. Validate all tests and other selection requirements where there is an obligation to do so under 41 CFR Part 60-3.

l. Conduct, at least annually, an inventory and evaluation at least of all minority and female personnel for promotional opportunities and encourage these employees to seek or to prepare for, through appropriate training, etc., such opportunities.

m. Ensure that seniority practices, job classifications, work assignments and other personnel practices, do not have a discriminatory effect by continually monitoring all personnel and employment related activities to ensure that the EEO policy and the Contractor's obligations under these specifications are being carried out.

n. Ensure that all facilities and company activities are nonsegregated except that separate or single-user toilet and necessary changing facilities shall be provided to assure privacy between the sexes.

o. Document and maintain a record of all solicitations of offers for subcontracts from minority and female construction contractors and suppliers, including circulation of solicitations to minority and female contractor associations and other business associations.

p. Conduct a review, at least annually, of all supervisors' adherence to and performance under the Contractor's EEO policies and affirmative action obligations.

8.) Contractors are encouraged to participate in voluntary associations which assist in fulfilling one or more of their affirmative action obligations (7a through p). The efforts of a contractor association, joint contractor-union, contractor-community, or other similar group of which the contractor is a member and participant may be asserted as fulfilling any one or more of its obligations under 7a through p of those Specifications provided that the Contractor actively participates in the group, makes every effort to assure that the group has a positive impact on the employment of minorities and women in the industry, ensures that the concrete benefits of the program are reflected in the Contractor's minority and female workforce participation, makes a good faith effort to meet its individual goals and timetables, and can provide access to documentation which demonstrates the effectiveness of actions taken on behalf of the Contractor. The obligation to comply, however, is the Contractor's and failure of such a group to fulfill an obligation shall not be a defense for the Contractor's noncompliance.

9.) A single goal for minorities and a separate single goal for women have been established. The Contractor, however, is required to provide equal employment opportunity and to take affirmative action for all minority groups, both male and female, and all women, both minority and non-minority. Consequently, the Contractor may be in violation of the Executive Order if a particular group is employed in a substantially disparate manner (for example, even though the Contractor has achieved its goals for women generally, the Contractor may be in violation of the Executive Order if a specific minority group of women is underutilized).

10.) The Contractor shall not use the goals and timetables or affirmative action standards to discriminate against any person because of race color, religion, sex or national origin.

11.) The Contractor shall not enter into any Subcontract with any person or firm debarred from Government contracts pursuant to Executive Order 11246.

12.) The Contractor shall carry out such sanctions and penalties for violation of these specifications and of the Equal Opportunity Clause, including suspension, termination and cancellation of existing subcontracts as may be imposed or ordered pursuant to Executive Order 11246, as amended, and its implementing regulations, by the Office of Federal Contract Compliance Programs. any Contractor who fails to carry out such sanctions and penalties shall be in violation of these specifications and Executive Order 11246, as amended.

13.) The Contractor, in fulfilling its obligations under these specifications, shall implement specific affirmative action steps, at least as extensive as those standards prescribed in paragraph 7 of these specifications, so as to achieve maximum results from its efforts to ensure equal employment opportunity. If the Contractor fails to comply with the requirements of the Executive Order, the implementing regulations, or these specifications, the Director shall proceed in accordance with 41 CFR 60-4.S.

14.) The Contractor shall designate a responsible official to monitor all employment related activity to ensure that the company EEO policy is being carried out, to submit reports relating to the provisions hereof as may be required by the Government and to keep records. Records shall at least include for each employee the name, address, telephone numbers, construction trade, union affiliation if any, employee identification number when assigned, social security number, race, sex, status (e.g., mechanic, apprentice, trainee, helper or laborer), dates of changes in status, hours worked per week in the indicated trade, rate of pay, and locations at which the work was performed. Records shall be maintained in an easily understandable and retrievable form; however, to the degree that existing records satisfy this requirement, contractors shall not be required to maintain separate records.

15.) Nothing herein provided shall be construed as a limitation upon the application of other laws which establish different standards of compliance or upon the application of requirements for the hiring of local or other area residents (e.g., those under the Public Works Employment Act of 1977 and the Community Development Block Grant Program).

**NOTICE OF REQUIREMENT FOR AFFIRMATIVE ACTION TO EQUAL
EMPLOYMENT OPPORTUNITY (EXECUTIVE ORDER 11246)**

1.) The Offerer's or Bidder's attention is called to the "Equal Opportunity Clause" and the "Standard Federal Equal Employment Opportunity Construction Contract Specifications" set forth herein.

2.) The goals and timetables for minority and female participation, expressed in percentage terms for the Contractor's aggregate workforce in each trade on all construction work in the covered area, are as follows:

<u>Timetable:</u>	<u>Goals for minority participation</u>	<u>Goals for female participation</u>
Until Further Notice	(insert goal) *	6.9%

These goals are applicable to each non-exempt contractor's total on-site construction workforce, regardless of whether or not part of that workforce is performing work on a Federal, Federally assisted or non-Federally related project, contract or sub-contract.

The contractor's compliance with the Executive Order and the regulations in 41 CFR Part 60-4 shall be based on its implementation of the Equal Opportunity Clause, specific affirmative action obligations required by the specifications set forth in 41 CFR 60-4.3(a), and its efforts to meet the goals established for the geographical area where the contract resulting from this solicitation is to be performed. The hours of minority and female employment and training must be substantially uniform throughout the length of the contract, and in each trade, and the contractor shall make a good faith effort to employ minorities and women evenly on each of its projects. The transfer of minority or female employees or trainees from Contractor to Contractor or from project to project for the sole purpose of meeting the Contractor's goals shall be a violation of the contract, the Executive Order and the regulations in 41 CFR Part 60-4. Compliance with the goals will be measured against the total work hours performed.

3.) The Contractor shall provide written notification to the Director of the Office of Federal Contract Compliance Programs within 10 working days of award of any construction subcontract in excess of \$10,000 at any tier for construction work under the contract resulting from this solicitation. The notification shall list the name, address and telephone number of the subcontractor; employer identification number; estimated dollar amount of the subcontract; estimated starting and completion dates of the subcontract; and the geographical area in which the contract is to be performed.

4.) As used in this Notice, and in the contract resulting from this solicitation, the "covered area" is the City of Pembroke, located in the Savannah, Georgia SMSA, which includes Bryan, Chatham, and Effingham counties.

*Note: See the following Federal Register, Vol. 44, No. 175, dated 9-7-79, for appropriate goals arranged by economic area. The goal for female participation is 6.9% statewide.

Federal Register, Vol. 44, No 175 (8/7/79)
E.O. 11246: Goals for Minority Participation in the Construction Industry

Augusta, Georgia SMSA		Columbus, Georgia SMSA	
<u>SMSA Counties</u>	27.2%	<u>SMSA Counties</u>	29.5%
Columbia		Chattahoochee	
Richmond		Columbus/Muscogee	31.8%
<u>Non-SMSA Counties</u>	32.8%	<u>Non-SMSA Counties</u>	
Burke		Harris	
Emanuel		Marion	
Glascock		Meriwether	
Jefferson		Quitman	
Jenkins		Schley	
Lincoln		Stewart	
McDuffie		Sumter	
Taliaferro		Talbot	
Warren		Troup	
Wilkes		Webster	
Atlanta, Georgia SMSA		Macon, Georgia SMSA	
<u>SMSA Counties</u>	21.2%	<u>SMSA Counties</u>	27.5%
Butts		Bibb	
Cherokee		Houston	
Clayton		Jones	
Cobb		Twiggs	
DeKalb		<u>Non-SMSA Counties</u>	31.7%
Douglas		Baldwin	
Fayette		Bleckley	
Forsyth		Crawford	
Fulton		Crisp	
Gwinette		Dodge	
Henry		Dooly	
Newton		Hancock	
Paulding		Johnson	
Rockdale		Laurens	
Walton		Macon	
<u>Non-SMSA Counties</u>	19.5%	Monroe	
Banks		Peach	
Barrow		Pulaski	
Bartow		Putnam	
Carroll		Taylor	
Clarke		Telfair	
Coweta		Treutlin	
Dawson		Washington	
Elbert		Wheeler	
Fannin		Wilcox	
Floyd		Wilkinson	
Franklin			
Gilmer		Savannah, Georgia SMSA	30.6%
Gordon		<u>SMSA Counties</u>	
Greene		Bryan	
Habersham		Chatham	
Hall		Effingham	
Haralson		<u>Non-SMSA Counties</u>	29.8%
Hart		Appling	
Heard		Atkinson	
Jackson		Bacon	
Jasper		Bulloch	
Lamar		Candler	
Lumpkin		Coffee	
Madison		Evans	
Morgan		Jeff Davis	
Oconee		Liberty	
Oglethorpe		Long	
Pickens		McIntosh	
Pike		Montgomery	
Polk		Screven	
Rabun		Toombs	
Stephens		Wayne	
Towns			
Union			
Upson			
White			

<i>Albany Georgia SMSA</i>	
<u>SMSA Counties</u>	32.1%
Dougherty	
Lee	
<u>Non-SMSA Counties</u>	31.1%
Baker	
Ben Hill	
Berrien	
Brooks	
Calhoun	
Clay	
Clinch	
Colquitt	
Cook	
Decatur	
Early	
Echols	
Grady	
Irwin	
Lanier	
Lowndes	
Miller	
Mitchell	
Randolph	
Seminole	
Terrell	
Thomas	
Tift	
Turner	
Worth	

<i>Jacksonville, Florida SMSA</i>	
<u>Non-SMSA Counties</u>	22.2%
Brantley	
Camden	
Charlton	
Glynn	
Pierce	
Ware	
<i>Chattanooga, Tennessee SMSA</i>	
<u>SMSA Counties</u>	12.5%
Catoosa	
Dade	
Walker	
<u>Non-SMSA Counties</u>	8.5%
Chattoga	
Murray	
Whitfield	

Unofficial

Certification of Nonsegregated Facilities

By the submission of this bid, the bidder, offerer, applicant or subcontractor certifies that s/he does not maintain or provide for his/her employees any segregated facility at any of his/her establishments, and that s/he does not permit employees to perform their services at any location, under his/her control, where segregated facilities are maintained. S/He certifies further that s/he will not maintain or provide for employees any segregated facilities at any of his/her establishments, and s/he will not permit employees to perform their services at any location under his/her control where segregated facilities are maintained. The bidder, offerer, applicant or subcontractor agrees that a breach of this certification is a violation of the Equal Opportunity Clause of this contract. As used in this certification, the term "segregated facilities" means any waiting rooms, work areas, rest rooms and wash rooms, restaurants and other eating areas, time clocks, locker rooms, and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation and housing facilities provided for employees which are segregated by explicit directive or are in fact segregated on the basis of race, color, religion, or national origin, because of habit, local custom, or otherwise. S/He further agrees that (except where s/he has obtained identical certifications from proposed subcontractors for specific time periods) s/he will obtain identical certification from proposed subcontractors prior to the award of subcontracts exceeding \$10,000 which are not exempt from the provisions of the Equal Opportunity Clause; that s/he will retain such certifications in his/her files; and that s/he will forward the following notice to such proposed subcontractors (except where proposed subcontractors have submitted identical certifications for specific time periods).

FEDERAL LABOR STANDARDS PROVISION Georgia Community Development Block Grant

Applicability

The Project or Program to which the construction work covered by this contract pertains is being assisted by the United States of America and the following Federal Labor Standards Provisions are included in this Contract pursuant to the provisions applicable to such Federal assistance.

A.1.(i) **Minimum Wages.** All laborers and mechanics employed or working upon the site of the work (or under the United States Housing Act of 1937 or under the Housing Act of 1949 in the construction or development of the project), will be paid unconditionally and not less often than once a week, and without subsequent deduction or rebate on any account (except such payroll deductions as are permitted by regulations issued by the Secretary of Labor under the Copeland Act (29 CFR Part 3), the full amount of wages and bona fide fringe benefits (or cash equivalents thereof) due at time of payment computed at rates not less than those contained in the wage determination of the Secretary of Labor which is attached hereto and made a part hereof, regardless of any contractual relationship which may be alleged to exist between the contractor and such laborers and mechanics. Contributions made or costs reasonably anticipated for bona fide fringe benefits under Section 1(b)(2) of the Davis-Bacon Act on behalf of laborers or mechanics are considered wages paid to such laborers or mechanics, subject to the provisions of 29 CFR Part 5.5(a)(4). Laborers or mechanics performing work in more than one classification may be compensated at the rate specified for each classification for the time actually worked therein: Provided, that the employer's payroll records accurately set forth the time spent in each classification in which work is performed. The wage determination (including any additional classification and wage rates conformed under 29 CFR Part 5.5(a)(1)(ii)) and the Davis-Bacon poster (WH-1321) shall be posted at all times by the contractor and its subcontractors at the site of the work in a prominent and accessible place where it can be easily seen by the workers.

(ii)(a) The contracting officer shall require that any class of laborers or mechanics, which is not listed in the wage determination and which is to be employed under the contract shall be classified in conformance with the wage determination. The contracting officer shall approve an additional classification and wage rate and fringe benefits therefore only when the following criteria have been met:

(1) The work to be performed by the classification requested is not performed by a classification in the wage determination; and

(2) The classification is utilized in the area by the construction industry; and

(3) The proposed wage rate, including any bona fide fringe benefits, bears a reasonable relationship to the wage rates contained in the wage determination.

(b) If the contractor and the laborers and mechanics to be employed in the classification (if known), or their representatives, and HUD or its designee agree on the classification and wage rate (including the amount designated for fringe benefits where appropriate), a report of the action taken shall be sent by HUD or its designee to the Administrator of the Wage and Hour

Division, Employment Standards Administration, US. Department of Labor, Washington, D.C. 20210. The Administrator, or an authorized representative, will approve, modify, or disapprove every additional classification action within 30 days of receipt and so advise HUD or its designee or will notify HUD or its designee within the 30-day period that additional time is necessary.

(c) In the event the contractor, the laborers or mechanics to be employed in the classification or their representatives, and HUD or its designee do not agree on the proposed classification and wage rate (including the amount designated for fringe benefits, where appropriate), HUD or its designee shall refer the questions, including the views of all interested parties and the recommendation of HUD or its designee, to the Administrator for determination. The Administrator, or an authorized representative, will issue a determination within 30 days of receipt and so advise HUD or its designee or will notify HUD or its designee within the 30-day period that additional time is necessary.

(d) The wage rate (including fringe benefits where appropriate) determined pursuant to subparagraphs (1)(b) or (c) of this paragraph, shall be paid to all workers performing work in the classification under this contract from the first day on which work is performed in the classification.

(iii) Whenever the minimum wage rate prescribed in the contract for a class of laborers or mechanics includes a fringe benefit which is not expressed as an hourly rate, the contractor shall either pay the benefit as stated in the wage determination or shall pay another bona fide fringe benefit or an hourly cash equivalent thereof.

(iv) If the contractor does not make payments to a trustee or other third person, the contractor may consider as part of the wages of any laborer or mechanic the amount of any costs reasonably anticipated in providing bona fide fringe benefits under a plan or program, provided, that the Secretary of Labor has found, upon the written request of the contractor, that the applicable standards of the Davis-Bacon Act have been met. The Secretary of Labor may require the contractor to set aside in a separate account assets for the meeting of obligations under the plan or program. (Approved by the Office of Management and Budget under OMB Control Number 1215-0140.)

2. Withholding. HUD or its designee shall upon its own action or upon written request of an authorized representative of the Department of Labor withhold or cause to be withheld from the contractor under this contract or any other Federal contract with the same prime contractor, or any other Federally-assisted contract subject to Davis-Bacon prevailing wage requirements, which is held by the same prime contractor so much of the accrued payments or advances as may be considered necessary to pay laborers and mechanics, including apprentices, trainees and helpers, employed by the contractor or any subcontractor the full amount of wages required by the contract. In the event of failure to pay any laborer or mechanic, including any apprentice, trainee or helper, employed or working on the site of the work (or under the United States Housing Act of 1937 for under the Housing Act of 1949 in the construction or development of the project), all or part of the wages required by the contract, HUD or its designee may, after written notice to the contractor, sponsor, applicant, or owner, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds until

such violations have ceased. HUD or its designee may, after written notice to the contractor, disburse such amounts withheld for and on account of the contractor or subcontractor to the respective employees to whom they are due. The Comptroller General shall make such disbursements in the case of direct Davis-Bacon Act contracts.

3. (i) **Payrolls and basic records.** Payrolls and basic records relating thereto shall be maintained by the contractor during the course of the work preserved for a period of three years thereafter for all laborers and mechanics working at the site of the work (or under the United States Housing Act of 1937, or under the Housing Act of 1949, in the construction or development of the project.) Such records shall contain the name, address, and social security number of each such worker, his or her correct classification, hourly rates of wages paid (including rates of contributions or costs anticipated for bona fide fringe benefits or cash equivalents thereof of the types described in Section 1(b)(2)(B) of the Davis-Bacon Act), daily and weekly number of hours worked, deductions made and actual wages paid. Whenever the Secretary of Labor has found under 29 CFR 5.5(a)(1)(iv) that the wages of any laborer or mechanic include the amount of any costs reasonably anticipated in providing benefits under a plan or program described in Section 1(b)(2)(B) of the Davis-Bacon Act, the contractor shall maintain records which show that the commitment to provide such benefits is enforceable, that the plan or program is financially responsible, and that the plan or program has been communicated in writing to the laborers or mechanics affected, and records which show the costs anticipated or the actual cost incurred in providing such benefits. Contractors employing apprentices or trainees under approved programs shall maintain written evidence of the registration of apprenticeship programs and certification of trainee programs, the registration of the apprentices and trainees, and the ratios and wage rates prescribed in the applicable program (Approved by the Office of Management and Budget under OMB Control Numbers 1215-0140 and 1215-0017.)

(ii)(a) The contractor shall submit weekly for each week in which any contract work is performed a copy of all payrolls to HUD or its designee if the agency is a party to the contract, but if the agency is not such a party, the contractor will submit the payrolls to the applicant, sponsor, or owner, as the case may be, for transmission to HUD or its designee. The payrolls submitted shall set out accurately and completely all of the information required to be maintained under 29 CFR Part 5.5(a)(3)(i). This information may be submitted in any form desired. Optional Form WH-347 is available for this purpose and may be purchased from the Superintendent of Documents (Federal Stock Number 029-005-00014-1), US. Government Printing Office, Washington, DC, 20402. The prime contractor is responsible for the submission of copies of payrolls by all subcontractors. (Approved by the Office of Management and Budget under OMB Control Number 1215-0149.)

(b) Each payroll submitted shall be accompanied by a "Statement of Compliance," signed by the contractor or subcontractor or his or her agent who pays or supervises the payment of the persons employed under the contract and shall certify the following:

(1) That the payroll for the payroll period contains the information required to be maintained under 29 CFR Part 5.5(a)(3)(i) and that such information is correct and complete;

(2) That each laborer or mechanic (including each helper, apprentice, and trainee) employed on the contract during the payroll period has been paid the full weekly wages earned, without rebate, either directly or indirectly from the full wages earned, other than permissible deductions as set forth in 29 CFR Part 3;

(c) The weekly submission of a properly executed certification set forth on the reverse side of Optional Form WH-347 shall satisfy the requirement for submission of the "Statement of Compliance" required by paragraph A.3(ii)(b) of this section.

(d) The falsification of any of the above certifications may subject the contractor or subcontractor to civil or criminal prosecution under Section 1001 of Title 18 and Section 231 of Title 31 of the United States Code.

(iii) The contractor or subcontractor shall make the records required under paragraph A.3(i) of this section available for inspection, copying, or transcription by authorized representatives of HUD or its designee or the Department of Labor, and shall permit such representatives to interview employees during working hours on the job. If the contractor or subcontractor fails to submit the required records or to make them available, HUD or its designee may, after written notice to the contractor, sponsor, applicant, or owner, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds. Furthermore, failure to submit the required records upon request or to make such records available may be grounds for debarment action pursuant to 29 CFR Part 5.12.

4.(i) Apprentices and Trainees. Apprentices. Apprentices will be permitted to work at less than the predetermined rate for the work they performed when they are employed pursuant to and individually registered in a bona fide apprenticeship program registered with the US. Department of Labor, Employment and Training Administration, Bureau of Apprenticeship and Training, or with a State Apprenticeship Agency recognized by the Bureau, or if a person is employed in his or her first 90 days of probationary employment as an apprentice in such an apprenticeship program, who is not individually registered in the program, but who has been certified by the Bureau of Apprenticeship and Training or a State Apprenticeship Agency (where appropriate) to be eligible for probationary employment as an apprentice. The allowable ratio of apprentices to journeymen on the job site in any craft classification shall not be greater than the ratio permitted to the contractor as to the entire work force under the registered program. Any worker listed on a payroll at an apprentice wage rate, who is not registered or otherwise employed as stated above, shall be paid not less than the applicable wage rate on the wage determination for the classification of work actually performed. In addition, any apprentice performing work on the job site in excess of the ration permitted under the registered program shall be paid not less than the applicable wage rate on the wage determination for the work actually performed. Where a contractor is performing construction on a project in a locality other than that in which its program is registered, the ratios and wage rates (expressed in percentages of the journeymen's hourly rate) specified in the contractor's or subcontractor's registered program shall be observed. Every apprentice must be paid at not less than the rate specified in the registered program for the apprentice's level of progress, expressed as a percentage of the journeymen hourly rate specified in the applicable wage determination. Apprentices shall be paid fringe benefits in accordance with the provisions of the apprenticeship

program. If the apprenticeship program does not specify fringe benefits, apprentices must be paid the full amount of fringe benefits listed on the wage determination for the applicable classification.

If the Administrator determines that a different practice prevails for the applicable apprentice classification, fringes shall be paid in accordance with that determination. In the event the Bureau of Apprenticeship and Training, or a State Apprenticeship Agency recognized by the Bureau, withdraws approval of an apprenticeship program, the contractor will no longer be permitted to utilize apprentices at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

(ii) **Trainees.** Except as provided in 29 CFR 5.16, trainees will not be permitted to work at less than the predetermined rate for the work performed unless they are employed pursuant to and individually registered in a program which has received prior approval, evidenced by formal certification by the US. Department of Labor, Employment and Training Administration. The ratio of trainees to journeymen on the job site shall not be greater than permitted under the plan approved by the Employment and Training Administration. Every trainee must be paid at not less than the rate specified in the approved program for the trainee's level of progress, expressed as a percentage of the journey hourly rate specified in the applicable wage determination. Trainees shall be paid fringe benefits in accordance with the provisions of the trainee program. If the trainee program does not mention fringe benefits, trainees shall be paid the full amount of fringe benefits listed on the wage determination unless the Administrator of the Wage and Hour Division determines that there is an apprenticeship program associated with the corresponding journeyman wage rate on the wage determination which provides for less than full fringe benefits for apprentices. Any employee listed on the payroll at a trainee rate who is not registered and participating in a training plan approved by the Employment and Training Administration shall be paid not less than the applicable wage rate on the wage determination for the work actually performs. In addition, any trainee performing work on the job site in excess of the ration permitted under the registered program shall be paid not less than the applicable wage rate on the wage determination for the work actually performed. In the event the Employment and Training Administration withdraws approval of a training program, the contractor will no longer be permitted to utilize trainees at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

(iii) **Equal employment opportunity.** The utilization of apprentices, trainees and journeymen under this part shall be in conformity with the equal employment opportunity requirements of Executive Order 11246, as amended, and 29 CFR Part 30.

5. Compliance with Copeland Act requirements. The contractor shall comply with the requirements of 29 CFR Part 3 which are incorporated by reference in this contract.

6. Subcontracts. The contractor or subcontractor will insert in any subcontracts the clauses contained in 29 CFR 5.5(a)(1) through (10) and such other clauses as HUD or its designee may be appropriate instructions require, and also a clause requiring the subcontractors to include these clauses in any lower tier subcontracts. The prime contractor shall be responsible for the

compliance by any subcontractor or lower tier subcontractor with all the contract clauses in 29 CFR Part 5.5.

7. **Contract termination:** debarment. A breach of the contract clauses in 29 CFR 5.5 may be grounded for termination of the contract, and for debarment as a contractor and a subcontractor as provided in 29 CFR 5.12.

8. **Compliance with Davis-Bacon and Related Act Requirements.** All rulings and interpretations of the Davis-Bacon and Related Acts contained in 29 CFR Parts 1, 3, and 5 are herein incorporated by reference in this contract.

9. **Disputes concerning labor standards.** Disputes arising out of a labor standards provision of this contract shall to be subject to the general disputes clause of this contract. Such disputes shall be resolved in accordance with the procedures of the Department of Labor set forth in 29 CFR Parts 5, 6 and 7. Disputes within the meaning of this clause include disputes between the contractor (or any of its subcontractors) and HUD or its designee, the US. Department of Labor, or the employees or their representatives.

10. (i) **Certification of Eligibility.** By entering into this contract, the contractor certifies that neither it (nor he or she) nor any person or firm who has an interest in the contractor's firm is a person or firm ineligible to be awarded Government contracts by virtue of Section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1) or to be awarded HUD contracts or participate in HUD programs pursuant to 24 CFR Part 24.

(ii) No part of this contract shall be subcontracted to any person or firm ineligible for award of a Government contract by virtue of Section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1) or to be awarded HUD contracts or participate in HUD programs pursuant to 24 CFR Part 24.

(iii) The penalty for making false statements is prescribed in the US. Criminal Code, 18 U.S.C. 1001. Additionally, US. Criminal Code, Section 1010, Title 18, U.S.C., "Federal Housing Administration transactions", provides in part: "Whoever, for the purpose of ...influencing in any way the action of such Administration...makes, utters or publishes any statement, knowing the same to be false...shall be fined not more than \$5,000 or imprisoned not more than two years, or both."

11. **Complaints, Proceedings, or Testimony by Employees.** No laborer or mechanic to whom the wage, salary, or other labor standards provisions of this Contract are applicable shall be discharged or in any other manner discriminated against by the Contractor or any subcontractor because such employee has filed any complaint or instituted or caused to be instituted any proceeding or has testified or is about to testify in any proceeding under or relating to the labor standards applicable under this Contract to his employer.

B. Contract Work Hours and Safety Standards Act. As used in this paragraph, the terms "laborers" and "mechanics" include watchmen and guards.

(1) **Overtime requirements:** No contractor or subcontractor contracting for any part of the contract work may require or involve the employment of laborers or mechanics shall require or permit any such laborer or mechanic in any workweek in which he or she is employed on such work to work in excess of forty hours in such workweek unless such laborer or mechanic receives compensation at a rate not less than one and one-half times the basic rate of pay for all hours worked in excess of forty hours in such workweek.

(2) **Violation:** liability for unpaid wages, liquidated damages. In the event of any violation of the clause set forth in subparagraph (1) of this paragraph, the contractor and any subcontractor responsible therefore shall be liable for the unpaid wages. In addition, such contractor and subcontractor shall be liable to the United States (in the case of work done under contract for the District of Columbia or a territory, to such District or to such territory), for liquidated damages. Such liquidated damages shall be computed with respect to each individual laborer or mechanic, including watchmen and guards, employed in violation of the clause set forth in subparagraph (1) of this paragraph, in the sum of \$10 for each calendar day on which such individual was required or permitted to work in excess of the standard workweek of forty hours without payment of the overtime wages required by the clause set forth in subparagraph (1) of this paragraph.

(3) **Withholding for unpaid wages and liquidated damages:** HUD or its designee shall upon its own action or upon written request of an authorized representative of the Department of Labor withhold or cause to be withheld, from any money payable on account of work performed by the contractor or subcontractor under any such contract or any other Federal contract with the same prime contractor such sums as may be determined to be necessary to satisfy any liabilities of such contractor or subcontractor for unpaid wages and liquidated damages as provided in the clause set forth in subparagraph (2) of this paragraph.

(4) **Subcontracts:** The contractor or subcontractor shall insert in any subcontracts the clauses set forth in subparagraph (1) through (4) of this paragraph and also a clause requiring the subcontractors to include these clauses in any lower tier subcontracts. The prime contractor shall be responsible for compliance by any subcontractor or lower tier subcontractor with the clauses set forth in subparagraphs (1) through (4) of this paragraph.

C. Health and Safety

(1) No laborer or mechanic shall be required to work in surroundings or under working conditions which are unsanitary, hazardous, or dangerous to his health and safety as determined under construction safety and health standards promulgated by the Secretary of Labor by regulation.

(2) The Contractor shall comply with all regulations issued by the Secretary of Labor pursuant to Title 29 Part 1926 (formerly part 1518) and failure to comply may result in imposition of sanctions pursuant to the Contract Work Hours and Safety Standards Act (Public Law 91-54, 83 Stat. 96).

(3) The Contractor shall include the provisions of this Article in every subcontract so that such provisions will be binding on each subcontractor. The Contractor shall take such action with

respect to any subcontract as the Secretary of Housing and Urban Development or the Secretary of Labor shall direct as a means of enforcing such provisions.

Unofficial

**ACCEPTABLE ALTERNATE WORK SHEET FOR CONTRACTOR CERTIFICATION
REGARDING DEBARMENT, SUSPENSION, INELIGIBILITY AND VOLUNTARY EXCLUSION
(LOWER-TIER PARTICIPANT) FOR HUD PROGRAMS**

Certification regarding Debarment, Suspension, Ineligibility and Voluntary Exclusion-Lower-Tier Covered Transactions pursuant to 24 Code of Federal Regulations, Part 24.510(b).

1. By signing and submitting this proposal, the prospective lower-tier participant certifies that neither it, its principals nor affiliates, is presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from participation in this transaction by any Federal department or agency. Further, the Participant provides the certification set out below.
2. The certification in this clause is a material representation of fact upon which reliance was placed when this transaction was entered into. If it is later determined that an erroneous certification was rendered, in addition to other remedies available to the Federal Government, the Department or agency with which this transaction originated may pursue available remedies.
3. Further, the Participant shall provide immediate written notice to the person to which this proposal is submitted if at any time the Participant learns that this certification was erroneous when submitted or has become erroneous by reason of changed circumstances.
4. By submitting this proposal, it is agreed that should the proposed covered transaction be entered into, the Participant will not knowingly enter into any lower-tier covered transaction with a person who is debarred, suspended, declared ineligible, or voluntarily excluded from participation in this covered transaction unless authorized by the agency with which this transaction originated.
5. It is further agreed that by submitting this proposal, the Participant will include this Certification, without modification, in all lower-tier covered transactions and in all solicitations for lower-tier covered transactions.

Contractor Name _____ Date _____

Title _____ Address _____

City _____ State _____ Zip _____

NON-CERTIFICATION:

As the perspective lower-tier participant, I am unable to certify to statements in this Certification as explained in the attachment to this proposal.

Contractor Name _____ Date _____

Title _____ Address _____

City _____ State _____ Zip _____

The penalty for making false statements is prescribed in the U.S. Criminal Code, 18 U.S.C. 1001.

COMPLIANCE WITH CLEAN AIR AND WATER ACTS

The contract is subject to the requirements of the Clean Air Act, as amended, 42 USC 1857 et. seq., and the regulations of the Environmental Protection Agency with respect thereto, at 40 CFR Part 15, as amended from time to time.

In compliance with said regulations:

- 1.) The Contractor shall require of subcontractors that any facility to be utilized in the performance of any nonexempt contract or subcontract is not listed on the List of Violating Facilities issued by the Environmental Protection Agency (EPA) pursuant to 4C CFR 15.20.
- 2.) The Contractor will comply with all the requirements of Section 114 of the Clean Air Act, as amended, (42 USC 1857c-8) and section 308 of the Federal Water Pollution Control Act as amended, (330 USC 1318) relating to inspection, monitoring, entry, reports, and information, as well as all other requirements specified in said section 114 and section 308, and all regulations and guidelines issued thereunder.
- 3.) The Contractor will provide prompt notice of any notification received from the Director, Office of Federal Activities, EPA, indicating that a facility utilized or to be utilized for the contract is under consideration to be listed on the EPA List of Violating Facilities.
- 4.) The Contract will include or cause to be included the criteria and requirements to paragraph (1) through (4) of this section in every nonexempt subcontract and take such action as the Government will direct as a means of enforcing such provisions.

PERFORMANCE, PAYMENT and BID BONDS

Contract Performance and Payment Bonds issued in the full amount of the contract are required by federal procurement rules if the contract is for \$20,000 or more. Note that state law requirement is \$40,000 for Performance, Payment and Bid Bonds.

A Bid Bond or other security is required by federal rules whenever the contract is for \$100,000 or more.

Generally these bonds must be issued by a surety company satisfactory to the local government, qualified to do business in Georgia, and in a format meeting the federal and state legal requirements. The bonding company must also appear on the "List of Acceptable Sureties" published annually by the US Department of the Treasury.

DCA recommends that CDBG Recipients be sure to assign responsibility for reviewing construction bonds. This job may be given to the local attorney, the grant administrator, or the project architect/engineer. Specific duties include verification that the agent is licensed by the state and authorized by the bonding company and verification through the Insurance Commissioner that the company is financially sound and licensed in Georgia. The actual bond should also be reviewed and verified as being valid.

Unofficial

A1. DAVIS-BACON WAGES

Unofficial

"General Decision Number: GA20240294 01/05/2024

Superseded General Decision Number: GA20230294

State: Georgia

Construction Type: Heavy

Counties: Bryan and Effingham Counties in Georgia.

HEAVY CONSTRUCTION PROJECTS

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

<p>If the contract is entered into on or after January 30, 2022, or the contract is renewed or extended (e.g., an option is exercised) on or after January 30, 2022:</p>	<ul style="list-style-type: none"> . Executive Order 14026 generally applies to the contract. . The contractor must pay all covered workers at least \$17.20 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2024.
<p>If the contract was awarded on or between January 1, 2015 and January 29, 2022, and the contract is not renewed or extended on or after January 30, 2022:</p>	<ul style="list-style-type: none"> . Executive Order 13658 generally applies to the contract. . The contractor must pay all covered workers at least \$12.90 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on that contract in 2024.

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

Modification Number Publication Date
0 01/05/2024

	Rates	Fringes
CARPENTER (Form Work Only).....	\$ 24.02	10.71
CARPENTER, Excludes Form Work....	\$ 24.34	4.53
CEMENT MASON/CONCRETE FINISHER...	\$ 21.40	4.25
ELECTRICIAN.....	\$ 23.67	8.02
LABORER: Common or General.....	\$ 15.81 **	2.44
LABORER: Pipelayer.....	\$ 16.95 **	0.00
OPERATOR: Backhoe/Excavator/Trackhoe.....	\$ 22.31	3.29
OPERATOR: Bulldozer.....	\$ 16.29 **	0.00
OPERATOR: Crane.....	\$ 25.45	0.00
OPERATOR: Loader.....	\$ 22.13	0.00
OPERATOR: Roller.....	\$ 11.89 **	0.00

Please specify type of:
*Laborer
*Operator

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.
=====

** Workers in this classification may be entitled to a higher minimum wage under Executive Order 14026 (\$17.20) or 13658 (\$12.90). Please see the Note at the top of the wage determination for more information. Please also note that the minimum wage requirements of Executive Order 14026 are not currently being enforced as to any contract or subcontract to which the states of Texas, Louisiana, or Mississippi, including their agencies, are a party.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of ""identifiers"" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than ""SU"" or ""UAVG"" denotes that the union classification and rate were prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. 07/01/2014 is the effective date of the most current negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

Survey Rate Identifiers

Classifications listed under the ""SU"" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of

each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- * a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour National Office because National Office has responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

=====
END OF GENERAL DECISION"

"General Decision Number: GA20240065 09/20/2024

State: Georgia

Construction Type: Highway

Counties: Brantley, Bryan, Chatham, Effingham, Glynn, Liberty, Long and McIntosh Counties in Georgia.

HIGHWAY CONSTRUCTION PROJECTS

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

<p>If the contract is entered into on or after January 30, 2022, or the contract is renewed or extended (e.g., an option is exercised) on or after January 30, 2022:</p>	<ul style="list-style-type: none"> ◆ Executive Order 14026 generally applies to the contract. ◆ The contractor must pay all covered workers at least \$17.20 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2024.
<p>If the contract was awarded on or between January 1, 2015 and January 29, 2022, and the contract is not renewed or extended on or after January 30, 2022:</p>	<ul style="list-style-type: none"> ◆ Executive Order 13658 generally applies to the contract. ◆ The contractor must pay all covered workers at least \$12.90 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours performing on that contract in 2024.

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

Modification Number Publication Date
 0 09/20/2024

	Rates	Fringes
CARPENTER.....	\$ 32.68	0.00
CEMENT MASON/CONCRETE FINISHER...	\$ 28.44	0.00
LABORER: Asphalt, Includes Raker, Shoveler, Spreader and Distributor.....	\$ 16.72 **	2.23
LABORER: Common or General.....	\$ 18.46	0.00
LABORER: Pipelayer.....	\$ 22.42	0.00
OPERATOR: Backhoe/Excavator/Trackhoe.....	\$ 23.40	3.73
OPERATOR: Bulldozer.....	\$ 22.82	0.00
OPERATOR: Crane.....	\$ 39.31	0.00
OPERATOR: Grader/Blade.....	\$ 26.31	5.43
OPERATOR: Loader.....	\$ 22.81	1.91
OPERATOR: Paver (Asphalt, Aggregate, and Concrete).....	\$ 23.22	4.10
OPERATOR: Roller.....	\$ 18.51	3.99
TRAFFIC CONTROL: Flagger.....	\$ 14.64 **	0.00
TRUCK DRIVER: Dump Truck.....	\$ 21.58	3.58

Please specify type of:
*Laborer
*Operator

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.
=====

** Workers in this classification may be entitled to a higher minimum wage under Executive Order 14026 (\$17.20) or 13658 (\$12.90). Please see the Note at the top of the wage determination for more information. Please also note that the minimum wage requirements of Executive Order 14026 are not currently being enforced as to any contract or subcontract to which the states of Texas, Louisiana, or Mississippi, including their agencies, are a party.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information

on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of ""identifiers"" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than ""SU"" or ""UAVG"" denotes that the union classification and rate were prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. 07/01/2014 is the effective date of the most current negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

Survey Rate Identifiers

Classifications listed under the ""SU"" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate

that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

State Adopted Rate Identifiers

Classifications listed under the ""SA"" identifier indicate that the prevailing wage rate set by a state (or local) government was adopted under 29 C.F.R. 1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 01/03/2024 reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- * a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour National Office because National Office has responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator
U.S. Department of Labor

200 Constitution Avenue, N.W.
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

=====

END OF GENERAL DECISION"

Unofficial

EMPLOYEE RIGHTS

UNDER THE DAVIS-BACON ACT

FOR LABORERS AND MECHANICS EMPLOYED ON FEDERAL OR FEDERALLY ASSISTED CONSTRUCTION PROJECTS

PREVAILING WAGES

You must be paid not less than the wage rate listed in the Davis-Bacon Wage Decision posted with this Notice for the work you perform.

OVERTIME

You must be paid not less than one and one-half times your basic rate of pay for all hours worked over 40 in a work week. There are few exceptions.

ENFORCEMENT

Contract payments can be withheld to ensure workers receive wages and overtime pay due, and liquidated damages may apply if overtime pay requirements are not met. Davis-Bacon contract clauses allow contract termination and debarment of contractors from future federal contracts for up to three years. A contractor who falsifies certified payroll records or induces wage kickbacks may be subject to civil or criminal prosecution, fines and/or imprisonment.

APPRENTICES

Apprentice rates apply only to apprentices properly registered under approved Federal or State apprenticeship programs.

PROPER PAY

If you do not receive proper pay, or require further information on the applicable wages, contact the Contracting Officer listed below:

or contact the U.S. Department of Labor's Wage and Hour Division.



OSHA[®]
Occupational Safety
and Health Administration

Job Safety and Health

All workers have the right to:

- A safe workplace.
- Raise a safety or health concern with your employer or OSHA, or report a work-related injury or illness, without being retaliated against.
- Receive information and training on job hazards, including all hazardous substances in your workplace.
- Request a confidential OSHA inspection of your workplace if you believe there are unsafe or unhealthy conditions. You have the right to have a representative contact OSHA on your behalf.
- Participate (or have your representative participate) in an OSHA inspection and speak in private to the inspector.
- File a complaint with OSHA within 30 days (by phone, online or by mail) if you have been retaliated against for using your rights.
- See any OSHA citations issued to your employer.
- Request copies of your medical records, tests that measure hazards in the workplace, and the workplace injury and illness log.

This poster is available free from OSHA.

Contact OSHA. We can help.

Employers must:

- Provide employees a workplace free from recognized hazards. It is illegal to retaliate against an employee for using any of their rights under the law, including raising a health and safety concern with you or with OSHA, or reporting a work-related injury or illness.
- Comply with all applicable OSHA standards.
- Notify OSHA within 8 hours of a workplace fatality or within 24 hours of any work-related inpatient hospitalization, amputation, or loss of an eye.
- Provide required training to all workers in a language and vocabulary they can understand.
- Prominently display this poster in the workplace.
- Post OSHA citations at or near the place of the alleged violations.

On-Site Consultation services are available to small and medium-sized employers, without citation or penalty, through OSHA-supported consultation programs in every state.



DERECHOS DEL EMPLEADO BAJO LA LEY DAVIS-BACON

PARA OBREROS Y MECÁNICOS EMPLEADOS EN PROYECTOS DE CONSTRUCCIÓN FEDERAL O CON ASISTENCIA FEDERAL

SALARIOS PREVALECIENTES

No se le puede pagar menos de la tasa de pago indicada en la Decisión de Salarios Davis-Bacon fijada con este Aviso para el trabajo que Ud. desempeña.

SOBRETIEMPO

Se le ha de pagar no menos de tiempo y medio de su tasa básica de pago por todas las horas trabajadas en exceso de 40 en una semana laboral. Existen pocas excepciones.

CUMPLIMIENTO


Se pueden retener pagos por contratos para asegurarse que los obreros reciban los salarios y el pago de sobretiempo debidos, y se podría aplicar daños y perjuicios si no se cumple con las exigencias del pago de sobretiempo. Las cláusulas contractuales de Davis-Bacon permiten la terminación y exclusión de contratistas para efectuar futuros contratos federales hasta tres años. El contratista que falsifique los registros certificados de las nóminas de pago o induzca devoluciones de salarios puede ser sujeto a procesamiento civil o criminal, multas y/o encarcelamiento.

APRENDICES

Las tasas de aprendices sólo se aplican a aprendices correctamente inscritos bajo programas federales o estatales aprobados.

PAGO APROPIADO

Si Ud. no recibe el pago apropiado, o precisa de información adicional sobre los salarios aplicables, póngase en contacto con el Contratista Oficial que aparece abajo:



o póngase en contacto con la División de Horas y Salarios del Departamento de Trabajo de los EE.UU.



DIVISIÓN DE HORAS Y SALARIOS
DEPARTAMENTO DE TRABAJO DE LOS EE.UU.

1-866-487-9243
TTY: 1-877-889-5627
www.dol.gov/whd





OSHA[®]
Administración de
Seguridad y Salud
Ocupacional

Seguridad y Salud en el Trabajo ¡ES LA LEY!

Todos los trabajadores tienen el derecho a:

- Un lugar de trabajo seguro.
- Decir algo a su empleador o la OSHA sobre preocupaciones de seguridad o salud, o reportar una lesión o enfermedad en el trabajo, sin sufrir represalias.
- Recibir información y entrenamiento sobre los peligros del trabajo, incluyendo sustancias tóxicas en su sitio de trabajo.
- Pedirle a la OSHA inspeccionar su lugar de trabajo si usted cree que hay condiciones peligrosas o insalubres. Su información es confidencial. Algún representante suyo puede comunicarse con OSHA a su nombre.
- Participar (o su representante puede participar) en la inspección de OSHA y hablar en privado con el inspector.
- Presentar una queja con la OSHA dentro de 30 días (por teléfono, por internet, o por correo) si usted ha sufrido represalias por ejercer sus derechos.
- Ver cualquier citación de la OSHA emitidas a su empleador.
- Pedir copias de sus registros médicos, pruebas que miden los peligros en el trabajo, y registros de lesiones y enfermedades relacionadas con el trabajo.

Los empleadores deben:

- Proveer a los trabajadores un lugar de trabajo libre de peligros reconocidos. Es ilegal discriminar contra un empleado quien ha ejercido sus derechos bajo la ley, incluyendo hablando sobre preocupaciones de seguridad o salud a usted o con la OSHA, o por reportar una lesión o enfermedad relacionada con el trabajo.
- Cumplir con todas las normas aplicables de la OSHA.
- Reportar a la OSHA todas las fatalidades relacionadas con el trabajo dentro de 8 horas, y todas hospitalizaciones, amputaciones y la pérdida de un ojo dentro de 24 horas.
- Proporcionar el entrenamiento requerido a todos los trabajadores en un idioma y vocabulario que pueden entender.
- Mostrar claramente este cartel en el lugar de trabajo.
- Mostrar las citaciones de la OSHA acerca del lugar de la violación alegada.

Los empleadores de tamaño pequeño y mediano pueden recibir ASISTENCIA GRATIS para identificar y corregir los peligros sin citación o multa, a través de los programas de consultación apoyados por la OSHA en cada estado.

Este cartel está disponible de la OSHA para gratis.

Llame OSHA. Podemos ayudar.



A2. BABA ACT REQUIREMENTS

Unofficial

State of Georgia's Non-Entitlement Community Development Block Grant (CDBG) Program



Build America, Buy America (BABA) CDBG Requirements

Build America, Buy America (BABA) CDBG Requirements

Build America, Buy America Summary

- Enacted in the Infrastructure Investment and Jobs Act signed by President Biden on November 15, 2021. Final rule issued for 2 CFR Parts 184 and 200.
- Requires that products purchased in connection with infrastructure projects funded by Federal financial assistance programs must be “produced in the United States”.
 - This requirement is known as the “Buy America Preference (BAP).”
- The following products used in Federally funded infrastructure projects must be produced in the United States:
 - Iron and steel;
 - Manufactured products; and
 - Construction materials.
- For the purposes of BABA, an infrastructure project is defined as any project that includes the following activities: Construction, Alteration, Maintenance, Repair.
- Infrastructure includes: Buildings and real property (including housing), utilities, water and sewer systems, electrical transmission facilities and systems, broadband infrastructure, transportation infrastructure.
- Non-construction materials or Section 70917(c) Materials - defined in 2 CFR 184.3 and means cement and cementitious materials: aggregates such as stone, sand, or gravel, or aggregate binding agents or additives. These materials are not considered “construction materials” for the purpose of BABA implementation.

Produced in the United States as defined in 2 CFR 184.3

- 1) Iron or Steel Products** - all manufacturing processes, from the initial melting stage through the application of coatings, occurred in the United States.
- 2) In the case of manufactured products:**
 - a) The product was manufactured in the United States; and
 - b) The cost of components of the manufactured product that are mined, produced, or manufactured in the United States is greater than 55 percent of the total cost of all components of the manufactured product, unless another standard that meets or exceeds this standard has been established under applicable law or regulation for determining the minimum amount of domestic content of the manufactured product. See 2 CFR 184.2(a). The costs of components of a manufactured product are determined according to 2 CFR 184.5.
- 3) Construction Materials** - all manufacturing processes for the construction material occurred in the United States. See 2 CFR 184.6 for more information on the meaning of “all manufacturing processes” for specific construction materials.

Applicability to CDBG Projects

Prior to funding, compliance with the Buy America Preference must be considered regarding the availability of products and the impacts of compliance on costs. Additionally, these considerations must be addressed on form DCA-5 of CDBG applications.

- Three (3) general applicability waivers are currently in effect for HUD programs and apply to all Covered CPD Programs. Each waiver is outlined below.
 1. **Phased Implementation** – Waiver published March 15, 2023, establishes a phased implementation schedule for application of the BAP to HUD programs. Funds obligated by HUD after November 14, 2022, are subject to the BAP.

Build America, Buy America (BABA) CDBG Requirements

- a. **Iron and Steel** - BAP applies to iron and steel for CDBG projects awarded by DCA in 2023 and going forward.
 - b. **Specifically Listed Construction Materials** – BAP applies to “Specifically Listed Construction Materials” for CDBG projects awarded by DCA in 2024 and going forward. Specifically listed construction materials include; Metals other than iron or steel (non-ferrous metals), lumber, composite building materials, plastic and polymer-based pipes/tubes.
 - c. **All Other Construction Materials** – BAP applies to “all other construction materials” for CDBG projects awarded by DCA in 2025 and going forward. All other construction materials include: glass, drywall, and other construction materials
 - d. **Manufactured Products** – BAP applies to manufactured products for CDBG projects awarded by DCA in 2025 and going forward. Manufactured products are defined as a material or supply used in an infrastructure project that is not iron or steel or a construction material. When two or more materials are combined, they should be treated as a manufactured product.
2. **Exigent Circumstances** - BAP may be waived if projects must be completed immediately to protect life, ensure safety, or prevent the destruction of property. Effective until November 23, 2027
 3. **De Minimis, Small Grants & Minor Components** - BAP waived for projects with a total cost of \$250,000 or less. BAP waived for a de minimis portion that comprises no more than 5 percent of the total cost of covered materials used in a project, up to \$1 million. Effective until November 23, 2027

General Compliance Requirements

CDBG Recipients must retain supporting documentation from subrecipients, contractors, and vendors to develop records demonstrating compliance with the BABA requirements on a project and material level basis, regardless of whether infrastructure is the primary purpose of the project.

- Documenting the Country of Origin
- Bidding Requirements
- Contract Requirements

Documenting the Country of Origin

Recipients will ensure the products delivered to the construction site are accompanied by proper documentation demonstrating compliance with the law and made available to the funding authority upon request. The documentation may be received and maintained in hard copy or electronically. The use of a signed certification letter by the manufacturer for the project is the most direct and effective form of compliance documentation for ensuring products used on site are BABA-compliant prior to their installation; however, other forms of documentation are also acceptable if collectively, the following can be demonstrated:

- Documentation linked to the project. For example, this can be in the form of the project name, project location, contract number, or project number.

Build America, Buy America (BABA) CDBG Requirements

- Documentation linked to the product used on the project. For example, description of product(s) (simple explanation sufficient to identify the product(s)), or an attached (or electronic link to) purchase order, invoice, or bill of lading.
- Documentation includes statement attesting that the products supplied to the assistance recipient are compliant with BABA requirement. Reference to the Infrastructure Investment and Jobs Act ("IIJA") or the Bipartisan Infrastructure Law (BIL) are also acceptable. For iron and steel items under BABA, references to the American Iron and Steel (AIS) requirements are also acceptable and reciprocal with BABA for such items.
- Documentation that manufacturing occurred in the United States, which could include, for example, the location(s) of manufacturing for each manufacturing step that is being certified. It is acceptable for manufactured products to note a single point of manufacturing, documenting that the final point of manufacturing is in the United States. Note that each BABA category may require different determinations for compliance
- Signature of company representative (on company letterhead and signature can be electronic). The signatory of the certifying statement affirms their knowledge of the manufacturing processes for the referenced product(s) and attests that the product meets the BABA requirements.

In addition to compliance documentation, Grantees or their representatives should also conduct a visual inspection of the product when it arrives to the project site, especially for iron and steel products which are often stamped with the country of origin.

Note: A country of origin stamp alone is not sufficient verification of compliance with BABA and assistance receipts should not rely on it to ensure compliance.

Other Certification Methods for Iron & Steel

- Material Test Reports (MTRs, commonly referred to as "Mill Certifications" or "Mill Certs") provide the chemical composition of steel and iron from a mill or foundry. If an MTR accompanies the delivery of steel or iron to a project site with an invoice or bill of lading, it will be considered sufficient to demonstrate compliance (equivalent to a certification letter) as long as the MTR includes a manufacturer representative's signature in addition to the location (city and state) of the mill/foundry. It is common for MTRs to be the first letter in a "step certification" if the product is further fabricated or painted, etc., by another manufacturer.

Bidding Requirements

Advertisement for Bids

- This agreement is for services related to a project that is subject to the Build America, Buy America Act (BABAA) requirements under Title IX of the Infrastructure Investment and Jobs Act ("IIJA"), Pub. L. 177-58. Absent an approved waiver, all iron, steel, manufactured products, and construction materials used in this project must be produced in the United States, as further outlined by the Office of Management and Budget's Memorandum M-22-11, Initial Implementation Guidance on Application of Buy America Preference in Federal Financial Assistance Programs for Infrastructure, April 18, 2022.

Build America, Buy America (BABA) CDBG Requirements

Instructions to Bidders

- Any request for substitute or “or equal” shall include the Manufacturer’s Certification of compliance with the Build America, Buy America Act (BABAA) requirements mandated by Title IX of the Infrastructure Investment and Jobs Act (“IIJA”), Pub. L. 177-58. Include the following, in the Federal requirements section: BABAA requirements apply to this project.

Please note: Country of Origin compliance documentation will be required prior to the drawdown of construction funds.

Bid Form

- Bidder’s representation section: Bidder is familiar with all laws and regulations that may affect cost, progress, and performance of the work, including BABAA requirements.

Contract Requirements

- Compliance with BABA must be spelled out in agreements for services, construction contracts, and procurement contracts. Generally, the architect/engineer’s contract should include, as a basic service, obtaining and maintaining all BABA documentation (particularly manufacturers’ certifications) during construction, which shall be transferred to the recipient. The architect or engineer will need to certify to this action at the project’s end.
- At a minimum, the following must be included in all construction contract documents: All requirements of the Build America, Buy America (BABA) Act, 41 USC 8301 note, and all applicable rules and notices, as may be amended, shall be complied with if applicable to the infrastructure project. Pursuant to HUD’s Notice, “Public Interest Phased Implementation Waiver for FY 2022 and 2023 of Build America, Buy America Provisions as Applied to Recipients of HUD Federal Financial Assistance” (88 FR 17001), any funds obligated by HUD on or after the applicable listed effective dates, are subject to BABA requirements, unless excepted by a waiver.
- Additionally, contractor construction contract(s) must include a requirement to procure and install only items that comply with BABA or are subject to an approved waiver. Contractors must provide manufacturers’ certifications for all BABA compliant items to the responsible party before a request for reimbursement to the agency is made. The contractor will be required to certify that all items used on the contract complied with BABAA and that all manufacturers’ certifications were provided.

Project Specific Waivers – Submission portal <https://babawaiver.hud.gov/s/>

Project-/product-specific waivers are available on a limited, case-by-case basis, after HUD’s review, a public comment period, and final approval from the Made In America Office (MIAO). If more than one Federal agency is funding an infrastructure project, project-/product-specific waivers will require coordination among those Federal agencies prior to a determination by the MIAO. Please note, DCA CDBG Recipients’ wishing to submit a waiver must coordinate this with DCA, as only direct HUD Recipients may submit waiver applications. As such, waiver applications will not be accepted by HUD from DCA CDBG Recipients. If you think a project

Build America, Buy America (BABA) CDBG Requirements

specific waiver is necessary, please contact DCA at CDBG.Biz@dca.ga.gov . There are three (3) categories of waivers:

1. Public interest: BAP would be inconsistent with the public interest.
2. Nonavailability: covered materials are not produced in the US in sufficient and reasonably available quantities or of a satisfactory quality.
3. Unreasonable cost: inclusion of domestically produced covered materials will increase the cost of the overall project by more than 25 percent.

For HUD to consider a project/product-specific waiver the CDBG grantee must provide the following details as required by the MIAO:

- A detailed justification for the use of goods, products, or materials mined, produced, or manufactured outside the United States.
- A certification that there was a good faith effort to solicit bids for domestic products supported by terms included in requests for proposals, contracts, and nonproprietary communications with potential suppliers.
- Each proposed waiver should include the following information, as applicable:
 - Waiver type (nonavailability, unreasonable cost, or public interest).
 - Recipient name and Unique Entity Identifier (UEI).
 - Federal awarding agency organizational information (e.g., Common Governmentwide Accounting Classification (CGAC) Agency Code).
 - Financial assistance listing name and number
 - Federal financial assistance program name.
 - Federal Award Identification Number (FAIN) (if available).
 - Federal financial assistance funding amount.
 - Total estimated infrastructure expenditures, including all Federal and non-Federal funds (to the extent known).
 - Infrastructure project description and location (to the extent known).
 - List of iron or steel item(s), manufactured products, and construction material(s) proposed to be excepted from Buy America requirements, including name, cost, country(ies) of origin (if known), and relevant PSC and NAICS code for each.
 - A certification that the Federal official or assistance recipient made a good faith effort to solicit bids for domestic products supported by terms included in requests for proposals, contracts, and nonproprietary communications with the prime contractor.
 - A statement of waiver justification, including a description of efforts made (e.g., market research, industry outreach), by the Federal awarding agency and, and in the case of a project or award specific waiver, by the recipient, in an attempt to avoid the need for a waiver. Such a justification may cite, if applicable, the absence of any Buy America-compliant bids received in response to a solicitation.
 - Anticipated impact if no waiver is issued.
 - Any relevant comments received through the public comment period.

For general waiver inquiries, please contact: CDBG.Biz@dca.ga.gov

Build America, Buy America (BABA) CDBG Requirements

For more information on HUD's project specific waiver process, please refer to [Notice CPD-23-12: CPD Implementation Guidance for BABA's Domestic Content Procurement Preference as Part of the Infrastructure Investment and Jobs Act.](#)

Unofficial

A3. SECTION 3 SOLICITATION PACKAGE

Unofficial

Georgia Department of Community Affairs Mandatory Section 3 Solicitation Package

This mandatory solicitation package has been developed in accordance with DCA's Section 3 Policy for Covered HUD Funded Activities. DCA encourages all recipients, sub-recipients, contractors, and sub-contractors to review this policy prior to completion of the solicitation package. For those awards that meet the applicable Section 3 thresholds, this package must be returned in accordance with the applicable instructions to the contracting entity prior to award **or at the time of submission of a bid/proposal in order to claim a Section 3 preference**. The Section 3 Clause, required forms, and instructions are included in this package. All Recipients and Sub-recipients of Section 3 covered Assistance (including but not limited to contractors, sub-contractors, developers, grantees, CHDOs, non-profits, and local government entities) are subject to compliance with regulations in 2 Part 75.

Additional provisions for Housing and Community Development Financial Assistance.

§75.19 Requirements.

(a) Employment and training.

- (1) To the greatest extent feasible and consistent with existing federal state and local laws and regulations recipients covered by this subpart shall ensure that employment and training opportunities arising in connection with Section 3 projects are provided to Section 3 workers within the metropolitan area (or nonmetropolitan county) in which the project is located.
- (2) Where feasible priority for opportunities and training described in paragraph (a)(1) of this section should be given to:
 - (i) Section 3 workers residing within the service area or the neighborhood of the project and
 - (ii) Participants in YouthBuild programs.

(b) Contracting

- (1) To the greatest extent feasible and consistent with existing, Federal, state, and local laws and regulations recipients covered by this subpart shall ensure contracts for work awarded in connection with Section 3 projects are provided to business concerns that provide economic opportunities to Section 3 workers residing within the metropolitan area (or nonmetropolitan county) in which the project is located.
- (2) Where feasible, priority for contracting opportunities described in paragraph (b)(1) of this section should be given to:
 - (i) Section 3 business concerns that provide economic opportunities to Section 3 workers residing within the service area or the neighborhood of the project, and
 - (ii) YouthBuild programs.

Any bid/proposal claiming a preference must include the completed and signed Section 3 Self-Certification and Action Plan and the Section 3 Business Concern Self Certification and be submitted by the bid/proposal deadline.

The following Section 3 forms must be completed and returned prior to contract execution:

- Section 3 Self Certification and Action Plan
- Previous Section 3 Compliance Certification
- Assurance of Compliance Certification

Additionally, if the contractor is claiming certification as a 51% owned by low or very low-income residents or is certifying as a 75% workforce the Resident Self-Certification and Skills Data Form must be returned for all employees who meet the low- or very low-income requirement as well as the appropriate Section 3 Business Certification.

Section 3 Solicitation Overview and Instructions for Contractors

The DCA Section 3 Policy requires that, when the **Section 3 regulation is triggered**, every effort within the contractor's disposal must be made, to the greatest extent feasible, to offer all available employment and contracting opportunities to Section 3 residents and Section 3 businesses based on the compliance methods below.

All Contracts and All Contractors must meet Section 3 compliance by:

- A. Giving notice of any and all opportunities for employment and contracting to residents of the local Public Housing Authority (PHA), and other low and very low income area residents and businesses, by posting the opportunity in community sources generally available to low income residents and the general public. Exercising a **minimum of three (3)** of the following listed sources must be completed prior to offering employment to anyone not covered by Section 3 requirements:
1. The local community newspaper
 2. The most widely distributed newspaper
 3. Company or agency website
 4. The management office of the local housing authority/homeless service agency/local low income housing community
 5. Local Workforce Board (i.e., Department of Labor)
 6. Local office of the Georgia Division of Family and Children Services
 7. Dodge Room <http://www.construction.com/dodge/dodge.asp>
 8. Other locations as approved by DCA
- B. The recipient, sub-recipient or contractor must check the HUD Section 3 Business Registry to determine if there are any Section 3 businesses in the County where the work will be performed. If there are Section 3 businesses in the County that may be able to perform the work, the recipient, sub-recipient or contractor must provide a copy of the contracting opportunity(ies) (e.g., bid notices) to the Section 3 businesses. See the HUD Section 3 Business Registry at: <https://hudapps.hud.gov/OpportunityPortal/>.
- C. Clearly stating in notices that the position is a "Section 3 covered position under the HUD Act of 1968 and that Section 3 Residents and Business Concerns are encouraged to apply."
- D. Placing the Section 3 Clause provided in Appendix A in ALL solicitations.
- E. When possible, other activities may be done to demonstrate effort to comply with the Safe Harbor Limits. These other efforts are listed in the appendix to part 75 of the Code of Federal Regulations—24 CFR Part 75 and include:

Engaged in outreach efforts to generate job applicants who are Targeted Section 3 workers.

- 1) Provided training or apprenticeship opportunities.
- 2) Provided technical assistance to help Section 3 workers compete for jobs (e.g.,

- resume assistance, coaching).
- 3) Provided or connected Section 3 workers with assistance in seeking employment including: drafting resumes, preparing for interviews, and finding job opportunities connecting residents to job placement services.
 - 4) Held one or more job fairs.
 - 5) Provided or referred Section 3 workers to services supporting work readiness and retention (e.g., work readiness activities, interview clothing, test fees, transportation, childcare).
 - 6) Provided assistance to apply for/or attend community college, a four-year educational institution, or vocational/technical training.
 - 7) Assisted Section 3 workers to obtain financial literacy training and/or coaching.
 - 8) Engaged in outreach efforts to identify and secure bids from Section 3 business concerns.
 - 9) Provided technical assistance to help Section 3 business concerns understand and bid on contracts.
 - 10) Divided contracts into smaller jobs to facilitate participation by Section 3 business concerns.
 - 11) Provided bonding assistance, guaranties, or other efforts to support viable bids from Section 3 business concerns.
 - 12) Promoted use of business registries designed to create opportunities for disadvantaged and small businesses.
 - 13) Outreach, engagement, or referrals with the state one-stop system as defined in Section 121(e)(2) of the Workforce Innovation and Opportunity Act
- F. Linking residents or businesses to local resources that may be available to help prepare them for applying for and achieving the opportunity.
- G. Working with DCA, the recipient, sub-recipient or contractor as applicable in developing a communication and follow up process to track and report all Section 3 applications and hiring activities to ensure the reporting of compliance efforts, and that contracting and sub- contracting are accurate. Provide preference in hiring and contracting to Section 3 applicants and contractors when employment or contracting opportunities are offered and all requirements are met and remain equal. Contractors must:
1. Provide this package to all sub-contractors when soliciting bids for all contracts or sub- contracts;
 2. Meet all the same processes in A-E; and
 3. Provide Preference to all sub-contractors meeting the definitions as stated in Section VI of DCA's Section 3 Policy for Covered HUD Funded Activities.
- H. In order for Preference as a Section 3 Contractor to be factored into the award decision, all elements of the solicitation criteria must be equal between contracts. This means price and all other factors must be equal. Then the contractors that elect Preference on the Certification and Action Plan form that meet that Preference criterion will be provided Preference in the award of the contract as provided in Part VI., Preferences and Eligibility of DCA's Section 3 Policy for Covered HUD Funded Activities.

Example:

Bill's electrical and Sue's Electrical bid a job where the housing authority has a budget of \$500,000. Bill bids \$480,000 and elects a Preference as a Section business concern because he qualifies as a Section 3 Business concern. Sue bids \$450,000 but does not elect any Preference. Both companies met all the other requirements. Sue will be awarded the contract because Bill's bid was higher.

Important items to remember about receiving Preferences in contract award:

All contractors and/or subcontractors that elect a Preference and are awarded a contract must be in compliance prior to the issuance of a Notice to Proceed by DCA, the recipient, sub-recipient, or the contractor based on the policies established for the applicable DCA funding program. The contractor and/or subcontractor must maintain the elected Preference standard during the entire contract or risk having the contract terminated for failure to comply. **See Appendix B for further details.**

When a contractor and/or subcontractor that elected a Preference is unable to identify a Section 3 resident or a Section 3 business for employment or contracting opportunities, the contractor then **must** offer employment related training to the Section 3 residents in the county. The training must be provided according to Part VII – Other Economic Opportunities in DCA's Section 3 Policy.

Unofficial

Appendix A **Section 3 Clause**

Training and Employment Opportunities for Residents in the Project Area (Section 3, HUD Act of 1968; 24 CFR 75)

(a) The work to be performed under this contract is subject to the requirements of section 3 of the Housing and Urban Development Act of 1968, as amended, 12 U.S.C. 1701u (section 3). The purpose of section 3 is to ensure that employment and other economic opportunities generated by HUD assistance or HUD-assisted projects covered by section 3, shall, to the greatest extent feasible, be directed to low- and very low-income persons, particularly persons who are recipients of HUD assistance for housing.

(b) The parties to this contract agree to comply with HUD's regulations in 24 CFR Part 75, which implement section 3. As evidenced by their execution of this contract, the parties to this contract certify that they are under no contractual or other impediment that would prevent them from complying with the Part 75 regulations.

(c) The contractor agrees to send to each labor organization or representative of workers with which the contractor has a collective bargaining agreement or other understanding, if any, a notice advising the labor organization or workers' representative of the contractor's commitments under this section 3 clause and will post copies of the notice in conspicuous places at the work site where both employees and applicants for training and employment positions can see the notice. The notice shall describe the section 3 preference, shall set forth minimum number and job titles subject to hire, availability of Section 3 apprenticeship and training positions, the qualifications for each; and the name and location of the person(s) taking applications for each of the positions; and the anticipated date the work shall begin.

(d) The contractor agrees to include this section 3 clause in every subcontract subject to compliance with regulations in 24 CFR Part 75, and agrees to take appropriate action, as provided in an applicable provision of the subcontract or in this section 3 clause, upon a finding that the subcontractor is in violation of the regulations in 24 CFR Part 75. The contractor will not subcontract with any subcontractor where the contractor has notice or knowledge that the subcontractor has been found in violation of the regulations in 24 CFR Part 75.

(e) The contractor will certify that any vacant employment positions, including training positions, that are filled (1) after the contractor is selected but before the contract is executed, and (2) with persons other than those to whom the regulations of 24 CFR Part 75 require employment opportunities to be directed, were not filled to circumvent the contractor's obligations under 24 CFR Part 75.

(f) Noncompliance with HUD's regulations in 24 CFR Part 75 may result in sanctions, termination of this contract for default, and debarment or suspension from future HUD assisted contracts.

Appendix B

Section 3 Contract Non-Compliance Cure /Termination Processes

This language is a component of contract compliance with the work to which you are responding in this solicitation. The full requirements are provided in the Section 3 Clause found elsewhere in this package and in DCA's Section 3 Policy for Covered HUD Funded Activities.

Any recipient, sub-recipient or contractor claiming Preference **must be in compliance prior to issuance of a notice to proceed by DCA, recipient, sub-recipient, or contractor based on the policies established for the applicable DCA funding program. This preference can be met by any of the three qualifications (meets criteria within the past 6 months):**

1. 51% or more owned and controlled by low or very-low income persons
2. 75% or more of the labor hours are performed by Section 3 workers or YouthBuild Participants
3. 51% or more owned by current residents of Public Housing

The recipient, sub-recipient or contractor must maintain compliance throughout the life of the contract. The contractor understands and agrees that a compliance management firm may be used to conduct routine and certified payroll reviews to ensure compliance. The Contractor agrees to provide the payroll data in an Excel or Word format each time the payroll is processed throughout the contract.

Failure to meet the Section 3 requirements will result in penalties up to and including contract termination. Any contractor triggering the regulation by doing any hiring or contracting once they are awarded the contract through execution must comply with the Section 3 requirements by executing the efforts on their Certification and Action Plan in accordance with DCA's Section 3 Policy.

DCA, the recipient, sub-recipient or contractor shall execute these remedies to achieve compliance in this order:

NON-COMPLIANCE CURE PROCESS

- A. Based on the first observation or report of non-compliance with Section 3, the recipient, sub-recipient or contractor will be sent an e-mail by the compliance manager notifying them of their non-compliance issue. The recipient, sub-recipient or contractor will have until the next payroll or 10 business days, whichever is less, to bring the contract into compliance and/or justify in writing why they cannot meet compliance requirements.

- B. DCA, the recipient, sub-recipient or contractor must render a response to the violating party within 10 business days of receipt of the violating party's letter of reason for non-compliance. If DCA, the recipient, sub-recipient, or the contractor deems the reason to be unacceptable, at its option, DCA, the recipient, sub-recipient, or the contractor can extend the response period one time for up to 5 business days to allow the violating party to identify and secure other compliance options.

NON-COMPLIANCE TERMINATION PROCESS

If the violating party fails to take any corrective action to bring the contract into compliance within the allotted time, or DCA, the recipient, sub-recipient, or the contractor rejects any of the corrective plans and justifications for non-compliance, DCA, the recipient, sub-recipient, or the contractor will either terminate the contract immediately or impose liquidated damages equal to \$100 a day for every day out of compliance. At DCA's determination, any liquidated damages received must be paid to the recipient, sub-recipient or DCA, at DCA's determination, and be used to promote economic opportunities for Section 3 Residents and Business Concerns.

DCA, the recipient, sub-recipient, or the contractor will hold **all funds due to the violating party until such time that a financial workout is completed.**

Additionally, the violating party may be banned by DCA, the recipient, sub-recipient, and the contractor on future HUD funded projects.

Appendix C Section 3 Forms

Georgia Department of Community Affairs

Required Submittal - Section 3 Self-Certification and Action Plan

All firms and individuals intending to do business with DCA, its recipients, sub-recipients and contractors MUST complete and submit this Action Plan and submit it with the bid, offer, or proposal in order to claim a preference on any contract or prior to award of a contract when **projects** involve more than \$200,000 in CDBG funds.

Business Name:		
D.B.A. (if different from above):		
Address:	City:	State/Zip:
Business Phone: ()	Fax: ()	
E-Mail:	Business Website:	
Federal Employer Identification Number:	Owner Social Security Number (if no EIN):	
Contact Person & Title:	Contact Phone:	
Trade Description: <input type="checkbox"/> Carpentry <input type="checkbox"/> Heating (HVAC) <input type="checkbox"/> Electrical <input type="checkbox"/> Painting <input type="checkbox"/> Masonry Restoration <input type="checkbox"/> Asbestos <input type="checkbox"/> Plumbing <input type="checkbox"/> Roofing <input type="checkbox"/> Lead (Abatement) <input type="checkbox"/> General Contractor <input type="checkbox"/> Concrete <input type="checkbox"/> Ironwork <input type="checkbox"/> Carpet/Flooring <input type="checkbox"/> Rubbish Removal/Hauling <input type="checkbox"/> Appraisal Services <input type="checkbox"/> Landscaping <input type="checkbox"/> Demolition <input type="checkbox"/> Other:		
Date Business was established (MM/DD/YYYY): _____		
Type of Business (Check One): Corporation Partnership Sole Proprietorship <input type="checkbox"/> Limited Liability Corporation (LLC) <input type="checkbox"/> Limited Liability Partnership (LLP) <input type="checkbox"/> Joint Venture <input type="checkbox"/> Other (Describe):		
Number of employees: Full-time: _____ Part-time: _____ Contract: _____ Total: _____		
Section 3 workers: Full-time: _____ Part-time: _____ Contract: _____ Total: _____		

I am Certifying as a Section 3 Business Concern and requesting Preference accordingly (Select only One Option):

Option 1

- A business claiming status as 51% or more owned and controlled by low or very-low income persons

Option 2

- Over 75% of the labor hours performed for the business over the prior six-month period are performed by Section 3 workers

Option 3

- 51% or more owned and controlled by current residents of public housing or Section 8-assisted housing

Business Concern Affirmation

I, affirm that the above statements of this form in its entirety are true complete and correct to the best of my knowledge and belief. I understand that businesses who misrepresent themselves as Section 3 business concerns and report false information to insert name of recipient/grantee may have their contracts terminated as default and be barred from ongoing and future considerations for contracting opportunities. Thereby certify under penalty of law that the following information is correct to the best of my knowledge.

Signature:

Date:

Print name:

Certification expires within six (6) months of the date of signature

Information regarding Section 3 Business Concerns can be found at 2 Part 75.5

FOR ADMINISTRATIVE USE ONLY

- Yes the business a Section 3 business concern based upon their certification

EMPLOYERS MUST RETAIN THIS FORM IN THEIR SECTION 3 COMPLIANCE FILE FOR FIVE YEARS.

I am NOT Requesting Preference under Section 3:

I am **NOT** certifying as a qualified Section 3 Business Concern and I am not requesting a preference. However, if I do trigger the regulation by doing any sub-contracting or hiring, I will comply by meeting all requirements of DCA's Section 3 policy and I am committing to do the outreach as specified below.

Check all methods you will employ to secure Section 3 Residents/Businesses

Posting the position/contract opportunity in community sources that are generally available to low income residents and Section 3 Businesses and the general public is a standard requirement. **Check at least three**

(3) methods you will employ:

- The local community newspaper
- The most widely distributed newspaper
- Company or agency website
- The management office of the local housing authority, or homeless service agency, or local low income housing community
- Local Workforce Board (i.e., Department of Labor)
- Local office of the Georgia Division of Family and Children Services
- Local office of the Georgia Department of Public Health
- Dodge Room <http://www.construction.com/dodge/dodge.asp>
- Other locations identified below and subject to DCA approval:

_____ Initial here to confirm selection of this option

Signature: _____

Printed/Typed Name: _____

Title: _____

Date: _____

Notarial Affidavit

Sworn to and subscribed before me this _____ day of _____, 20_____.

Signature of Notary Public

Printed Name of Notary Public

Commission Expiration Date: _____

(Notarial Seal)

Georgia Department of Community Affairs
Required Submittal - Previous Section 3 Compliance Certification

Name of Business: _____

Address of Business: _____

Type of Business (Check One): Corporation Partnership
 Sole Proprietorship Other

Business Activity: _____

All firms and individuals intending to do business with DCA, its recipients, sub-recipients, or contractors **MUST** complete and submit this certification of prior compliance prior to award of any contract for a **project** involving \$200,000 or more in CDBG assistance. Please check the appropriate line box below and sign and date the form.

1. I am certifying that I have complied with the HUD Section 3 Regulations, when triggered by new hiring or contracting opportunities, in my past contracts **when required** by the recipient, sub-recipient or contractor by either:
- i. Certifying as a Section 3 Business Concern because at least 51 percent of the business is owned and controlled by low- or very low-income persons;
 - ii. Certifying as a Section 3 Business Concern because over 75 percent of the labor hours performed for the business over the prior six-month period are performed by Section 3 workers;
 - iii. Certifying as a Section 3 Business Concern because at least 51 percent of the business is owned and controlled by current public housing residents or residents who currently live in Section 8-assisted housing;
 - iv. Hiring or contracting to the "greatest extent feasible" with Section 3 Residents or Section 3 Businesses.

Check this box

2. I have never done any HUD funded contracting.

Check this box

3. I completed HUD Section 3 covered contracts in the past three years but the regulation was not triggered because either there were no new hires on the contract(s) and/or I did not do any new contracting or subcontracting.

Check this box

Signature: _____
Print Name: _____ Title: _____

**Required Submittal - Assurance of
Compliance Certification Section 3
Action Plan
Housing and Urban
Development Act of 1968
(12 U.S.C. 1701 U)**

Contract/Solicitation Name or Number: _____

DCA Funding Program: _____

Entity Receiving DCA Funding Award: _____

Purpose: To ensure that regulations promulgated under 24 CFR Part 75 Employment Opportunities for Businesses and Lower Income Persons in Connection with Assisted Projects and the Section 3 Policy of DCA, its recipients, sub-recipients and contractors to the greatest extent feasible is adhered to, and to serve as the "assurance of compliance" certification and action plan as required in the bid documents, supplemental general conditions, and required forms for the contract for any HUD work funded by DCA.

Description of the project's work detail: The project work will be as listed in the final scope of work in the contract with DCA, its recipients, sub-recipients and contractors including any change orders. List all known subcontractors below:

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Subcontractor(s): _____

Use an additional sheet if required.

Note: If subcontractors are unknown at this time, print UNKNOWN on the line above. Also, the contractor must notify DCA or recipient or sub-recipient if subcontractors are added or changed during the contract. Any changes to this certification require a resubmission of this form to DCA or recipient or sub-recipient.

Preliminary Statement for Work Force Needs:

DCA intends to meet Section 3 compliance at the highest level, and it is our intent to identify any short-term and long-term employment or contracting opportunities for qualified Section 3 workers and Business Concerns during the course of the contract funded by DCA via its recipients or sub-recipients and contractors. Please list the status of all planned employment positions and opportunities for this contract. **Preference for all opportunities must be given to low and very low-income residents if they qualify. If awarded a contract, regardless of whether your firm has elected a preference, you are required to provide a list of your aggregate workforce on this project. Any changes to that workforce during the project will constitute NEW hires. You must notify DCA, its recipient, sub-recipient or contractor (respectively) overseeing your contract of any new hire opportunities that arise during the life of your contract. The anticipated workforce list may be provided on a separate sheet or in a different format.**

<u>List All Employees</u>	<u>Date Hired</u>	<u>Section 3 Worker (Yes/No)</u>	<u>Job Title/Trade</u>	<u>Salary Range</u>
Name: Address: City, ZIP:				
Name: Address: City, Zip Code:				
Name: Address: City, Zip Code:				
Name: Address: City, Zip Code:				

Use additional pages as needed.

“To the Greatest Extent Feasible”:

The Contractor has identified # _____ of **OPEN** positions with respect to this contract. The positions are filled by the _____ (Position title) of the Contractor.

Should the scope of work or duties of the contractor change to a degree requiring a modification of the work force needs, the contractor shall put forth a reasonable effort to fill vacant positions with eligible Section 3 workers.

Documentation of “To the Greatest Extent Feasible”:

The contractor will work with DCA, its recipients, sub-recipients, and contractors staff to notify residents of any opportunities afforded under the contract. The contractor will partner with DCA, its recipients, sub-recipients, and contractors by giving preference of any employment opportunities to the Section 3 persons or businesses.

The contractor shall recruit or attempt to recruit from the Section 3 service area the necessary number of low-income and very low-income residents and Section 3 businesses, as applicable. The contractor must also document their recruiting efforts and any impediments to compliance with DCA’s Section 3 policy and the requirements of this solicitation package. This documentation must be submitted to the recipient or sub-recipient.

1. DCA, its sub-recipients and contractors shall: Maintain a list of all low-income area residents who have applied, either on their own or from referral from any source and employ such person if otherwise eligible and if a trainee vacancy exists.
2. Conduct solicitation in accordance with DCA’s Section 3 policy and the requirements outlined in the solicitation package.

The contractor shall review all employment applications and determine if low-income and very low-income residents or Section 3 businesses meet minimum hiring or contracting qualifications. If these applicants meet such minimum qualifications but are not hired due to lack of employment opportunities or for other reasons, they will be placed on a priority list and offered positions/contracts upon the occurrence of the first available appropriate opening.

Utilization of Section 3 Businesses Located Within the service area or neighborhood of the project:

The recipient, sub-recipient or contractor does ___ does not ___ intend to subcontract any of the work identified in the scope of work cited in the bid specifications, scope of work or General Conditions. Should the scope of work or needs of the contractor change, the contractor shall, to the greatest extent feasible, shall ensure contracts for work awarded in connection with Section 3 projects are provided to business concerns that provide economic opportunities to Section 3 workers residing within the metropolitan area (or nonmetropolitan county) in which the project is located.

Record Keeping:

The recipient, sub-recipient, contractor or subcontractor, as applicable, shall maintain on file all records related to employment and job training of low-income and very low-income residents or other such records, advertisements, legal notices, brochures, flyers, publications, assurances of compliance from sub-contractors, etc., in connection with this contract. If a report is needed in the future, the recipient,

sub-recipient, contractor or subcontractor, as applicable, agrees to provide all records upon request. The contractor shall, upon request, provide such records or copies of records to HUD, DCA, their recipients, sub-recipients, contractors, staff, or agents. Records shall be maintained for at least three (3) years after the close of the contract.

Reports:

The recipient, sub-recipient or contractor shall provide reports as required in connection with the contractor specifications. All certified and regular payrolls shall clearly detail which employees qualify under Section 3. The U.S. Department of Housing and Urban Development (HUD) requires that recipients of federal funds capture record and report the total number of labor hours the total amount of Section 3 worker hours and the total amount of Section 3 Target worker hours.

Certification:

The recipient, sub-recipient or contractor will certify that any vacant employment positions, including training positions that filled:

- 1) After the recipient, sub-recipient or contractor is selected but before the contract is executed, and
- 2) With persons other than those to who the regulations of 24 CFR Part 75 require employment opportunities to be directed, were not filled to circumvent the subcontractor's obligations under 24 CFR Part 75.

Grievance and Compliance:

The recipient, sub-recipient, contractor or subcontractor hereby acknowledges that they understand that any low-income and very low-income resident of the project area, for him/her or as representatives of persons similarly situated, seeking employment or job training opportunities in the project area, or any eligible business concerns seeking contract opportunities may file a grievance if efforts to the greatest extent feasible were not executed. The grievance must be filed with HUD not later than one hundred eighty (180) calendar days from the date of the action (or omission) upon which the grievance is based.

I attest that the information on the preceding pages is true and correct.

Signature

Date

Print Name

Resident Section 3 Self Certification and Skills Data Form

The purpose of this form is to comply with HUD Section 3 administration and certification regulations. **Certification for Section 3 Workers or other Low-Income Persons Seeking Employment, Training or Contracting**

I, _____, am a legal resident of the United States and meet the income eligibility and federal guidelines for a Section 3 Resident as defined within this Certification.

My home address is: _____
Must be a **Street** address not a P O Box # Apt Number

 City State Zip Home # Cell #

County of Residence _____

Graduated High School or GED (month/year): _____ I Read and Speak English Fluently: Yes or No

Attended College, Trade, or Technical School: Yes or No

Graduated? Yes or No

Year Graduated: _____

Check the Skills, Trades, and/or Professions in which you have been employed or contracted to do for others:

<input type="checkbox"/> Drywall Hanging <input type="checkbox"/> Drywall Finishing <input type="checkbox"/> Interior Painting <input type="checkbox"/> HVAC <input type="checkbox"/> Electrical <input type="checkbox"/> Interior Plumbing <input type="checkbox"/> Exterior Plumbing <input type="checkbox"/> Cabinet hanging <input type="checkbox"/> Heavy Equipment Operator	<input type="checkbox"/> Stucco <input type="checkbox"/> Window/Door Replacement <input type="checkbox"/> Construction Cleaning <input type="checkbox"/> Exterior Framing <input type="checkbox"/> Landscaping <input type="checkbox"/> Fencing <input type="checkbox"/> Concrete/ Asphalt Work	<input type="checkbox"/> Siding <input type="checkbox"/> Door Replacement <input type="checkbox"/> Trim /Carpentry <input type="checkbox"/> Roofing <input type="checkbox"/> Welding <input type="checkbox"/> Metal/Steel Work <input type="checkbox"/> Other
---	---	---

I am certifying as a Section 3 worker: **Person seeking Training** or **Person seeking employment**

(Check all that apply):

A low or very-low income resident Employed by a Section 3 Business Concern YouthBuild Participant

I live in the service area or neighborhood -one-mile radius of project site or if fewer than 5,000 people a radius of project containing 5,000 people.

My total annual income is \$ _____

I certify that all of the information given on this Certification is true and correct. If found to be inaccurate, I understand that I may be disqualified as an applicant and/or a certified Section 3 individual which may be grounds for termination of training, employment, or contracts that resulted from this certification. I attest under penalty of perjury that my income annually is at or below the income amount at the time of this document is being signed and notarized. I understand that proof of this statement may be requested in the future.

 Signature Date

Printed Name: _____

Purpose:

The purpose of Section 3 of the Housing and Urban Development of 1968 (12 U.S.C. 1701u) (Section 3) is to ensure that employment and other economic and business opportunities generated by HUD Financial Assistance shall be directed to the Authority Residents and other low- and very low-income persons, particularly those who are recipients of government housing assistance and to business concerns which provide economic opportunities to low- and very low-income persons and YouthBuild participants.

A Section 3 worker as defined by §75.5 is any worker who currently fits or when hired within the past five years fit at least one of the following criteria:

- (1) The worker's income for the previous or annualized calendar year is below the income limit established by HUD.
- (2) The worker is employed by a Section 3 business concern.
- (3) The worker is a YouthBuild participant.

A person seeking the training and employment preference provided by section 3 bears the responsibility of providing evidence (if requested) that the person is eligible for the preference.

Low- and very low-income limits are defined in Section 3(b)(2) of the Housing Act of 1937 and are determined annually by HUD. These limits are typically established at 80 percent and 50 percent of the area median individual income. HUD income limits may be obtained from: <https://www.huduser.gov/portal/datasets/il.html>.

(§75.21) A Targeted Section 3 worker for housing and community development financial assistance means a Section 3 worker who is:

- (1) A worker employed by a Section 3 business concern or
- (2) A worker who currently fits or when hired fit at least one of the following categories as documented within the past five years:
 - (i) Living within the service area or the neighborhood of the project as defined in 75.5 or
 - (ii) A YouthBuild participant.

Service area or the neighborhood of the project means an area within one mile of the Section 3 project or if fewer than 5,000 people live within one mile of a Section 3 project within a circle centered on the Section 3 project that is sufficient to encompass a population of 5,000 people according to the most recent U.S. Census.

HUD income limits may be obtained from: <https://www.huduser.gov/portal/datasets/il.html>.

Please indicate the Household income \$ _____

Resident Section 3 Self-Certification and Skills Data Form Affidavit

STATE OF _____

County of _____

I, _____, a Notary Public of the City/County of _____,
State of _____, do hereby certify that, _____,
whose name is signed to the writing above bearing date on the ___ Day of _____, 20_

has acknowledged the same before me in my State aforesaid.

Given under my hand and official seal, this the ___ day of _____, 20_.

Signature of Notary Public

Printed Name of Notary Public

Commission Expiration Date: _____

(Notarial Seal)

SECTION 3 BUSINESS CONCERN SELF CERTIFICATION

The Georgia Department of Community Affairs (DCA) is seeking to extend the benefits of and to promote compliance with Section 3 by identifying Section 3 Business Concerns and targeting Section 3 Business Concerns for business opportunities, events and educational programs.

In an effort to comply with Federal Section 3 Regulations which promote contract, employment and training opportunities for State of Georgia residents, DCA has instituted a Section 3 Self Certification process.

Businesses seeking certification must complete and submit the attached Section 3 Business Concern Self Certification forms as follow:

1. If your company is qualified because it is owned (51% or more) by one or more low or very-low- income residents, then complete **Form A, "Section 3 Business Concern – Resident Business Owner(s) Verification"**; **OR**
2. If your company is qualified because over 75 percent of the labor hours performed for the business over the prior three-month period are performed by Section 3 workers, then complete **Form B, "Section 3 Business Concern – 75% + Workforce"**.
OR
3. If at least 51 percent owned and controlled by current public housing residents or residents who currently live in Section 8-assisted housing, then complete **Form C, "Section 3 Business Concern-Housing Residents"**.

Please answer all questions, sign the completed forms, and notarize the affidavit. Completed packets must be returned to the sub-recipient or contractor as follows:

Name of sub-recipient/contractor: _____

Attn: _____

Mailing Address: _____

If you have any questions or require assistance, please contact:

Name: _____

Phone Number: _____

Email Address: _____

Form A
SECTION 3 BUSINESS CONCERN
Resident Business Owner(s) Verification

A business can be certified as a Section 3 Business Concern if the business is owned (51% or more) by low or very-low-income residents.

Name of Owner: _____

Home Street Address: _____

Home City, County, & Zip Code: _____

Name of Business: _____

Percentage of Ownership: _____%

Low- and very low-income limits are defined in Section 3(b)(2) of the Housing Act of 1937 and are determined annually by HUD. These limits are typically established at 80 percent and 50 percent of the area median individual income. HUD income limits may be obtained from: <https://www.huduser.gov/portal/datasets/il.html>.

Individual Income Limits

FY 20 Income Limit Area	Income Limits Category	FY 202 Income Limits
	Extremely Low Income Limits	
	Very Low Income Limits (50%)	
	Low Income Limits (80%)	

If the business is owned by more than one low to very-low-income residents, list each owner below and each should submit a separate Resident Business Owner Verification Form (Form A).

Name	Position	% Percentage of Ownership

I certify I am a resident of Georgia and my total income last year was not more than the amount shown above. I further certify the information provided is true and accurate and agree to provide upon request, documents verifying the information submitted to qualify as a Section 3 Business Concern.

Print: _____ Signature: _____ Date: _____

Form B
SECTION 3 BUSINESS CONCERN
75% + Workforce

A business can be certified as a Section 3 Business Concern if over 75 percent of the labor hours performed for the business over the prior three-month period are performed by Section 3 workers. For your firm to be eligible UNDER THIS CRITERIA, you must provide the following information for **all permanent, full-time employees**.

You may attach additional copies of this chart, if necessary.

List All Employees	Date Hired	Section 3 Worker	Job Title/Trade	Salary Range
Name: Address: City/Zip:				
Name: Address: City/Zip:				
Name: Address: City/Zip:				
Name: Address: City/Zip:				
Name: Address: City/Zip:				
Name: Address: City/Zip:				
Total Number of Employees:	Full-Time: _____	Part-Time: _____	Contract: _____	
Number of Section 3 workers:				
Section 3 % of Total Workforce:				

I certify that the information provided is true and accurate and agree to provide upon request, any/all documents verifying the information submitted to qualify as a Section 3 Business Concern.

Print:
Date:

Signature:

Form C
SECTION 3 BUSINESS CONCERN
Public Housing Residents

To qualify the business must be at least 51 percent owned and controlled by current public housing residents or residents who currently live in Section 8-assisted housing

Business Information

Name of Business: _____

Address of Business: _____

Name of Business Owner: _____

Phone Number of Business Owner: _____

Email Address of Business Owner: _____

Preferred Contact Information: _____

Name of Preferred Contact: _____

Phone Number of Preferred Contact: _____

Type of Business (select from the following options):

Corporation Partnership Sole Proprietorship Joint Venture

Percent owned and controlled by current public housing residents or residents who currently live in Section 8-assisted housing: _____%

I certify that the information provided is true and accurate and agree to provide upon request, any/all documents verifying the information submitted to qualify as a Section 3 business concern.

Print Name: _____

Title: _____

Company Name: _____

Signature: _____

Date: _____

B. SUPPLEMENTAL CONDITIONS

Unofficial

SUPPLEMENTAL CONDITIONS

01. GENERAL CONDITIONS:

The "Standard General Conditions of the Construction Contract", Engineers Joint Contract Documents Committee, 2007 Edition, Articles 1 through 17 inclusive, included herein preceding these supplements, is a part of this Contract.

ARTICLE 5 - BONDS & INSURANCE

5.04 B 1& 2 Contractor's protective liability insurance, with minimum limits as follows:

General Liability – \$1,000,000 per occurrence;

Damage to rented premises – \$100,000 per occurrence;

Personal injury including death – \$1,000,000 for each occurrence;

General aggregate – \$2,000,000 per project;

Property damage - \$100,000 for each and \$200,000. for the aggregate for operations.

Contractor's automobile liability insurance (including contractual liability insurance as applicable to the Contractor's obligations under paragraph 6.20) with minimum limits as follows:

Automobile liability – \$1,000,000 per occurrence;

Workers compensation – Statutory coverage and \$1,000,000 Employers liability limit.

- (a) Any exclusion of so-called underground damage to pipes, collapse of structures or damage resulting from explosion or blasting, shall be deleted.
- (b) The policy shall provide completed operations coverage, and such coverage shall be maintained by the Contractor for a period of one year from the date of payment of the final amounts owed the Contractor by the Owner, whichever occurs first.

ARTICLE 14 - PAYMENTS TO CONTRACTOR AND COMPLETION

14.02 Progress Payments

A. Applications for Payments

1. Add a sentence after the second sentence stating, "Each payment request shall be accompanied with record drawings showing as-built conditions of all work requested during the pay period."

ARTICLE 16 - DISPUTE RESOLUTION

- 16.01 Any dispute arising under this agreement shall first be resolved by utilizing non-binding mediation, however, should the dispute not be resolved by this method it shall be heard in the Superior Court of the County in which the owner resides, and the parties consent to jurisdiction and venue in that Court. The parties waive any defense they may have to lack of jurisdiction or improper venue and agree to have all disputes resolved in the Superior Court of the County in which the owner resides.

C. GENERAL CONDITIONS

Unofficial

This document has important legal consequences; consultation with an attorney is encouraged with respect to its use or modification. This document should be adapted to the particular circumstances of the contemplated Project and the controlling Laws and Regulations.

STANDARD GENERAL CONDITIONS OF THE CONSTRUCTION CONTRACT

Prepared by

ENGINEERS JOINT CONTRACT DOCUMENTS COMMITTEE

and

Issued and Published Jointly by

ACEC

AMERICAN COUNCIL OF ENGINEERING COMPANIES

ASCE American Society
of Civil Engineers



**National Society of
Professional Engineers**
Professional Engineers in Private Practice

AMERICAN COUNCIL OF ENGINEERING COMPANIES

ASSOCIATED GENERAL CONTRACTORS OF AMERICA

AMERICAN SOCIETY OF CIVIL ENGINEERS

PROFESSIONAL ENGINEERS IN PRIVATE PRACTICE

A Practice Division of the

NATIONAL SOCIETY OF PROFESSIONAL ENGINEERS

Endorsed by



CONSTRUCTION SPECIFICATIONS INSTITUTE

These General Conditions have been prepared for use with the Suggested Forms of Agreement Between Owner and Contractor (EJCDC C-520 or C-525, 2007 Editions). Their provisions are interrelated and a change in one may necessitate a change in the other. Comments concerning their usage are contained in the Narrative Guide to the EJCDC Construction Documents (EJCDC C-001, 2007 Edition). For guidance in the preparation of Supplementary Conditions, see Guide to the Preparation of Supplementary Conditions (EJCDC C-800, 2007 Edition).

Copyright © 2007 National Society of Professional Engineers
1420 King Street, Alexandria, VA 22314-2794
(703) 684-2882
www.nspe.org

American Council of Engineering Companies
1015 15th Street N.W., Washington, DC 20005
(202) 347-7474
www.acec.org

American Society of Civil Engineers
1801 Alexander Bell Drive, Reston, VA 20191-4400
(800) 548-2723
www.asce.org

Associated General Contractors of America
2300 Wilson Boulevard, Suite 400, Arlington, VA 22201-3308
(703) 548-3118
www.agc.org

The copyright for this EJCDC document is owned jointly by the four EJCDC sponsoring organizations and held in trust for their benefit by NSPE.

STANDARD GENERAL CONDITIONS OF THE CONSTRUCTION CONTRACT

TABLE OF CONTENTS

	Page
Article 1 – Definitions and Terminology	1
1.01 Defined Terms.....	1
1.02 Terminology.....	5
Article 2 – Preliminary Matters	6
2.01 Delivery of Bonds and Evidence of Insurance	6
2.02 Copies of Documents.....	6
2.03 Commencement of Contract Times; Notice to Proceed.....	6
2.04 Starting the Work.....	7
2.05 Before Starting Construction	7
2.06 Preconstruction Conference; Designation of Authorized Representatives.....	7
2.07 Initial Acceptance of Schedules.....	7
Article 3 – Contract Documents: Intent, Amending, Reuse	8
3.01 Intent.....	8
3.02 Reference Standards.....	8
3.03 Reporting and Resolving Discrepancies.....	9
3.04 Amending and Supplementing Contract Documents.....	9
3.05 Reuse of Documents	10
3.06 Electronic Data.....	10
Article 4 – Availability of Lands; Subsurface and Physical Conditions; Hazardous Environmental Conditions; Reference Points.....	11
4.01 Availability of Lands.....	11
4.02 Subsurface and Physical Conditions.....	11
4.03 Differing Subsurface or Physical Conditions	12
4.04 Underground Facilities.....	13
4.05 Reference Points.....	14
4.06 Hazardous Environmental Condition at Site	14
Article 5 – Bonds and Insurance.....	16
5.01 Performance, Payment, and Other Bonds.....	16
5.02 Licensed Sureties and Insurers.....	16
5.03 Certificates of Insurance	17
5.04 Contractor’s Insurance	17
5.05 Owner’s Liability Insurance.....	19
5.06 Property Insurance.....	19
5.07 Waiver of Rights	20
5.08 Receipt and Application of Insurance Proceeds.....	21

5.09	Acceptance of Bonds and Insurance; Option to Replace	21
5.10	Partial Utilization, Acknowledgment of Property Insurer.....	22
Article 6 – Contractor’s Responsibilities		22
6.01	Supervision and Superintendence.....	22
6.02	Labor; Working Hours	22
6.03	Services, Materials, and Equipment	22
6.04	Progress Schedule	23
6.05	Substitutes and “Or-Equals”	23
6.06	Concerning Subcontractors, Suppliers, and Others.....	25
6.07	Patent Fees and Royalties	27
6.08	Permits.....	27
6.09	Laws and Regulations	28
6.10	Taxes	28
6.11	Use of Site and Other Areas.....	28
6.12	Record Documents.....	29
6.13	Safety and Protection	29
6.14	Safety Representative.....	30
6.15	Hazard Communication Programs.....	30
6.16	Emergencies	30
6.17	Shop Drawings and Samples	31
6.18	Continuing the Work.....	32
6.19	Contractor’s General Warranty and Guarantee.....	33
6.20	Indemnification	33
6.21	Delegation of Professional Design Services.....	34
Article 7 – Other Work at the Site.....		35
7.01	Related Work at Site	35
7.02	Coordination.....	35
7.03	Legal Relationships.....	36
Article 8 – Owner’s Responsibilities.....		36
8.01	Communications to Contractor.....	36
8.02	Replacement of Engineer	36
8.03	Furnish Data	36
8.04	Pay When Due.....	36
8.05	Lands and Easements; Reports and Tests.....	36
8.06	Insurance.....	36
8.07	Change Orders.....	37
8.08	Inspections, Tests, and Approvals	37
8.09	Limitations on Owner’s Responsibilities	37
8.10	Undisclosed Hazardous Environmental Condition	37
8.11	Evidence of Financial Arrangements.....	37
8.12	Compliance with Safety Program.....	37
Article 9 – Engineer’s Status During Construction.....		37
9.01	Owner’s Representative	37

9.02	Visits to Site	37
9.03	Project Representative.....	38
9.04	Authorized Variations in Work	38
9.05	Rejecting Defective Work.....	38
9.06	Shop Drawings, Change Orders and Payments.....	39
9.07	Determinations for Unit Price Work	39
9.08	Decisions on Requirements of Contract Documents and Acceptability of Work.....	39
9.09	Limitations on Engineer’s Authority and Responsibilities	39
9.10	Compliance with Safety Program	40
Article 10 – Changes in the Work; Claims		40
10.01	Authorized Changes in the Work	40
10.02	Unauthorized Changes in the Work.....	41
10.03	Execution of Change Orders.....	41
10.04	Notification to Surety.....	41
10.05	Claims.....	41
Article 11 – Cost of the Work; Allowances; Unit Price Work.....		42
11.01	Cost of the Work	42
11.02	Allowances	45
11.03	Unit Price Work	45
Article 12 – Change of Contract Price; Change of Contract Times		46
12.01	Change of Contract Price	46
12.02	Change of Contract Times	47
12.03	Delays.....	47
Article 13 – Tests and Inspections; Correction, Removal or Acceptance of Defective Work.....		48
13.01	Notice of Defects.....	48
13.02	Access to Work	48
13.03	Tests and Inspections	49
13.04	Uncovering Work.....	49
13.05	Owner May Stop the Work.....	50
13.06	Correction or Removal of Defective Work	50
13.07	Correction Period	50
13.08	Acceptance of Defective Work.....	51
13.09	Owner May Correct Defective Work	52
Article 14 – Payments to Contractor and Completion		52
14.01	Schedule of Values.....	52
14.02	Progress Payments	52
14.03	Contractor’s Warranty of Title.....	55
14.04	Substantial Completion.....	55
14.05	Partial Utilization	56
14.06	Final Inspection.....	57
14.07	Final Payment.....	57
14.08	Final Completion Delayed	58

14.09 Waiver of Claims	58
Article 15 – Suspension of Work and Termination	59
15.01 Owner May Suspend Work.....	59
15.02 Owner May Terminate for Cause	59
15.03 Owner May Terminate For Convenience	60
15.04 Contractor May Stop Work or Terminate.....	60
Article 16 – Dispute Resolution	61
16.01 Methods and Procedures	61
Article 17 – Miscellaneous	61
17.01 Giving Notice	61
17.02 Computation of Times	62
17.03 Cumulative Remedies	62
17.04 Survival of Obligations	62
17.05 Controlling Law	62
17.06 Headings.....	62

Unofficial

ARTICLE 1 – DEFINITIONS AND TERMINOLOGY

1.01 *Defined Terms*

- A. Wherever used in the Bidding Requirements or Contract Documents and printed with initial capital letters, the terms listed below will have the meanings indicated which are applicable to both the singular and plural thereof. In addition to terms specifically defined, terms with initial capital letters in the Contract Documents include references to identified articles and paragraphs, and the titles of other documents or forms.
1. *Addenda*—Written or graphic instruments issued prior to the opening of Bids which clarify, correct, or change the Bidding Requirements or the proposed Contract Documents.
 2. *Agreement*—The written instrument which is evidence of the agreement between Owner and Contractor covering the Work.
 3. *Application for Payment*—The form acceptable to Engineer which is to be used by Contractor during the course of the Work in requesting progress or final payments and which is to be accompanied by such supporting documentation as is required by the Contract Documents.
 4. *Asbestos*—Any material that contains more than one percent asbestos and is friable or is releasing asbestos fibers into the air above current action levels established by the United States Occupational Safety and Health Administration.
 5. *Bid*—The offer or proposal of a Bidder submitted on the prescribed form setting forth the prices for the Work to be performed.
 6. *Bidder*—The individual or entity who submits a Bid directly to Owner.
 7. *Bidding Documents*—The Bidding Requirements and the proposed Contract Documents (including all Addenda).
 8. *Bidding Requirements*—The advertisement or invitation to bid, Instructions to Bidders, Bid security of acceptable form, if any, and the Bid Form with any supplements.
 9. *Change Order*—A document recommended by Engineer which is signed by Contractor and Owner and authorizes an addition, deletion, or revision in the Work or an adjustment in the Contract Price or the Contract Times, issued on or after the Effective Date of the Agreement.
 10. *Claim*—A demand or assertion by Owner or Contractor seeking an adjustment of Contract Price or Contract Times, or both, or other relief with respect to the terms of the Contract. A demand for money or services by a third party is not a Claim.
 11. *Contract*—The entire and integrated written agreement between the Owner and Contractor concerning the Work. The Contract supersedes prior negotiations, representations, or agreements, whether written or oral.

12. *Contract Documents*—Those items so designated in the Agreement. Only printed or hard copies of the items listed in the Agreement are Contract Documents. Approved Shop Drawings, other Contractor submittals, and the reports and drawings of subsurface and physical conditions are not Contract Documents.
13. *Contract Price*—The moneys payable by Owner to Contractor for completion of the Work in accordance with the Contract Documents as stated in the Agreement (subject to the provisions of Paragraph 11.03 in the case of Unit Price Work).
14. *Contract Times*—The number of days or the dates stated in the Agreement to: (i) achieve Milestones, if any; (ii) achieve Substantial Completion; and (iii) complete the Work so that it is ready for final payment as evidenced by Engineer's written recommendation of final payment.
15. *Contractor*—The individual or entity with whom Owner has entered into the Agreement.
16. *Cost of the Work*—See Paragraph 11.01 for definition.
17. *Drawings*—That part of the Contract Documents prepared or approved by Engineer which graphically shows the scope, extent, and character of the Work to be performed by Contractor. Shop Drawings and other Contractor submittals are not Drawings as so defined.
18. *Effective Date of the Agreement*—The date indicated in the Agreement on which it becomes effective, but if no such date is indicated, it means the date on which the Agreement is signed and delivered by the last of the two parties to sign and deliver.
19. *Engineer*—The individual or entity named as such in the Agreement.
20. *Field Order*—A written order issued by Engineer which requires minor changes in the Work but which does not involve a change in the Contract Price or the Contract Times.
21. *General Requirements*—Sections of Division 1 of the Specifications.
22. *Hazardous Environmental Condition*—The presence at the Site of Asbestos, PCBs, Petroleum, Hazardous Waste, or Radioactive Material in such quantities or circumstances that may present a substantial danger to persons or property exposed thereto.
23. *Hazardous Waste*—The term Hazardous Waste shall have the meaning provided in Section 1004 of the Solid Waste Disposal Act (42 USC Section 6903) as amended from time to time.
24. *Laws and Regulations; Laws or Regulations*—Any and all applicable laws, rules, regulations, ordinances, codes, and orders of any and all governmental bodies, agencies, authorities, and courts having jurisdiction.
25. *Liens*—Charges, security interests, or encumbrances upon Project funds, real property, or personal property.
26. *Milestone*—A principal event specified in the Contract Documents relating to an intermediate completion date or time prior to Substantial Completion of all the Work.

27. *Notice of Award*—The written notice by Owner to the Successful Bidder stating that upon timely compliance by the Successful Bidder with the conditions precedent listed therein, Owner will sign and deliver the Agreement.
28. *Notice to Proceed*—A written notice given by Owner to Contractor fixing the date on which the Contract Times will commence to run and on which Contractor shall start to perform the Work under the Contract Documents.
29. *Owner*—The individual or entity with whom Contractor has entered into the Agreement and for whom the Work is to be performed.
30. *PCBs*—Polychlorinated biphenyls.
31. *Petroleum*—Petroleum, including crude oil or any fraction thereof which is liquid at standard conditions of temperature and pressure (60 degrees Fahrenheit and 14.7 pounds per square inch absolute), such as oil, petroleum, fuel oil, oil sludge, oil refuse, gasoline, kerosene, and oil mixed with other non-Hazardous Waste and crude oils.
32. *Progress Schedule*—A schedule, prepared and maintained by Contractor, describing the sequence and duration of the activities comprising the Contractor's plan to accomplish the Work within the Contract Times.
33. *Project*—The total construction of which the Work to be performed under the Contract Documents may be the whole, or a part.
34. *Project Manual*—The bound documentary information prepared for bidding and constructing the Work. A listing of the contents of the Project Manual, which may be bound in one or more volumes, is contained in the table(s) of contents.
35. *Radioactive Material*—Source, special nuclear, or byproduct material as defined by the Atomic Energy Act of 1954 (42 USC Section 2011 et seq.) as amended from time to time.
36. *Resident Project Representative*—The authorized representative of Engineer who may be assigned to the Site or any part thereof.
37. *Samples*—Physical examples of materials, equipment, or workmanship that are representative of some portion of the Work and which establish the standards by which such portion of the Work will be judged.
38. *Schedule of Submittals*—A schedule, prepared and maintained by Contractor, of required submittals and the time requirements to support scheduled performance of related construction activities.
39. *Schedule of Values*—A schedule, prepared and maintained by Contractor, allocating portions of the Contract Price to various portions of the Work and used as the basis for reviewing Contractor's Applications for Payment.

40. *Shop Drawings*—All drawings, diagrams, illustrations, schedules, and other data or information which are specifically prepared or assembled by or for Contractor and submitted by Contractor to illustrate some portion of the Work.
41. *Site*—Lands or areas indicated in the Contract Documents as being furnished by Owner upon which the Work is to be performed, including rights-of-way and easements for access thereto, and such other lands furnished by Owner which are designated for the use of Contractor.
42. *Specifications*—That part of the Contract Documents consisting of written requirements for materials, equipment, systems, standards and workmanship as applied to the Work, and certain administrative requirements and procedural matters applicable thereto.
43. *Subcontractor*—An individual or entity having a direct contract with Contractor or with any other Subcontractor for the performance of a part of the Work at the Site.
44. *Substantial Completion*—The time at which the Work (or a specified part thereof) has progressed to the point where, in the opinion of Engineer, the Work (or a specified part thereof) is sufficiently complete, in accordance with the Contract Documents, so that the Work (or a specified part thereof) can be utilized for the purposes for which it is intended. The terms “substantially complete” and “substantially completed” as applied to all or part of the Work refer to Substantial Completion thereof.
45. *Successful Bidder*—The Bidder submitting a responsive Bid to whom Owner makes an award.
46. *Supplementary Conditions*—That part of the Contract Documents which amends or supplements these General Conditions.
47. *Supplier*—A manufacturer, fabricator, supplier, distributor, materialman, or vendor having a direct contract with Contractor or with any Subcontractor to furnish materials or equipment to be incorporated in the Work by Contractor or Subcontractor.
48. *Underground Facilities*—All underground pipelines, conduits, ducts, cables, wires, manholes, vaults, tanks, tunnels, or other such facilities or attachments, and any encasements containing such facilities, including those that convey electricity, gases, steam, liquid petroleum products, telephone or other communications, cable television, water, wastewater, storm water, other liquids or chemicals, or traffic or other control systems.
49. *Unit Price Work*—Work to be paid for on the basis of unit prices.
50. *Work*—The entire construction or the various separately identifiable parts thereof required to be provided under the Contract Documents. Work includes and is the result of performing or providing all labor, services, and documentation necessary to produce such construction, and furnishing, installing, and incorporating all materials and equipment into such construction, all as required by the Contract Documents.
51. *Work Change Directive*—A written statement to Contractor issued on or after the Effective Date of the Agreement and signed by Owner and recommended by Engineer ordering an

addition, deletion, or revision in the Work, or responding to differing or unforeseen subsurface or physical conditions under which the Work is to be performed or to emergencies. A Work Change Directive will not change the Contract Price or the Contract Times but is evidence that the parties expect that the change ordered or documented by a Work Change Directive will be incorporated in a subsequently issued Change Order following negotiations by the parties as to its effect, if any, on the Contract Price or Contract Times.

1.02 Terminology

A. The words and terms discussed in Paragraph 1.02.B through F are not defined but, when used in the Bidding Requirements or Contract Documents, have the indicated meaning.

B. *Intent of Certain Terms or Adjectives:*

1. The Contract Documents include the terms “as allowed,” “as approved,” “as ordered,” “as directed” or terms of like effect or import to authorize an exercise of professional judgment by Engineer. In addition, the adjectives “reasonable,” “suitable,” “acceptable,” “proper,” “satisfactory,” or adjectives of like effect or import are used to describe an action or determination of Engineer as to the Work. It is intended that such exercise of professional judgment, action, or determination will be solely to evaluate, in general, the Work for compliance with the information in the Contract Documents and with the design concept of the Project as a functioning whole as shown or indicated in the Contract Documents (unless there is a specific statement indicating otherwise). The use of any such term or adjective is not intended to and shall not be effective to assign to Engineer any duty or authority to supervise or direct the performance of the Work, or any duty or authority to undertake responsibility contrary to the provisions of Paragraph 9.09 or any other provision of the Contract Documents.

C. *Day:*

1. The word “day” means a calendar day of 24 hours measured from midnight to the next midnight.

D. *Defective:*

1. The word “defective,” when modifying the word “Work,” refers to Work that is unsatisfactory, faulty, or deficient in that it:
 - a. does not conform to the Contract Documents; or
 - b. does not meet the requirements of any applicable inspection, reference standard, test, or approval referred to in the Contract Documents; or
 - c. has been damaged prior to Engineer’s recommendation of final payment (unless responsibility for the protection thereof has been assumed by Owner at Substantial Completion in accordance with Paragraph 14.04 or 14.05).

E. *Furnish, Install, Perform, Provide:*

1. The word “furnish,” when used in connection with services, materials, or equipment, shall mean to supply and deliver said services, materials, or equipment to the Site (or some other specified location) ready for use or installation and in usable or operable condition.
2. The word “install,” when used in connection with services, materials, or equipment, shall mean to put into use or place in final position said services, materials, or equipment complete and ready for intended use.
3. The words “perform” or “provide,” when used in connection with services, materials, or equipment, shall mean to furnish and install said services, materials, or equipment complete and ready for intended use.
4. When “furnish,” “install,” “perform,” or “provide” is not used in connection with services, materials, or equipment in a context clearly requiring an obligation of Contractor, “provide” is implied.

F. Unless stated otherwise in the Contract Documents, words or phrases that have a well-known technical or construction industry or trade meaning are used in the Contract Documents in accordance with such recognized meaning.

ARTICLE 2 – PRELIMINARY MATTERS

2.01 *Delivery of Bonds and Evidence of Insurance*

- A. When Contractor delivers the executed counterparts of the Agreement to Owner, Contractor shall also deliver to Owner such bonds as Contractor may be required to furnish.
- B. *Evidence of Insurance:* Before any Work at the Site is started, Contractor and Owner shall each deliver to the other, with copies to each additional insured identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance which either of them or any additional insured may reasonably request) which Contractor and Owner respectively are required to purchase and maintain in accordance with Article 5.

2.02 *Copies of Documents*

- A. Owner shall furnish to Contractor up to ten printed or hard copies of the Drawings and Project Manual. Additional copies will be furnished upon request at the cost of reproduction.

2.03 *Commencement of Contract Times; Notice to Proceed*

- A. The Contract Times will commence to run on the thirtieth day after the Effective Date of the Agreement or, if a Notice to Proceed is given, on the day indicated in the Notice to Proceed. A Notice to Proceed may be given at any time within 30 days after the Effective Date of the Agreement. In no event will the Contract Times commence to run later than the sixtieth day after the day of Bid opening or the thirtieth day after the Effective Date of the Agreement, whichever date is earlier.

2.04 *Starting the Work*

- A. Contractor shall start to perform the Work on the date when the Contract Times commence to run. No Work shall be done at the Site prior to the date on which the Contract Times commence to run.

2.05 *Before Starting Construction*

- A. *Preliminary Schedules:* Within 10 days after the Effective Date of the Agreement (unless otherwise specified in the General Requirements), Contractor shall submit to Engineer for timely review:
 - 1. a preliminary Progress Schedule indicating the times (numbers of days or dates) for starting and completing the various stages of the Work, including any Milestones specified in the Contract Documents;
 - 2. a preliminary Schedule of Submittals; and
 - 3. a preliminary Schedule of Values for all of the Work which includes quantities and prices of items which when added together equal the Contract Price and subdivides the Work into component parts in sufficient detail to serve as the basis for progress payments during performance of the Work. Such prices will include an appropriate amount of overhead and profit applicable to each item of Work.

2.06 *Preconstruction Conference; Designation of Authorized Representatives*

- A. Before any Work at the Site is started, a conference attended by Owner, Contractor, Engineer, and others as appropriate will be held to establish a working understanding among the parties as to the Work and to discuss the schedules referred to in Paragraph 2.05.A, procedures for handling Shop Drawings and other submittals, processing Applications for Payment, and maintaining required records.
- B. At this conference Owner and Contractor each shall designate, in writing, a specific individual to act as its authorized representative with respect to the services and responsibilities under the Contract. Such individuals shall have the authority to transmit instructions, receive information, render decisions relative to the Contract, and otherwise act on behalf of each respective party.

2.07 *Initial Acceptance of Schedules*

- A. At least 10 days before submission of the first Application for Payment a conference attended by Contractor, Engineer, and others as appropriate will be held to review for acceptability to Engineer as provided below the schedules submitted in accordance with Paragraph 2.05.A. Contractor shall have an additional 10 days to make corrections and adjustments and to complete and resubmit the schedules. No progress payment shall be made to Contractor until acceptable schedules are submitted to Engineer.
 - 1. The Progress Schedule will be acceptable to Engineer if it provides an orderly progression of the Work to completion within the Contract Times. Such acceptance will not impose on

Engineer responsibility for the Progress Schedule, for sequencing, scheduling, or progress of the Work, nor interfere with or relieve Contractor from Contractor's full responsibility therefor.

2. Contractor's Schedule of Submittals will be acceptable to Engineer if it provides a workable arrangement for reviewing and processing the required submittals.
3. Contractor's Schedule of Values will be acceptable to Engineer as to form and substance if it provides a reasonable allocation of the Contract Price to component parts of the Work.

ARTICLE 3 – CONTRACT DOCUMENTS: INTENT, AMENDING, REUSE

3.01 *Intent*

- A. The Contract Documents are complementary; what is required by one is as binding as if required by all.
- B. It is the intent of the Contract Documents to describe a functionally complete project (or part thereof) to be constructed in accordance with the Contract Documents. Any labor, documentation, services, materials, or equipment that reasonably may be inferred from the Contract Documents or from prevailing custom or trade usage as being required to produce the indicated result will be provided whether or not specifically called for, at no additional cost to Owner.
- C. Clarifications and interpretations of the Contract Documents shall be issued by Engineer as provided in Article 9.

3.02 *Reference Standards*

- A. Standards, Specifications, Codes, Laws, and Regulations
 1. Reference to standards, specifications, manuals, or codes of any technical society, organization, or association, or to Laws or Regulations, whether such reference be specific or by implication, shall mean the standard, specification, manual, code, or Laws or Regulations in effect at the time of opening of Bids (or on the Effective Date of the Agreement if there were no Bids), except as may be otherwise specifically stated in the Contract Documents.
 2. No provision of any such standard, specification, manual, or code, or any instruction of a Supplier, shall be effective to change the duties or responsibilities of Owner, Contractor, or Engineer, or any of their subcontractors, consultants, agents, or employees, from those set forth in the Contract Documents. No such provision or instruction shall be effective to assign to Owner, Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors, any duty or authority to supervise or direct the performance of the Work or any duty or authority to undertake responsibility inconsistent with the provisions of the Contract Documents.

3.03 *Reporting and Resolving Discrepancies*

A. *Reporting Discrepancies:*

1. *Contractor's Review of Contract Documents Before Starting Work:* Before undertaking each part of the Work, Contractor shall carefully study and compare the Contract Documents and check and verify pertinent figures therein and all applicable field measurements. Contractor shall promptly report in writing to Engineer any conflict, error, ambiguity, or discrepancy which Contractor discovers, or has actual knowledge of, and shall obtain a written interpretation or clarification from Engineer before proceeding with any Work affected thereby.
2. *Contractor's Review of Contract Documents During Performance of Work:* If, during the performance of the Work, Contractor discovers any conflict, error, ambiguity, or discrepancy within the Contract Documents, or between the Contract Documents and (a) any applicable Law or Regulation, (b) any standard, specification, manual, or code, or (c) any instruction of any Supplier, then Contractor shall promptly report it to Engineer in writing. Contractor shall not proceed with the Work affected thereby (except in an emergency as required by Paragraph 6.16.A) until an amendment or supplement to the Contract Documents has been issued by one of the methods indicated in Paragraph 3.04.
3. Contractor shall not be liable to Owner or Engineer for failure to report any conflict, error, ambiguity, or discrepancy in the Contract Documents unless Contractor had actual knowledge thereof.

B. *Resolving Discrepancies:*

1. Except as may be otherwise specifically stated in the Contract Documents, the provisions of the Contract Documents shall take precedence in resolving any conflict, error, ambiguity, or discrepancy between the provisions of the Contract Documents and:
 - a. the provisions of any standard, specification, manual, or code, or the instruction of any Supplier (whether or not specifically incorporated by reference in the Contract Documents); or
 - b. the provisions of any Laws or Regulations applicable to the performance of the Work (unless such an interpretation of the provisions of the Contract Documents would result in violation of such Law or Regulation).

3.04 *Amending and Supplementing Contract Documents*

- A. The Contract Documents may be amended to provide for additions, deletions, and revisions in the Work or to modify the terms and conditions thereof by either a Change Order or a Work Change Directive.
- B. The requirements of the Contract Documents may be supplemented, and minor variations and deviations in the Work may be authorized, by one or more of the following ways:

1. A Field Order;
2. Engineer's approval of a Shop Drawing or Sample (subject to the provisions of Paragraph 6.17.D.3); or
3. Engineer's written interpretation or clarification.

3.05 *Reuse of Documents*

A. Contractor and any Subcontractor or Supplier shall not:

1. have or acquire any title to or ownership rights in any of the Drawings, Specifications, or other documents (or copies of any thereof) prepared by or bearing the seal of Engineer or its consultants, including electronic media editions; or
2. reuse any such Drawings, Specifications, other documents, or copies thereof on extensions of the Project or any other project without written consent of Owner and Engineer and specific written verification or adaptation by Engineer.

B. The prohibitions of this Paragraph 3.05 will survive final payment, or termination of the Contract. Nothing herein shall preclude Contractor from retaining copies of the Contract Documents for record purposes.

3.06 *Electronic Data*

- A. Unless otherwise stated in the Supplementary Conditions, the data furnished by Owner or Engineer to Contractor, or by Contractor to Owner or Engineer, that may be relied upon are limited to the printed copies (also known as hard copies). Files in electronic media format of text, data, graphics, or other types are furnished only for the convenience of the receiving party. Any conclusion or information obtained or derived from such electronic files will be at the user's sole risk. If there is a discrepancy between the electronic files and the hard copies, the hard copies govern.
- B. Because data stored in electronic media format can deteriorate or be modified inadvertently or otherwise without authorization of the data's creator, the party receiving electronic files agrees that it will perform acceptance tests or procedures within 60 days, after which the receiving party shall be deemed to have accepted the data thus transferred. Any errors detected within the 60-day acceptance period will be corrected by the transferring party.
- C. When transferring documents in electronic media format, the transferring party makes no representations as to long term compatibility, usability, or readability of documents resulting from the use of software application packages, operating systems, or computer hardware differing from those used by the data's creator.

**ARTICLE 4 – AVAILABILITY OF LANDS; SUBSURFACE AND PHYSICAL CONDITIONS;
HAZARDOUS ENVIRONMENTAL CONDITIONS; REFERENCE POINTS**

4.01 *Availability of Lands*

- A. Owner shall furnish the Site. Owner shall notify Contractor of any encumbrances or restrictions not of general application but specifically related to use of the Site with which Contractor must comply in performing the Work. Owner will obtain in a timely manner and pay for easements for permanent structures or permanent changes in existing facilities. If Contractor and Owner are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times, or both, as a result of any delay in Owner's furnishing the Site or a part thereof, Contractor may make a Claim therefor as provided in Paragraph 10.05.
- B. Upon reasonable written request, Owner shall furnish Contractor with a current statement of record legal title and legal description of the lands upon which the Work is to be performed and Owner's interest therein as necessary for giving notice of or filing a mechanic's or construction lien against such lands in accordance with applicable Laws and Regulations.
- C. Contractor shall provide for all additional lands and access thereto that may be required for temporary construction facilities or storage of materials and equipment.

4.02 *Subsurface and Physical Conditions*

- A. *Reports and Drawings:* The Supplementary Conditions identify:
 - 1. those reports known to Owner of explorations and tests of subsurface conditions at or contiguous to the Site; and
 - 2. those drawings known to Owner of physical conditions relating to existing surface or subsurface structures at the Site (except Underground Facilities).
- B. *Limited Reliance by Contractor on Technical Data Authorized:* Contractor may rely upon the accuracy of the "technical data" contained in such reports and drawings, but such reports and drawings are not Contract Documents. Such "technical data" is identified in the Supplementary Conditions. Except for such reliance on such "technical data," Contractor may not rely upon or make any claim against Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors with respect to:
 - 1. the completeness of such reports and drawings for Contractor's purposes, including, but not limited to, any aspects of the means, methods, techniques, sequences, and procedures of construction to be employed by Contractor, and safety precautions and programs incident thereto; or
 - 2. other data, interpretations, opinions, and information contained in such reports or shown or indicated in such drawings; or
 - 3. any Contractor interpretation of or conclusion drawn from any "technical data" or any such other data, interpretations, opinions, or information.

4.03 *Differing Subsurface or Physical Conditions*

- A. *Notice:* If Contractor believes that any subsurface or physical condition that is uncovered or revealed either:
1. is of such a nature as to establish that any “technical data” on which Contractor is entitled to rely as provided in Paragraph 4.02 is materially inaccurate; or
 2. is of such a nature as to require a change in the Contract Documents; or
 3. differs materially from that shown or indicated in the Contract Documents; or
 4. is of an unusual nature, and differs materially from conditions ordinarily encountered and generally recognized as inherent in work of the character provided for in the Contract Documents;

then Contractor shall, promptly after becoming aware thereof and before further disturbing the subsurface or physical conditions or performing any Work in connection therewith (except in an emergency as required by Paragraph 6.16.A), notify Owner and Engineer in writing about such condition. Contractor shall not further disturb such condition or perform any Work in connection therewith (except as aforesaid) until receipt of written order to do so.

- B. *Engineer’s Review:* After receipt of written notice as required by Paragraph 4.03.A, Engineer will promptly review the pertinent condition, determine the necessity of Owner’s obtaining additional exploration or tests with respect thereto, and advise Owner in writing (with a copy to Contractor) of Engineer’s findings and conclusions.

C. *Possible Price and Times Adjustments:*

1. The Contract Price or the Contract Times, or both, will be equitably adjusted to the extent that the existence of such differing subsurface or physical condition causes an increase or decrease in Contractor’s cost of, or time required for, performance of the Work; subject, however, to the following:
 - a. such condition must meet any one or more of the categories described in Paragraph 4.03.A; and
 - b. with respect to Work that is paid for on a unit price basis, any adjustment in Contract Price will be subject to the provisions of Paragraphs 9.07 and 11.03.
2. Contractor shall not be entitled to any adjustment in the Contract Price or Contract Times if:
 - a. Contractor knew of the existence of such conditions at the time Contractor made a final commitment to Owner with respect to Contract Price and Contract Times by the submission of a Bid or becoming bound under a negotiated contract; or
 - b. the existence of such condition could reasonably have been discovered or revealed as a result of any examination, investigation, exploration, test, or study of the Site and

contiguous areas required by the Bidding Requirements or Contract Documents to be conducted by or for Contractor prior to Contractor's making such final commitment; or

- c. Contractor failed to give the written notice as required by Paragraph 4.03.A.
3. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times, or both, a Claim may be made therefor as provided in Paragraph 10.05. However, neither Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors shall be liable to Contractor for any claims, costs, losses, or damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Contractor on or in connection with any other project or anticipated project.

4.04 *Underground Facilities*

A. *Shown or Indicated:* The information and data shown or indicated in the Contract Documents with respect to existing Underground Facilities at or contiguous to the Site is based on information and data furnished to Owner or Engineer by the owners of such Underground Facilities, including Owner, or by others. Unless it is otherwise expressly provided in the Supplementary Conditions:

1. Owner and Engineer shall not be responsible for the accuracy or completeness of any such information or data provided by others; and
2. the cost of all of the following will be included in the Contract Price, and Contractor shall have full responsibility for:
 - a. reviewing and checking all such information and data;
 - b. locating all Underground Facilities shown or indicated in the Contract Documents;
 - c. coordination of the Work with the owners of such Underground Facilities, including Owner, during construction; and
 - d. the safety and protection of all such Underground Facilities and repairing any damage thereto resulting from the Work.

B. *Not Shown or Indicated:*

1. If an Underground Facility is uncovered or revealed at or contiguous to the Site which was not shown or indicated, or not shown or indicated with reasonable accuracy in the Contract Documents, Contractor shall, promptly after becoming aware thereof and before further disturbing conditions affected thereby or performing any Work in connection therewith (except in an emergency as required by Paragraph 6.16.A), identify the owner of such Underground Facility and give written notice to that owner and to Owner and Engineer. Engineer will promptly review the Underground Facility and determine the extent, if any, to which a change is required in the Contract Documents to reflect and document the

consequences of the existence or location of the Underground Facility. During such time, Contractor shall be responsible for the safety and protection of such Underground Facility.

2. If Engineer concludes that a change in the Contract Documents is required, a Work Change Directive or a Change Order will be issued to reflect and document such consequences. An equitable adjustment shall be made in the Contract Price or Contract Times, or both, to the extent that they are attributable to the existence or location of any Underground Facility that was not shown or indicated or not shown or indicated with reasonable accuracy in the Contract Documents and that Contractor did not know of and could not reasonably have been expected to be aware of or to have anticipated. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment in Contract Price or Contract Times, Owner or Contractor may make a Claim therefor as provided in Paragraph 10.05.

4.05 *Reference Points*

- A. Owner shall provide engineering surveys to establish reference points for construction which in Engineer's judgment are necessary to enable Contractor to proceed with the Work. Contractor shall be responsible for laying out the Work, shall protect and preserve the established reference points and property monuments, and shall make no changes or relocations without the prior written approval of Owner. Contractor shall report to Engineer whenever any reference point or property monument is lost or destroyed or requires relocation because of necessary changes in grades or locations, and shall be responsible for the accurate replacement or relocation of such reference points or property monuments by professionally qualified personnel.

4.06 *Hazardous Environmental Condition at Site*

- A. *Reports and Drawings:* The Supplementary Conditions identify those reports and drawings known to Owner relating to Hazardous Environmental Conditions that have been identified at the Site.
- B. *Limited Reliance by Contractor on Technical Data Authorized:* Contractor may rely upon the accuracy of the "technical data" contained in such reports and drawings, but such reports and drawings are not Contract Documents. Such "technical data" is identified in the Supplementary Conditions. Except for such reliance on such "technical data," Contractor may not rely upon or make any claim against Owner or Engineer, or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors with respect to:
 1. the completeness of such reports and drawings for Contractor's purposes, including, but not limited to, any aspects of the means, methods, techniques, sequences and procedures of construction to be employed by Contractor and safety precautions and programs incident thereto; or
 2. other data, interpretations, opinions and information contained in such reports or shown or indicated in such drawings; or
 3. any Contractor interpretation of or conclusion drawn from any "technical data" or any such other data, interpretations, opinions or information.

- C. Contractor shall not be responsible for any Hazardous Environmental Condition uncovered or revealed at the Site which was not shown or indicated in Drawings or Specifications or identified in the Contract Documents to be within the scope of the Work. Contractor shall be responsible for a Hazardous Environmental Condition created with any materials brought to the Site by Contractor, Subcontractors, Suppliers, or anyone else for whom Contractor is responsible.
- D. If Contractor encounters a Hazardous Environmental Condition or if Contractor or anyone for whom Contractor is responsible creates a Hazardous Environmental Condition, Contractor shall immediately: (i) secure or otherwise isolate such condition; (ii) stop all Work in connection with such condition and in any area affected thereby (except in an emergency as required by Paragraph 6.16.A); and (iii) notify Owner and Engineer (and promptly thereafter confirm such notice in writing). Owner shall promptly consult with Engineer concerning the necessity for Owner to retain a qualified expert to evaluate such condition or take corrective action, if any. Promptly after consulting with Engineer, Owner shall take such actions as are necessary to permit Owner to timely obtain required permits and provide Contractor the written notice required by Paragraph 4.06.E.
- E. Contractor shall not be required to resume Work in connection with such condition or in any affected area until after Owner has obtained any required permits related thereto and delivered written notice to Contractor: (i) specifying that such condition and any affected area is or has been rendered safe for the resumption of Work; or (ii) specifying any special conditions under which such Work may be resumed safely. If Owner and Contractor cannot agree as to entitlement to or on the amount or extent, if any, of any adjustment in Contract Price or Contract Times, or both, as a result of such Work stoppage or such special conditions under which Work is agreed to be resumed by Contractor, either party may make a Claim therefor as provided in Paragraph 10.05.
- F. If after receipt of such written notice Contractor does not agree to resume such Work based on a reasonable belief it is unsafe, or does not agree to resume such Work under such special conditions, then Owner may order the portion of the Work that is in the area affected by such condition to be deleted from the Work. If Owner and Contractor cannot agree as to entitlement to or on the amount or extent, if any, of an adjustment in Contract Price or Contract Times as a result of deleting such portion of the Work, then either party may make a Claim therefor as provided in Paragraph 10.05. Owner may have such deleted portion of the Work performed by Owner's own forces or others in accordance with Article 7.
- G. To the fullest extent permitted by Laws and Regulations, Owner shall indemnify and hold harmless Contractor, Subcontractors, and Engineer, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to a Hazardous Environmental Condition, provided that such Hazardous Environmental Condition: (i) was not shown or indicated in the Drawings or Specifications or identified in the Contract Documents to be included within the scope of the Work, and (ii) was not created by Contractor or by anyone for whom Contractor is responsible. Nothing in this Paragraph 4.06.G shall obligate Owner to indemnify any individual or entity from and against the consequences of that individual's or entity's own negligence.

- H. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to a Hazardous Environmental Condition created by Contractor or by anyone for whom Contractor is responsible. Nothing in this Paragraph 4.06.H shall obligate Contractor to indemnify any individual or entity from and against the consequences of that individual's or entity's own negligence.
- I. The provisions of Paragraphs 4.02, 4.03, and 4.04 do not apply to a Hazardous Environmental Condition uncovered or revealed at the Site.

ARTICLE 5 – BONDS AND INSURANCE

5.01 Performance, Payment, and Other Bonds

- A. Contractor shall furnish performance and payment bonds, each in an amount at least equal to the Contract Price as security for the faithful performance and payment of all of Contractor's obligations under the Contract Documents. These bonds shall remain in effect until one year after the date when final payment becomes due or until completion of the correction period specified in Paragraph 13.07, whichever is later, except as provided otherwise by Laws or Regulations or by the Contract Documents. Contractor shall also furnish such other bonds as are required by the Contract Documents.
- B. All bonds shall be in the form prescribed by the Contract Documents except as provided otherwise by Laws or Regulations, and shall be executed by such sureties as are named in the list of "Companies Holding Certificates of Authority as Acceptable Sureties on Federal Bonds and as Acceptable Reinsuring Companies" as published in Circular 570 (amended) by the Financial Management Service, Surety Bond Branch, U.S. Department of the Treasury. All bonds signed by an agent or attorney-in-fact must be accompanied by a certified copy of that individual's authority to bind the surety. The evidence of authority shall show that it is effective on the date the agent or attorney-in-fact signed each bond.
- C. If the surety on any bond furnished by Contractor is declared bankrupt or becomes insolvent or its right to do business is terminated in any state where any part of the Project is located or it ceases to meet the requirements of Paragraph 5.01.B, Contractor shall promptly notify Owner and Engineer and shall, within 20 days after the event giving rise to such notification, provide another bond and surety, both of which shall comply with the requirements of Paragraphs 5.01.B and 5.02.

5.02 Licensed Sureties and Insurers

- A. All bonds and insurance required by the Contract Documents to be purchased and maintained by Owner or Contractor shall be obtained from surety or insurance companies that are duly licensed or authorized in the jurisdiction in which the Project is located to issue bonds or insurance policies for the limits and coverages so required. Such surety and insurance companies shall also

meet such additional requirements and qualifications as may be provided in the Supplementary Conditions.

5.03 *Certificates of Insurance*

- A. Contractor shall deliver to Owner, with copies to each additional insured and loss payee identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance requested by Owner or any other additional insured) which Contractor is required to purchase and maintain.
- B. Owner shall deliver to Contractor, with copies to each additional insured and loss payee identified in the Supplementary Conditions, certificates of insurance (and other evidence of insurance requested by Contractor or any other additional insured) which Owner is required to purchase and maintain.
- C. Failure of Owner to demand such certificates or other evidence of Contractor's full compliance with these insurance requirements or failure of Owner to identify a deficiency in compliance from the evidence provided shall not be construed as a waiver of Contractor's obligation to maintain such insurance.
- D. Owner does not represent that insurance coverage and limits established in this Contract necessarily will be adequate to protect Contractor.
- E. The insurance and insurance limits required herein shall not be deemed as a limitation on Contractor's liability under the indemnities granted to Owner in the Contract Documents.

5.04 *Contractor's Insurance*

- A. Contractor shall purchase and maintain such insurance as is appropriate for the Work being performed and as will provide protection from claims set forth below which may arise out of or result from Contractor's performance of the Work and Contractor's other obligations under the Contract Documents, whether it is to be performed by Contractor, any Subcontractor or Supplier, or by anyone directly or indirectly employed by any of them to perform any of the Work, or by anyone for whose acts any of them may be liable:
 - 1. claims under workers' compensation, disability benefits, and other similar employee benefit acts;
 - 2. claims for damages because of bodily injury, occupational sickness or disease, or death of Contractor's employees;
 - 3. claims for damages because of bodily injury, sickness or disease, or death of any person other than Contractor's employees;
 - 4. claims for damages insured by reasonably available personal injury liability coverage which are sustained:

- a. by any person as a result of an offense directly or indirectly related to the employment of such person by Contractor, or
 - b. by any other person for any other reason;
5. claims for damages, other than to the Work itself, because of injury to or destruction of tangible property wherever located, including loss of use resulting therefrom; and
 6. claims for damages because of bodily injury or death of any person or property damage arising out of the ownership, maintenance or use of any motor vehicle.
- B. The policies of insurance required by this Paragraph 5.04 shall:
1. with respect to insurance required by Paragraphs 5.04.A.3 through 5.04.A.6 inclusive, be written on an occurrence basis, include as additional insureds (subject to any customary exclusion regarding professional liability) Owner and Engineer, and any other individuals or entities identified in the Supplementary Conditions, all of whom shall be listed as additional insureds, and include coverage for the respective officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of all such additional insureds, and the insurance afforded to these additional insureds shall provide primary coverage for all claims covered thereby;
 2. include at least the specific coverages and be written for not less than the limits of liability provided in the Supplementary Conditions or required by Laws or Regulations, whichever is greater;
 3. include contractual liability insurance covering Contractor's indemnity obligations under Paragraphs 6.11 and 6.20;
 4. contain a provision or endorsement that the coverage afforded will not be canceled, materially changed or renewal refused until at least 30 days prior written notice has been given to Owner and Contractor and to each other additional insured identified in the Supplementary Conditions to whom a certificate of insurance has been issued (and the certificates of insurance furnished by the Contractor pursuant to Paragraph 5.03 will so provide);
 5. remain in effect at least until final payment and at all times thereafter when Contractor may be correcting, removing, or replacing defective Work in accordance with Paragraph 13.07; and
 6. include completed operations coverage:
 - a. Such insurance shall remain in effect for two years after final payment.
 - b. Contractor shall furnish Owner and each other additional insured identified in the Supplementary Conditions, to whom a certificate of insurance has been issued, evidence satisfactory to Owner and any such additional insured of continuation of such insurance at final payment and one year thereafter.

5.05 *Owner's Liability Insurance*

- A. In addition to the insurance required to be provided by Contractor under Paragraph 5.04, Owner, at Owner's option, may purchase and maintain at Owner's expense Owner's own liability insurance as will protect Owner against claims which may arise from operations under the Contract Documents.

5.06 *Property Insurance*

- A. Unless otherwise provided in the Supplementary Conditions, Owner shall purchase and maintain property insurance upon the Work at the Site in the amount of the full replacement cost thereof (subject to such deductible amounts as may be provided in the Supplementary Conditions or required by Laws and Regulations). This insurance shall:
1. include the interests of Owner, Contractor, Subcontractors, and Engineer, and any other individuals or entities identified in the Supplementary Conditions, and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them, each of whom is deemed to have an insurable interest and shall be listed as a loss payee;
 2. be written on a Builder's Risk "all-risk" policy form that shall at least include insurance for physical loss or damage to the Work, temporary buildings, falsework, and materials and equipment in transit, and shall insure against at least the following perils or causes of loss: fire, lightning, extended coverage, theft, vandalism and malicious mischief, earthquake, collapse, debris removal, demolition occasioned by enforcement of Laws and Regulations, water damage (other than that caused by flood), and such other perils or causes of loss as may be specifically required by the Supplementary Conditions.
 3. include expenses incurred in the repair or replacement of any insured property (including but not limited to fees and charges of engineers and architects);
 4. cover materials and equipment stored at the Site or at another location that was agreed to in writing by Owner prior to being incorporated in the Work, provided that such materials and equipment have been included in an Application for Payment recommended by Engineer;
 5. allow for partial utilization of the Work by Owner;
 6. include testing and startup; and
 7. be maintained in effect until final payment is made unless otherwise agreed to in writing by Owner, Contractor, and Engineer with 30 days written notice to each other loss payee to whom a certificate of insurance has been issued.
- B. Owner shall purchase and maintain such equipment breakdown insurance or additional property insurance as may be required by the Supplementary Conditions or Laws and Regulations which will include the interests of Owner, Contractor, Subcontractors, and Engineer, and any other individuals or entities identified in the Supplementary Conditions, and the officers, directors,

members, partners, employees, agents, consultants and subcontractors of each and any of them, each of whom is deemed to have an insurable interest and shall be listed as a loss payee.

- C. All the policies of insurance (and the certificates or other evidence thereof) required to be purchased and maintained in accordance with this Paragraph 5.06 will contain a provision or endorsement that the coverage afforded will not be canceled or materially changed or renewal refused until at least 30 days prior written notice has been given to Owner and Contractor and to each other loss payee to whom a certificate of insurance has been issued and will contain waiver provisions in accordance with Paragraph 5.07.
- D. Owner shall not be responsible for purchasing and maintaining any property insurance specified in this Paragraph 5.06 to protect the interests of Contractor, Subcontractors, or others in the Work to the extent of any deductible amounts that are identified in the Supplementary Conditions. The risk of loss within such identified deductible amount will be borne by Contractor, Subcontractors, or others suffering any such loss, and if any of them wishes property insurance coverage within the limits of such amounts, each may purchase and maintain it at the purchaser's own expense.
- E. If Contractor requests in writing that other special insurance be included in the property insurance policies provided under this Paragraph 5.06, Owner shall, if possible, include such insurance, and the cost thereof will be charged to Contractor by appropriate Change Order. Prior to commencement of the Work at the Site, Owner shall in writing advise Contractor whether or not such other insurance has been procured by Owner.

5.07 *Waiver of Rights*

- A. Owner and Contractor intend that all policies purchased in accordance with Paragraph 5.06 will protect Owner, Contractor, Subcontractors, and Engineer, and all other individuals or entities identified in the Supplementary Conditions as loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) in such policies and will provide primary coverage for all losses and damages caused by the perils or causes of loss covered thereby. All such policies shall contain provisions to the effect that in the event of payment of any loss or damage the insurers will have no rights of recovery against any of the insureds or loss payees thereunder. Owner and Contractor waive all rights against each other and their respective officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them for all losses and damages caused by, arising out of or resulting from any of the perils or causes of loss covered by such policies and any other property insurance applicable to the Work; and, in addition, waive all such rights against Subcontractors and Engineer, and all other individuals or entities identified in the Supplementary Conditions as loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) under such policies for losses and damages so caused. None of the above waivers shall extend to the rights that any party making such waiver may have to the proceeds of insurance held by Owner as trustee or otherwise payable under any policy so issued.
- B. Owner waives all rights against Contractor, Subcontractors, and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them for:

1. loss due to business interruption, loss of use, or other consequential loss extending beyond direct physical loss or damage to Owner's property or the Work caused by, arising out of, or resulting from fire or other perils whether or not insured by Owner; and
 2. loss or damage to the completed Project or part thereof caused by, arising out of, or resulting from fire or other insured peril or cause of loss covered by any property insurance maintained on the completed Project or part thereof by Owner during partial utilization pursuant to Paragraph 14.05, after Substantial Completion pursuant to Paragraph 14.04, or after final payment pursuant to Paragraph 14.07.
- C. Any insurance policy maintained by Owner covering any loss, damage or consequential loss referred to in Paragraph 5.07.B shall contain provisions to the effect that in the event of payment of any such loss, damage, or consequential loss, the insurers will have no rights of recovery against Contractor, Subcontractors, or Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them.

5.08 *Receipt and Application of Insurance Proceeds*

- A. Any insured loss under the policies of insurance required by Paragraph 5.06 will be adjusted with Owner and made payable to Owner as fiduciary for the loss payees, as their interests may appear, subject to the requirements of any applicable mortgage clause and of Paragraph 5.08.B. Owner shall deposit in a separate account any money so received and shall distribute it in accordance with such agreement as the parties in interest may reach. If no other special agreement is reached, the damaged Work shall be repaired or replaced, the moneys so received applied on account thereof, and the Work and the cost thereof covered by an appropriate Change Order.
- B. Owner as fiduciary shall have power to adjust and settle any loss with the insurers unless one of the parties in interest shall object in writing within 15 days after the occurrence of loss to Owner's exercise of this power. If such objection be made, Owner as fiduciary shall make settlement with the insurers in accordance with such agreement as the parties in interest may reach. If no such agreement among the parties in interest is reached, Owner as fiduciary shall adjust and settle the loss with the insurers and, if required in writing by any party in interest, Owner as fiduciary shall give bond for the proper performance of such duties.

5.09 *Acceptance of Bonds and Insurance; Option to Replace*

- A. If either Owner or Contractor has any objection to the coverage afforded by or other provisions of the bonds or insurance required to be purchased and maintained by the other party in accordance with Article 5 on the basis of non-conformance with the Contract Documents, the objecting party shall so notify the other party in writing within 10 days after receipt of the certificates (or other evidence requested) required by Paragraph 2.01.B. Owner and Contractor shall each provide to the other such additional information in respect of insurance provided as the other may reasonably request. If either party does not purchase or maintain all of the bonds and insurance required of such party by the Contract Documents, such party shall notify the other party in writing of such failure to purchase prior to the start of the Work, or of such failure to maintain prior to any change in the required coverage. Without prejudice to any other right or remedy, the other party may elect to obtain equivalent bonds or insurance to protect such other party's

interests at the expense of the party who was required to provide such coverage, and a Change Order shall be issued to adjust the Contract Price accordingly.

5.10 *Partial Utilization, Acknowledgment of Property Insurer*

- A. If Owner finds it necessary to occupy or use a portion or portions of the Work prior to Substantial Completion of all the Work as provided in Paragraph 14.05, no such use or occupancy shall commence before the insurers providing the property insurance pursuant to Paragraph 5.06 have acknowledged notice thereof and in writing effected any changes in coverage necessitated thereby. The insurers providing the property insurance shall consent by endorsement on the policy or policies, but the property insurance shall not be canceled or permitted to lapse on account of any such partial use or occupancy.

ARTICLE 6 – CONTRACTOR’S RESPONSIBILITIES

6.01 *Supervision and Superintendence*

- A. Contractor shall supervise, inspect, and direct the Work competently and efficiently, devoting such attention thereto and applying such skills and expertise as may be necessary to perform the Work in accordance with the Contract Documents. Contractor shall be solely responsible for the means, methods, techniques, sequences, and procedures of construction. Contractor shall not be responsible for the negligence of Owner or Engineer in the design or specification of a specific means, method, technique, sequence, or procedure of construction which is shown or indicated in and expressly required by the Contract Documents.
- B. At all times during the progress of the Work, Contractor shall assign a competent resident superintendent who shall not be replaced without written notice to Owner and Engineer except under extraordinary circumstances.

6.02 *Labor; Working Hours*

- A. Contractor shall provide competent, suitably qualified personnel to survey and lay out the Work and perform construction as required by the Contract Documents. Contractor shall at all times maintain good discipline and order at the Site.
- B. Except as otherwise required for the safety or protection of persons or the Work or property at the Site or adjacent thereto, and except as otherwise stated in the Contract Documents, all Work at the Site shall be performed during regular working hours. Contractor will not permit the performance of Work on a Saturday, Sunday, or any legal holiday without Owner’s written consent (which will not be unreasonably withheld) given after prior written notice to Engineer.

6.03 *Services, Materials, and Equipment*

- A. Unless otherwise specified in the Contract Documents, Contractor shall provide and assume full responsibility for all services, materials, equipment, labor, transportation, construction equipment and machinery, tools, appliances, fuel, power, light, heat, telephone, water, sanitary facilities, temporary facilities, and all other facilities and incidentals necessary for the performance, testing, start-up, and completion of the Work.

- B. All materials and equipment incorporated into the Work shall be as specified or, if not specified, shall be of good quality and new, except as otherwise provided in the Contract Documents. All special warranties and guarantees required by the Specifications shall expressly run to the benefit of Owner. If required by Engineer, Contractor shall furnish satisfactory evidence (including reports of required tests) as to the source, kind, and quality of materials and equipment.
- C. All materials and equipment shall be stored, applied, installed, connected, erected, protected, used, cleaned, and conditioned in accordance with instructions of the applicable Supplier, except as otherwise may be provided in the Contract Documents.

6.04 *Progress Schedule*

- A. Contractor shall adhere to the Progress Schedule established in accordance with Paragraph 2.07 as it may be adjusted from time to time as provided below.
 - 1. Contractor shall submit to Engineer for acceptance (to the extent indicated in Paragraph 2.07) proposed adjustments in the Progress Schedule that will not result in changing the Contract Times. Such adjustments will comply with any provisions of the General Requirements applicable thereto.
 - 2. Proposed adjustments in the Progress Schedule that will change the Contract Times shall be submitted in accordance with the requirements of Article 12. Adjustments in Contract Times may only be made by a Change Order.

6.05 *Substitutes and "Or-Equals"*

- A. Whenever an item of material or equipment is specified or described in the Contract Documents by using the name of a proprietary item or the name of a particular Supplier, the specification or description is intended to establish the type, function, appearance, and quality required. Unless the specification or description contains or is followed by words reading that no like, equivalent, or "or-equal" item or no substitution is permitted, other items of material or equipment or material or equipment of other Suppliers may be submitted to Engineer for review under the circumstances described below.
 - 1. "*Or-Equal*" Items: If in Engineer's sole discretion an item of material or equipment proposed by Contractor is functionally equal to that named and sufficiently similar so that no change in related Work will be required, it may be considered by Engineer as an "or-equal" item, in which case review and approval of the proposed item may, in Engineer's sole discretion, be accomplished without compliance with some or all of the requirements for approval of proposed substitute items. For the purposes of this Paragraph 6.05.A.1, a proposed item of material or equipment will be considered functionally equal to an item so named if:
 - a. in the exercise of reasonable judgment Engineer determines that:
 - 1) it is at least equal in materials of construction, quality, durability, appearance, strength, and design characteristics;

- 2) it will reliably perform at least equally well the function and achieve the results imposed by the design concept of the completed Project as a functioning whole; and
 - 3) it has a proven record of performance and availability of responsive service.
- b. Contractor certifies that, if approved and incorporated into the Work:
- 1) there will be no increase in cost to the Owner or increase in Contract Times; and
 - 2) it will conform substantially to the detailed requirements of the item named in the Contract Documents.

2. *Substitute Items:*

- a. If in Engineer's sole discretion an item of material or equipment proposed by Contractor does not qualify as an "or-equal" item under Paragraph 6.05.A.1, it will be considered a proposed substitute item.
- b. Contractor shall submit sufficient information as provided below to allow Engineer to determine if the item of material or equipment proposed is essentially equivalent to that named and an acceptable substitute therefor. Requests for review of proposed substitute items of material or equipment will not be accepted by Engineer from anyone other than Contractor.
- c. The requirements for review by Engineer will be as set forth in Paragraph 6.05.A.2.d, as supplemented by the General Requirements, and as Engineer may decide is appropriate under the circumstances.
- d. Contractor shall make written application to Engineer for review of a proposed substitute item of material or equipment that Contractor seeks to furnish or use. The application:
 - 1) shall certify that the proposed substitute item will:
 - a) perform adequately the functions and achieve the results called for by the general design,
 - b) be similar in substance to that specified, and
 - c) be suited to the same use as that specified;
 - 2) will state:
 - a) the extent, if any, to which the use of the proposed substitute item will prejudice Contractor's achievement of Substantial Completion on time,
 - b) whether use of the proposed substitute item in the Work will require a change in any of the Contract Documents (or in the provisions of any other direct contract with Owner for other work on the Project) to adapt the design to the proposed substitute item, and

- c) whether incorporation or use of the proposed substitute item in connection with the Work is subject to payment of any license fee or royalty;
 - 3) will identify:
 - a) all variations of the proposed substitute item from that specified, and
 - b) available engineering, sales, maintenance, repair, and replacement services; and
 - 4) shall contain an itemized estimate of all costs or credits that will result directly or indirectly from use of such substitute item, including costs of redesign and claims of other contractors affected by any resulting change.
- B. *Substitute Construction Methods or Procedures:* If a specific means, method, technique, sequence, or procedure of construction is expressly required by the Contract Documents, Contractor may furnish or utilize a substitute means, method, technique, sequence, or procedure of construction approved by Engineer. Contractor shall submit sufficient information to allow Engineer, in Engineer's sole discretion, to determine that the substitute proposed is equivalent to that expressly called for by the Contract Documents. The requirements for review by Engineer will be similar to those provided in Paragraph 6.05.A.2.
- C. *Engineer's Evaluation:* Engineer will be allowed a reasonable time within which to evaluate each proposal or submittal made pursuant to Paragraphs 6.05.A and 6.05.B. Engineer may require Contractor to furnish additional data about the proposed substitute item. Engineer will be the sole judge of acceptability. No "or equal" or substitute will be ordered, installed or utilized until Engineer's review is complete, which will be evidenced by a Change Order in the case of a substitute and an approved Shop Drawing for an "or equal." Engineer will advise Contractor in writing of any negative determination.
- D. *Special Guarantee:* Owner may require Contractor to furnish at Contractor's expense a special performance guarantee or other surety with respect to any substitute.
- E. *Engineer's Cost Reimbursement:* Engineer will record Engineer's costs in evaluating a substitute proposed or submitted by Contractor pursuant to Paragraphs 6.05.A.2 and 6.05.B. Whether or not Engineer approves a substitute so proposed or submitted by Contractor, Contractor shall reimburse Owner for the reasonable charges of Engineer for evaluating each such proposed substitute. Contractor shall also reimburse Owner for the reasonable charges of Engineer for making changes in the Contract Documents (or in the provisions of any other direct contract with Owner) resulting from the acceptance of each proposed substitute.
- F. *Contractor's Expense:* Contractor shall provide all data in support of any proposed substitute or "or-equal" at Contractor's expense.

6.06 *Concerning Subcontractors, Suppliers, and Others*

- A. Contractor shall not employ any Subcontractor, Supplier, or other individual or entity (including those acceptable to Owner as indicated in Paragraph 6.06.B), whether initially or as a replacement, against whom Owner may have reasonable objection. Contractor shall not be

required to employ any Subcontractor, Supplier, or other individual or entity to furnish or perform any of the Work against whom Contractor has reasonable objection.

- B. If the Supplementary Conditions require the identity of certain Subcontractors, Suppliers, or other individuals or entities to be submitted to Owner in advance for acceptance by Owner by a specified date prior to the Effective Date of the Agreement, and if Contractor has submitted a list thereof in accordance with the Supplementary Conditions, Owner's acceptance (either in writing or by failing to make written objection thereto by the date indicated for acceptance or objection in the Bidding Documents or the Contract Documents) of any such Subcontractor, Supplier, or other individual or entity so identified may be revoked on the basis of reasonable objection after due investigation. Contractor shall submit an acceptable replacement for the rejected Subcontractor, Supplier, or other individual or entity, and the Contract Price will be adjusted by the difference in the cost occasioned by such replacement, and an appropriate Change Order will be issued. No acceptance by Owner of any such Subcontractor, Supplier, or other individual or entity, whether initially or as a replacement, shall constitute a waiver of any right of Owner or Engineer to reject defective Work.
- C. Contractor shall be fully responsible to Owner and Engineer for all acts and omissions of the Subcontractors, Suppliers, and other individuals or entities performing or furnishing any of the Work just as Contractor is responsible for Contractor's own acts and omissions. Nothing in the Contract Documents:
1. shall create for the benefit of any such Subcontractor, Supplier, or other individual or entity any contractual relationship between Owner or Engineer and any such Subcontractor, Supplier or other individual or entity; nor
 2. shall create any obligation on the part of Owner or Engineer to pay or to see to the payment of any moneys due any such Subcontractor, Supplier, or other individual or entity except as may otherwise be required by Laws and Regulations.
- D. Contractor shall be solely responsible for scheduling and coordinating the Work of Subcontractors, Suppliers, and other individuals or entities performing or furnishing any of the Work under a direct or indirect contract with Contractor.
- E. Contractor shall require all Subcontractors, Suppliers, and such other individuals or entities performing or furnishing any of the Work to communicate with Engineer through Contractor.
- F. The divisions and sections of the Specifications and the identifications of any Drawings shall not control Contractor in dividing the Work among Subcontractors or Suppliers or delineating the Work to be performed by any specific trade.
- G. All Work performed for Contractor by a Subcontractor or Supplier will be pursuant to an appropriate agreement between Contractor and the Subcontractor or Supplier which specifically binds the Subcontractor or Supplier to the applicable terms and conditions of the Contract Documents for the benefit of Owner and Engineer. Whenever any such agreement is with a Subcontractor or Supplier who is listed as a loss payee on the property insurance provided in Paragraph 5.06, the agreement between the Contractor and the Subcontractor or Supplier will contain provisions whereby the Subcontractor or Supplier waives all rights against Owner,

Contractor, Engineer, and all other individuals or entities identified in the Supplementary Conditions to be listed as insureds or loss payees (and the officers, directors, members, partners, employees, agents, consultants, and subcontractors of each and any of them) for all losses and damages caused by, arising out of, relating to, or resulting from any of the perils or causes of loss covered by such policies and any other property insurance applicable to the Work. If the insurers on any such policies require separate waiver forms to be signed by any Subcontractor or Supplier, Contractor will obtain the same.

6.07 *Patent Fees and Royalties*

- A. Contractor shall pay all license fees and royalties and assume all costs incident to the use in the performance of the Work or the incorporation in the Work of any invention, design, process, product, or device which is the subject of patent rights or copyrights held by others. If a particular invention, design, process, product, or device is specified in the Contract Documents for use in the performance of the Work and if, to the actual knowledge of Owner or Engineer, its use is subject to patent rights or copyrights calling for the payment of any license fee or royalty to others, the existence of such rights shall be disclosed by Owner in the Contract Documents.
- B. To the fullest extent permitted by Laws and Regulations, Owner shall indemnify and hold harmless Contractor, and its officers, directors, members, partners, employees, agents, consultants, and subcontractors from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals, and all court or arbitration or other dispute resolution costs) arising out of or relating to any infringement of patent rights or copyrights incident to the use in the performance of the Work or resulting from the incorporation in the Work of any invention, design, process, product, or device specified in the Contract Documents, but not identified as being subject to payment of any license fee or royalty to others required by patent rights or copyrights.
- C. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to any infringement of patent rights or copyrights incident to the use in the performance of the Work or resulting from the incorporation in the Work of any invention, design, process, product, or device not specified in the Contract Documents.

6.08 *Permits*

- A. Unless otherwise provided in the Supplementary Conditions, Contractor shall obtain and pay for all construction permits and licenses. Owner shall assist Contractor, when necessary, in obtaining such permits and licenses. Contractor shall pay all governmental charges and inspection fees necessary for the prosecution of the Work which are applicable at the time of opening of Bids, or, if there are no Bids, on the Effective Date of the Agreement. Owner shall pay all charges of utility owners for connections for providing permanent service to the Work.

6.09 *Laws and Regulations*

- A. Contractor shall give all notices required by and shall comply with all Laws and Regulations applicable to the performance of the Work. Except where otherwise expressly required by applicable Laws and Regulations, neither Owner nor Engineer shall be responsible for monitoring Contractor's compliance with any Laws or Regulations.
- B. If Contractor performs any Work knowing or having reason to know that it is contrary to Laws or Regulations, Contractor shall bear all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such Work. However, it shall not be Contractor's responsibility to make certain that the Specifications and Drawings are in accordance with Laws and Regulations, but this shall not relieve Contractor of Contractor's obligations under Paragraph 3.03.
- C. Changes in Laws or Regulations not known at the time of opening of Bids (or, on the Effective Date of the Agreement if there were no Bids) having an effect on the cost or time of performance of the Work shall be the subject of an adjustment in Contract Price or Contract Times. If Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment, a Claim may be made therefor as provided in Paragraph 10.05.

6.10 *Taxes*

- A. Contractor shall pay all sales, consumer, use, and other similar taxes required to be paid by Contractor in accordance with the Laws and Regulations of the place of the Project which are applicable during the performance of the Work.

6.11 *Use of Site and Other Areas*

A. *Limitation on Use of Site and Other Areas:*

1. Contractor shall confine construction equipment, the storage of materials and equipment, and the operations of workers to the Site and other areas permitted by Laws and Regulations, and shall not unreasonably encumber the Site and other areas with construction equipment or other materials or equipment. Contractor shall assume full responsibility for any damage to any such land or area, or to the owner or occupant thereof, or of any adjacent land or areas resulting from the performance of the Work.
2. Should any claim be made by any such owner or occupant because of the performance of the Work, Contractor shall promptly settle with such other party by negotiation or otherwise resolve the claim by arbitration or other dispute resolution proceeding or at law.
3. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to any claim or action, legal or equitable, brought

by any such owner or occupant against Owner, Engineer, or any other party indemnified hereunder to the extent caused by or based upon Contractor's performance of the Work.

- B. *Removal of Debris During Performance of the Work:* During the progress of the Work Contractor shall keep the Site and other areas free from accumulations of waste materials, rubbish, and other debris. Removal and disposal of such waste materials, rubbish, and other debris shall conform to applicable Laws and Regulations.
- C. *Cleaning:* Prior to Substantial Completion of the Work Contractor shall clean the Site and the Work and make it ready for utilization by Owner. At the completion of the Work Contractor shall remove from the Site all tools, appliances, construction equipment and machinery, and surplus materials and shall restore to original condition all property not designated for alteration by the Contract Documents.
- D. *Loading Structures:* Contractor shall not load nor permit any part of any structure to be loaded in any manner that will endanger the structure, nor shall Contractor subject any part of the Work or adjacent property to stresses or pressures that will endanger it.

6.12 *Record Documents*

- A. Contractor shall maintain in a safe place at the Site one record copy of all Drawings, Specifications, Addenda, Change Orders, Work Change Directives, Field Orders, and written interpretations and clarifications in good order and annotated to show changes made during construction. These record documents together with all approved Samples and a counterpart of all approved Shop Drawings will be available to Engineer for reference. Upon completion of the Work, these record documents, Samples, and Shop Drawings will be delivered to Engineer for Owner.

6.13 *Safety and Protection*

- A. Contractor shall be solely responsible for initiating, maintaining and supervising all safety precautions and programs in connection with the Work. Such responsibility does not relieve Subcontractors of their responsibility for the safety of persons or property in the performance of their work, nor for compliance with applicable safety Laws and Regulations. Contractor shall take all necessary precautions for the safety of, and shall provide the necessary protection to prevent damage, injury or loss to:
 - 1. all persons on the Site or who may be affected by the Work;
 - 2. all the Work and materials and equipment to be incorporated therein, whether in storage on or off the Site; and
 - 3. other property at the Site or adjacent thereto, including trees, shrubs, lawns, walks, pavements, roadways, structures, utilities, and Underground Facilities not designated for removal, relocation, or replacement in the course of construction.
- B. Contractor shall comply with all applicable Laws and Regulations relating to the safety of persons or property, or to the protection of persons or property from damage, injury, or loss; and

shall erect and maintain all necessary safeguards for such safety and protection. Contractor shall notify owners of adjacent property and of Underground Facilities and other utility owners when prosecution of the Work may affect them, and shall cooperate with them in the protection, removal, relocation, and replacement of their property.

- C. Contractor shall comply with the applicable requirements of Owner's safety programs, if any. The Supplementary Conditions identify any Owner's safety programs that are applicable to the Work.
- D. Contractor shall inform Owner and Engineer of the specific requirements of Contractor's safety program with which Owner's and Engineer's employees and representatives must comply while at the Site.
- E. All damage, injury, or loss to any property referred to in Paragraph 6.13.A.2 or 6.13.A.3 caused, directly or indirectly, in whole or in part, by Contractor, any Subcontractor, Supplier, or any other individual or entity directly or indirectly employed by any of them to perform any of the Work, or anyone for whose acts any of them may be liable, shall be remedied by Contractor (except damage or loss attributable to the fault of Drawings or Specifications or to the acts or omissions of Owner or Engineer or anyone employed by any of them, or anyone for whose acts any of them may be liable, and not attributable, directly or indirectly, in whole or in part, to the fault or negligence of Contractor or any Subcontractor, Supplier, or other individual or entity directly or indirectly employed by any of them).
- F. Contractor's duties and responsibilities for safety and for protection of the Work shall continue until such time as all the Work is completed and Engineer has issued a notice to Owner and Contractor in accordance with Paragraph 14.07.B that the Work is acceptable (except as otherwise expressly provided in connection with Substantial Completion).

6.14 *Safety Representative*

- A. Contractor shall designate a qualified and experienced safety representative at the Site whose duties and responsibilities shall be the prevention of accidents and the maintaining and supervising of safety precautions and programs.

6.15 *Hazard Communication Programs*

- A. Contractor shall be responsible for coordinating any exchange of material safety data sheets or other hazard communication information required to be made available to or exchanged between or among employers at the Site in accordance with Laws or Regulations.

6.16 *Emergencies*

- A. In emergencies affecting the safety or protection of persons or the Work or property at the Site or adjacent thereto, Contractor is obligated to act to prevent threatened damage, injury, or loss. Contractor shall give Engineer prompt written notice if Contractor believes that any significant changes in the Work or variations from the Contract Documents have been caused thereby or are required as a result thereof. If Engineer determines that a change in the Contract Documents is

required because of the action taken by Contractor in response to such an emergency, a Work Change Directive or Change Order will be issued.

6.17 *Shop Drawings and Samples*

A. Contractor shall submit Shop Drawings and Samples to Engineer for review and approval in accordance with the accepted Schedule of Submittals (as required by Paragraph 2.07). Each submittal will be identified as Engineer may require.

1. *Shop Drawings:*

- a. Submit number of copies specified in the General Requirements.
- b. Data shown on the Shop Drawings will be complete with respect to quantities, dimensions, specified performance and design criteria, materials, and similar data to show Engineer the services, materials, and equipment Contractor proposes to provide and to enable Engineer to review the information for the limited purposes required by Paragraph 6.17.D.

2. *Samples:*

- a. Submit number of Samples specified in the Specifications.
- b. Clearly identify each Sample as to material, Supplier, pertinent data such as catalog numbers, the use for which intended and other data as Engineer may require to enable Engineer to review the submittal for the limited purposes required by Paragraph 6.17.D.

B. Where a Shop Drawing or Sample is required by the Contract Documents or the Schedule of Submittals, any related Work performed prior to Engineer's review and approval of the pertinent submittal will be at the sole expense and responsibility of Contractor.

C. *Submittal Procedures:*

1. Before submitting each Shop Drawing or Sample, Contractor shall have:

- a. reviewed and coordinated each Shop Drawing or Sample with other Shop Drawings and Samples and with the requirements of the Work and the Contract Documents;
- b. determined and verified all field measurements, quantities, dimensions, specified performance and design criteria, installation requirements, materials, catalog numbers, and similar information with respect thereto;
- c. determined and verified the suitability of all materials offered with respect to the indicated application, fabrication, shipping, handling, storage, assembly, and installation pertaining to the performance of the Work; and
- d. determined and verified all information relative to Contractor's responsibilities for means, methods, techniques, sequences, and procedures of construction, and safety precautions and programs incident thereto.

2. Each submittal shall bear a stamp or specific written certification that Contractor has satisfied Contractor's obligations under the Contract Documents with respect to Contractor's review and approval of that submittal.
3. With each submittal, Contractor shall give Engineer specific written notice of any variations that the Shop Drawing or Sample may have from the requirements of the Contract Documents. This notice shall be both a written communication separate from the Shop Drawings or Sample submittal; and, in addition, by a specific notation made on each Shop Drawing or Sample submitted to Engineer for review and approval of each such variation.

D. *Engineer's Review:*

1. Engineer will provide timely review of Shop Drawings and Samples in accordance with the Schedule of Submittals acceptable to Engineer. Engineer's review and approval will be only to determine if the items covered by the submittals will, after installation or incorporation in the Work, conform to the information given in the Contract Documents and be compatible with the design concept of the completed Project as a functioning whole as indicated by the Contract Documents.
2. Engineer's review and approval will not extend to means, methods, techniques, sequences, or procedures of construction (except where a particular means, method, technique, sequence, or procedure of construction is specifically and expressly called for by the Contract Documents) or to safety precautions or programs incident thereto. The review and approval of a separate item as such will not indicate approval of the assembly in which the item functions.
3. Engineer's review and approval shall not relieve Contractor from responsibility for any variation from the requirements of the Contract Documents unless Contractor has complied with the requirements of Paragraph 6.17.C.3 and Engineer has given written approval of each such variation by specific written notation thereof incorporated in or accompanying the Shop Drawing or Sample. Engineer's review and approval shall not relieve Contractor from responsibility for complying with the requirements of Paragraph 6.17.C.1.

E. *Resubmittal Procedures:*

1. Contractor shall make corrections required by Engineer and shall return the required number of corrected copies of Shop Drawings and submit, as required, new Samples for review and approval. Contractor shall direct specific attention in writing to revisions other than the corrections called for by Engineer on previous submittals.

6.18 *Continuing the Work*

- A. Contractor shall carry on the Work and adhere to the Progress Schedule during all disputes or disagreements with Owner. No Work shall be delayed or postponed pending resolution of any disputes or disagreements, except as permitted by Paragraph 15.04 or as Owner and Contractor may otherwise agree in writing.

6.19 *Contractor's General Warranty and Guarantee*

- A. Contractor warrants and guarantees to Owner that all Work will be in accordance with the Contract Documents and will not be defective. Engineer and its officers, directors, members, partners, employees, agents, consultants, and subcontractors shall be entitled to rely on representation of Contractor's warranty and guarantee.
- B. Contractor's warranty and guarantee hereunder excludes defects or damage caused by:
 - 1. abuse, modification, or improper maintenance or operation by persons other than Contractor, Subcontractors, Suppliers, or any other individual or entity for whom Contractor is responsible; or
 - 2. normal wear and tear under normal usage.
- C. Contractor's obligation to perform and complete the Work in accordance with the Contract Documents shall be absolute. None of the following will constitute an acceptance of Work that is not in accordance with the Contract Documents or a release of Contractor's obligation to perform the Work in accordance with the Contract Documents:
 - 1. observations by Engineer;
 - 2. recommendation by Engineer or payment by Owner of any progress or final payment;
 - 3. the issuance of a certificate of Substantial Completion by Engineer or any payment related thereto by Owner;
 - 4. use or occupancy of the Work or any part thereof by Owner;
 - 5. any review and approval of a Shop Drawing or Sample submittal or the issuance of a notice of acceptability by Engineer;
 - 6. any inspection, test, or approval by others; or
 - 7. any correction of defective Work by Owner.

6.20 *Indemnification*

- A. To the fullest extent permitted by Laws and Regulations, Contractor shall indemnify and hold harmless Owner and Engineer, and the officers, directors, members, partners, employees, agents, consultants and subcontractors of each and any of them from and against all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to the performance of the Work, provided that any such claim, cost, loss, or damage is attributable to bodily injury, sickness, disease, or death, or to injury to or destruction of tangible property (other than the Work itself), including the loss of use resulting therefrom but only to the extent caused by any negligent act or omission of Contractor, any Subcontractor, any Supplier, or any individual or entity directly or indirectly employed by any of them to perform any of the Work or anyone for whose acts any of them may be liable .

- B. In any and all claims against Owner or Engineer or any of their officers, directors, members, partners, employees, agents, consultants, or subcontractors by any employee (or the survivor or personal representative of such employee) of Contractor, any Subcontractor, any Supplier, or any individual or entity directly or indirectly employed by any of them to perform any of the Work, or anyone for whose acts any of them may be liable, the indemnification obligation under Paragraph 6.20.A shall not be limited in any way by any limitation on the amount or type of damages, compensation, or benefits payable by or for Contractor or any such Subcontractor, Supplier, or other individual or entity under workers' compensation acts, disability benefit acts, or other employee benefit acts.
- C. The indemnification obligations of Contractor under Paragraph 6.20.A shall not extend to the liability of Engineer and Engineer's officers, directors, members, partners, employees, agents, consultants and subcontractors arising out of:
 - 1. the preparation or approval of, or the failure to prepare or approve maps, Drawings, opinions, reports, surveys, Change Orders, designs, or Specifications; or
 - 2. giving directions or instructions, or failing to give them, if that is the primary cause of the injury or damage.

6.21 *Delegation of Professional Design Services*

- A. Contractor will not be required to provide professional design services unless such services are specifically required by the Contract Documents for a portion of the Work or unless such services are required to carry out Contractor's responsibilities for construction means, methods, techniques, sequences and procedures. Contractor shall not be required to provide professional services in violation of applicable law.
- B. If professional design services or certifications by a design professional related to systems, materials or equipment are specifically required of Contractor by the Contract Documents, Owner and Engineer will specify all performance and design criteria that such services must satisfy. Contractor shall cause such services or certifications to be provided by a properly licensed professional, whose signature and seal shall appear on all drawings, calculations, specifications, certifications, Shop Drawings and other submittals prepared by such professional. Shop Drawings and other submittals related to the Work designed or certified by such professional, if prepared by others, shall bear such professional's written approval when submitted to Engineer.
- C. Owner and Engineer shall be entitled to rely upon the adequacy, accuracy and completeness of the services, certifications or approvals performed by such design professionals, provided Owner and Engineer have specified to Contractor all performance and design criteria that such services must satisfy.
- D. Pursuant to this Paragraph 6.21, Engineer's review and approval of design calculations and design drawings will be only for the limited purpose of checking for conformance with performance and design criteria given and the design concept expressed in the Contract Documents. Engineer's review and approval of Shop Drawings and other submittals (except design calculations and design drawings) will be only for the purpose stated in Paragraph 6.17.D.1.

- E. Contractor shall not be responsible for the adequacy of the performance or design criteria required by the Contract Documents.

ARTICLE 7 – OTHER WORK AT THE SITE

7.01 Related Work at Site

- A. Owner may perform other work related to the Project at the Site with Owner's employees, or through other direct contracts therefor, or have other work performed by utility owners. If such other work is not noted in the Contract Documents, then:
 - 1. written notice thereof will be given to Contractor prior to starting any such other work; and
 - 2. if Owner and Contractor are unable to agree on entitlement to or on the amount or extent, if any, of any adjustment in the Contract Price or Contract Times that should be allowed as a result of such other work, a Claim may be made therefor as provided in Paragraph 10.05.
- B. Contractor shall afford each other contractor who is a party to such a direct contract, each utility owner, and Owner, if Owner is performing other work with Owner's employees, proper and safe access to the Site, provide a reasonable opportunity for the introduction and storage of materials and equipment and the execution of such other work, and properly coordinate the Work with theirs. Contractor shall do all cutting, fitting, and patching of the Work that may be required to properly connect or otherwise make its several parts come together and properly integrate with such other work. Contractor shall not endanger any work of others by cutting, excavating, or otherwise altering such work; provided, however, that Contractor may cut or alter others' work with the written consent of Engineer and the others whose work will be affected. The duties and responsibilities of Contractor under this Paragraph are for the benefit of such utility owners and other contractors to the extent that there are comparable provisions for the benefit of Contractor in said direct contracts between Owner and such utility owners and other contractors.
- C. If the proper execution or results of any part of Contractor's Work depends upon work performed by others under this Article 7, Contractor shall inspect such other work and promptly report to Engineer in writing any delays, defects, or deficiencies in such other work that render it unavailable or unsuitable for the proper execution and results of Contractor's Work. Contractor's failure to so report will constitute an acceptance of such other work as fit and proper for integration with Contractor's Work except for latent defects and deficiencies in such other work.

7.02 Coordination

- A. If Owner intends to contract with others for the performance of other work on the Project at the Site, the following will be set forth in Supplementary Conditions:
 - 1. the individual or entity who will have authority and responsibility for coordination of the activities among the various contractors will be identified;
 - 2. the specific matters to be covered by such authority and responsibility will be itemized; and
 - 3. the extent of such authority and responsibilities will be provided.

- B. Unless otherwise provided in the Supplementary Conditions, Owner shall have sole authority and responsibility for such coordination.

7.03 *Legal Relationships*

- A. Paragraphs 7.01.A and 7.02 are not applicable for utilities not under the control of Owner.
- B. Each other direct contract of Owner under Paragraph 7.01.A shall provide that the other contractor is liable to Owner and Contractor for the reasonable direct delay and disruption costs incurred by Contractor as a result of the other contractor's wrongful actions or inactions.
- C. Contractor shall be liable to Owner and any other contractor under direct contract to Owner for the reasonable direct delay and disruption costs incurred by such other contractor as a result of Contractor's wrongful action or inactions.

ARTICLE 8 – OWNER'S RESPONSIBILITIES

8.01 *Communications to Contractor*

- A. Except as otherwise provided in these General Conditions, Owner shall issue all communications to Contractor through Engineer.

8.02 *Replacement of Engineer*

- A. In case of termination of the employment of Engineer, Owner shall appoint an engineer to whom Contractor makes no reasonable objection, whose status under the Contract Documents shall be that of the former Engineer.

8.03 *Furnish Data*

- A. Owner shall promptly furnish the data required of Owner under the Contract Documents.

8.04 *Pay When Due*

- A. Owner shall make payments to Contractor when they are due as provided in Paragraphs 14.02.C and 14.07.C.

8.05 *Lands and Easements; Reports and Tests*

- A. Owner's duties with respect to providing lands and easements and providing engineering surveys to establish reference points are set forth in Paragraphs 4.01 and 4.05. Paragraph 4.02 refers to Owner's identifying and making available to Contractor copies of reports of explorations and tests of subsurface conditions and drawings of physical conditions relating to existing surface or subsurface structures at the Site.

8.06 *Insurance*

- A. Owner's responsibilities, if any, with respect to purchasing and maintaining liability and property insurance are set forth in Article 5.

8.07 *Change Orders*

A. Owner is obligated to execute Change Orders as indicated in Paragraph 10.03.

8.08 *Inspections, Tests, and Approvals*

A. Owner's responsibility with respect to certain inspections, tests, and approvals is set forth in Paragraph 13.03.B.

8.09 *Limitations on Owner's Responsibilities*

A. The Owner shall not supervise, direct, or have control or authority over, nor be responsible for, Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work. Owner will not be responsible for Contractor's failure to perform the Work in accordance with the Contract Documents.

8.10 *Undisclosed Hazardous Environmental Condition*

A. Owner's responsibility in respect to an undisclosed Hazardous Environmental Condition is set forth in Paragraph 4.06.

8.11 *Evidence of Financial Arrangements*

A. Upon request of Contractor, Owner shall furnish Contractor reasonable evidence that financial arrangements have been made to satisfy Owner's obligations under the Contract Documents.

8.12 *Compliance with Safety Program*

A. While at the Site, Owner's employees and representatives shall comply with the specific applicable requirements of Contractor's safety programs of which Owner has been informed pursuant to Paragraph 6.13.D.

ARTICLE 9 – ENGINEER'S STATUS DURING CONSTRUCTION

9.01 *Owner's Representative*

A. Engineer will be Owner's representative during the construction period. The duties and responsibilities and the limitations of authority of Engineer as Owner's representative during construction are set forth in the Contract Documents.

9.02 *Visits to Site*

A. Engineer will make visits to the Site at intervals appropriate to the various stages of construction as Engineer deems necessary in order to observe as an experienced and qualified design professional the progress that has been made and the quality of the various aspects of Contractor's executed Work. Based on information obtained during such visits and observations, Engineer, for the benefit of Owner, will determine, in general, if the Work is proceeding in accordance with the Contract Documents. Engineer will not be required to make exhaustive or

continuous inspections on the Site to check the quality or quantity of the Work. Engineer's efforts will be directed toward providing for Owner a greater degree of confidence that the completed Work will conform generally to the Contract Documents. On the basis of such visits and observations, Engineer will keep Owner informed of the progress of the Work and will endeavor to guard Owner against defective Work.

- B. Engineer's visits and observations are subject to all the limitations on Engineer's authority and responsibility set forth in Paragraph 9.09. Particularly, but without limitation, during or as a result of Engineer's visits or observations of Contractor's Work, Engineer will not supervise, direct, control, or have authority over or be responsible for Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work.

9.03 *Project Representative*

- A. If Owner and Engineer agree, Engineer will furnish a Resident Project Representative to assist Engineer in providing more extensive observation of the Work. The authority and responsibilities of any such Resident Project Representative and assistants will be as provided in the Supplementary Conditions, and limitations on the responsibilities thereof will be as provided in Paragraph 9.09. If Owner designates another representative or agent to represent Owner at the Site who is not Engineer's consultant, agent or employee, the responsibilities and authority and limitations thereon of such other individual or entity will be as provided in the Supplementary Conditions.

9.04 *Authorized Variations in Work*

- A. Engineer may authorize minor variations in the Work from the requirements of the Contract Documents which do not involve an adjustment in the Contract Price or the Contract Times and are compatible with the design concept of the completed Project as a functioning whole as indicated by the Contract Documents. These may be accomplished by a Field Order and will be binding on Owner and also on Contractor, who shall perform the Work involved promptly. If Owner or Contractor believes that a Field Order justifies an adjustment in the Contract Price or Contract Times, or both, and the parties are unable to agree on entitlement to or on the amount or extent, if any, of any such adjustment, a Claim may be made therefor as provided in Paragraph 10.05.

9.05 *Rejecting Defective Work*

- A. Engineer will have authority to reject Work which Engineer believes to be defective, or that Engineer believes will not produce a completed Project that conforms to the Contract Documents or that will prejudice the integrity of the design concept of the completed Project as a functioning whole as indicated by the Contract Documents. Engineer will also have authority to require special inspection or testing of the Work as provided in Paragraph 13.04, whether or not the Work is fabricated, installed, or completed.

9.06 *Shop Drawings, Change Orders and Payments*

- A. In connection with Engineer's authority, and limitations thereof, as to Shop Drawings and Samples, see Paragraph 6.17.
- B. In connection with Engineer's authority, and limitations thereof, as to design calculations and design drawings submitted in response to a delegation of professional design services, if any, see Paragraph 6.21.
- C. In connection with Engineer's authority as to Change Orders, see Articles 10, 11, and 12.
- D. In connection with Engineer's authority as to Applications for Payment, see Article 14.

9.07 *Determinations for Unit Price Work*

- A. Engineer will determine the actual quantities and classifications of Unit Price Work performed by Contractor. Engineer will review with Contractor the Engineer's preliminary determinations on such matters before rendering a written decision thereon (by recommendation of an Application for Payment or otherwise). Engineer's written decision thereon will be final and binding (except as modified by Engineer to reflect changed factual conditions or more accurate data) upon Owner and Contractor, subject to the provisions of Paragraph 10.05.

9.08 *Decisions on Requirements of Contract Documents and Acceptability of Work*

- A. Engineer will be the initial interpreter of the requirements of the Contract Documents and judge of the acceptability of the Work thereunder. All matters in question and other matters between Owner and Contractor arising prior to the date final payment is due relating to the acceptability of the Work, and the interpretation of the requirements of the Contract Documents pertaining to the performance of the Work, will be referred initially to Engineer in writing within 30 days of the event giving rise to the question.
- B. Engineer will, with reasonable promptness, render a written decision on the issue referred. If Owner or Contractor believes that any such decision entitles them to an adjustment in the Contract Price or Contract Times or both, a Claim may be made under Paragraph 10.05. The date of Engineer's decision shall be the date of the event giving rise to the issues referenced for the purposes of Paragraph 10.05.B.
- C. Engineer's written decision on the issue referred will be final and binding on Owner and Contractor, subject to the provisions of Paragraph 10.05.
- D. When functioning as interpreter and judge under this Paragraph 9.08, Engineer will not show partiality to Owner or Contractor and will not be liable in connection with any interpretation or decision rendered in good faith in such capacity.

9.09 *Limitations on Engineer's Authority and Responsibilities*

- A. Neither Engineer's authority or responsibility under this Article 9 or under any other provision of the Contract Documents nor any decision made by Engineer in good faith either to exercise

or not exercise such authority or responsibility or the undertaking, exercise, or performance of any authority or responsibility by Engineer shall create, impose, or give rise to any duty in contract, tort, or otherwise owed by Engineer to Contractor, any Subcontractor, any Supplier, any other individual or entity, or to any surety for or employee or agent of any of them.

- B. Engineer will not supervise, direct, control, or have authority over or be responsible for Contractor's means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or for any failure of Contractor to comply with Laws and Regulations applicable to the performance of the Work. Engineer will not be responsible for Contractor's failure to perform the Work in accordance with the Contract Documents.
- C. Engineer will not be responsible for the acts or omissions of Contractor or of any Subcontractor, any Supplier, or of any other individual or entity performing any of the Work.
- D. Engineer's review of the final Application for Payment and accompanying documentation and all maintenance and operating instructions, schedules, guarantees, bonds, certificates of inspection, tests and approvals, and other documentation required to be delivered by Paragraph 14.07.A will only be to determine generally that their content complies with the requirements of, and in the case of certificates of inspections, tests, and approvals that the results certified indicate compliance with, the Contract Documents.
- E. The limitations upon authority and responsibility set forth in this Paragraph 9.09 shall also apply to the Resident Project Representative, if any, and assistants, if any.

9.10 *Compliance with Safety Program*

- A. While at the Site, Engineer's employees and representatives shall comply with the specific applicable requirements of Contractor's safety programs of which Engineer has been informed pursuant to Paragraph 6.13.D.

ARTICLE 10 – CHANGES IN THE WORK; CLAIMS

10.01 *Authorized Changes in the Work*

- A. Without invalidating the Contract and without notice to any surety, Owner may, at any time or from time to time, order additions, deletions, or revisions in the Work by a Change Order, or a Work Change Directive. Upon receipt of any such document, Contractor shall promptly proceed with the Work involved which will be performed under the applicable conditions of the Contract Documents (except as otherwise specifically provided).
- B. If Owner and Contractor are unable to agree on entitlement to, or on the amount or extent, if any, of an adjustment in the Contract Price or Contract Times, or both, that should be allowed as a result of a Work Change Directive, a Claim may be made therefor as provided in Paragraph 10.05.

10.02 *Unauthorized Changes in the Work*

- A. Contractor shall not be entitled to an increase in the Contract Price or an extension of the Contract Times with respect to any work performed that is not required by the Contract Documents as amended, modified, or supplemented as provided in Paragraph 3.04, except in the case of an emergency as provided in Paragraph 6.16 or in the case of uncovering Work as provided in Paragraph 13.04.D.

10.03 *Execution of Change Orders*

- A. Owner and Contractor shall execute appropriate Change Orders recommended by Engineer covering:
 - 1. changes in the Work which are: (i) ordered by Owner pursuant to Paragraph 10.01.A, (ii) required because of acceptance of defective Work under Paragraph 13.08.A or Owner's correction of defective Work under Paragraph 13.09, or (iii) agreed to by the parties;
 - 2. changes in the Contract Price or Contract Times which are agreed to by the parties, including any undisputed sum or amount of time for Work actually performed in accordance with a Work Change Directive; and
 - 3. changes in the Contract Price or Contract Times which embody the substance of any written decision rendered by Engineer pursuant to Paragraph 10.05; provided that, in lieu of executing any such Change Order, an appeal may be taken from any such decision in accordance with the provisions of the Contract Documents and applicable Laws and Regulations, but during any such appeal, Contractor shall carry on the Work and adhere to the Progress Schedule as provided in Paragraph 6.18.A.

10.04 *Notification to Surety*

- A. If the provisions of any bond require notice to be given to a surety of any change affecting the general scope of the Work or the provisions of the Contract Documents (including, but not limited to, Contract Price or Contract Times), the giving of any such notice will be Contractor's responsibility. The amount of each applicable bond will be adjusted to reflect the effect of any such change.

10.05 *Claims*

- A. *Engineer's Decision Required:* All Claims, except those waived pursuant to Paragraph 14.09, shall be referred to the Engineer for decision. A decision by Engineer shall be required as a condition precedent to any exercise by Owner or Contractor of any rights or remedies either may otherwise have under the Contract Documents or by Laws and Regulations in respect of such Claims.
- B. *Notice:* Written notice stating the general nature of each Claim shall be delivered by the claimant to Engineer and the other party to the Contract promptly (but in no event later than 30 days) after the start of the event giving rise thereto. The responsibility to substantiate a Claim shall rest with the party making the Claim. Notice of the amount or extent of the Claim, with supporting data

shall be delivered to the Engineer and the other party to the Contract within 60 days after the start of such event (unless Engineer allows additional time for claimant to submit additional or more accurate data in support of such Claim). A Claim for an adjustment in Contract Price shall be prepared in accordance with the provisions of Paragraph 12.01.B. A Claim for an adjustment in Contract Times shall be prepared in accordance with the provisions of Paragraph 12.02.B. Each Claim shall be accompanied by claimant's written statement that the adjustment claimed is the entire adjustment to which the claimant believes it is entitled as a result of said event. The opposing party shall submit any response to Engineer and the claimant within 30 days after receipt of the claimant's last submittal (unless Engineer allows additional time).

- C. *Engineer's Action:* Engineer will review each Claim and, within 30 days after receipt of the last submittal of the claimant or the last submittal of the opposing party, if any, take one of the following actions in writing:
1. deny the Claim in whole or in part;
 2. approve the Claim; or
 3. notify the parties that the Engineer is unable to resolve the Claim if, in the Engineer's sole discretion, it would be inappropriate for the Engineer to do so. For purposes of further resolution of the Claim, such notice shall be deemed a denial.
- D. In the event that Engineer does not take action on a Claim within said 30 days, the Claim shall be deemed denied.
- E. Engineer's written action under Paragraph 10.05.C or denial pursuant to Paragraphs 10.05.C.3 or 10.05.D will be final and binding upon Owner and Contractor, unless Owner or Contractor invoke the dispute resolution procedure set forth in Article 16 within 30 days of such action or denial.
- F. No Claim for an adjustment in Contract Price or Contract Times will be valid if not submitted in accordance with this Paragraph 10.05.

ARTICLE 11 – COST OF THE WORK; ALLOWANCES; UNIT PRICE WORK

11.01 *Cost of the Work*

- A. *Costs Included:* The term Cost of the Work means the sum of all costs, except those excluded in Paragraph 11.01.B, necessarily incurred and paid by Contractor in the proper performance of the Work. When the value of any Work covered by a Change Order or when a Claim for an adjustment in Contract Price is determined on the basis of Cost of the Work, the costs to be reimbursed to Contractor will be only those additional or incremental costs required because of the change in the Work or because of the event giving rise to the Claim. Except as otherwise may be agreed to in writing by Owner, such costs shall be in amounts no higher than those prevailing in the locality of the Project, shall not include any of the costs itemized in Paragraph 11.01.B, and shall include only the following items:

1. Payroll costs for employees in the direct employ of Contractor in the performance of the Work under schedules of job classifications agreed upon by Owner and Contractor. Such employees shall include, without limitation, superintendents, foremen, and other personnel employed full time on the Work. Payroll costs for employees not employed full time on the Work shall be apportioned on the basis of their time spent on the Work. Payroll costs shall include, but not be limited to, salaries and wages plus the cost of fringe benefits, which shall include social security contributions, unemployment, excise, and payroll taxes, workers' compensation, health and retirement benefits, bonuses, sick leave, vacation and holiday pay applicable thereto. The expenses of performing Work outside of regular working hours, on Saturday, Sunday, or legal holidays, shall be included in the above to the extent authorized by Owner.
2. Cost of all materials and equipment furnished and incorporated in the Work, including costs of transportation and storage thereof, and Suppliers' field services required in connection therewith. All cash discounts shall accrue to Contractor unless Owner deposits funds with Contractor with which to make payments, in which case the cash discounts shall accrue to Owner. All trade discounts, rebates and refunds and returns from sale of surplus materials and equipment shall accrue to Owner, and Contractor shall make provisions so that they may be obtained.
3. Payments made by Contractor to Subcontractors for Work performed by Subcontractors. If required by Owner, Contractor shall obtain competitive bids from subcontractors acceptable to Owner and Contractor and shall deliver such bids to Owner, who will then determine, with the advice of Engineer, which bids, if any, will be acceptable. If any subcontract provides that the Subcontractor is to be paid on the basis of Cost of the Work plus a fee, the Subcontractor's Cost of the Work and fee shall be determined in the same manner as Contractor's Cost of the Work and fee as provided in this Paragraph 11.01.
4. Costs of special consultants (including but not limited to engineers, architects, testing laboratories, surveyors, attorneys, and accountants) employed for services specifically related to the Work.
5. Supplemental costs including the following:
 - a. The proportion of necessary transportation, travel, and subsistence expenses of Contractor's employees incurred in discharge of duties connected with the Work.
 - b. Cost, including transportation and maintenance, of all materials, supplies, equipment, machinery, appliances, office, and temporary facilities at the Site, and hand tools not owned by the workers, which are consumed in the performance of the Work, and cost, less market value, of such items used but not consumed which remain the property of Contractor.
 - c. Rentals of all construction equipment and machinery, and the parts thereof whether rented from Contractor or others in accordance with rental agreements approved by Owner with the advice of Engineer, and the costs of transportation, loading, unloading, assembly, dismantling, and removal thereof. All such costs shall be in accordance with the terms of

said rental agreements. The rental of any such equipment, machinery, or parts shall cease when the use thereof is no longer necessary for the Work.

- d. Sales, consumer, use, and other similar taxes related to the Work, and for which Contractor is liable, as imposed by Laws and Regulations.
- e. Deposits lost for causes other than negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, and royalty payments and fees for permits and licenses.
- f. Losses and damages (and related expenses) caused by damage to the Work, not compensated by insurance or otherwise, sustained by Contractor in connection with the performance of the Work (except losses and damages within the deductible amounts of property insurance established in accordance with Paragraph 5.06.D), provided such losses and damages have resulted from causes other than the negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable. Such losses shall include settlements made with the written consent and approval of Owner. No such losses, damages, and expenses shall be included in the Cost of the Work for the purpose of determining Contractor's fee.
- g. The cost of utilities, fuel, and sanitary facilities at the Site.
- h. Minor expenses such as telegrams, long distance telephone calls, telephone service at the Site, express and courier services, and similar petty cash items in connection with the Work.
- i. The costs of premiums for all bonds and insurance Contractor is required by the Contract Documents to purchase and maintain.

B. *Costs Excluded:* The term Cost of the Work shall not include any of the following items:

1. Payroll costs and other compensation of Contractor's officers, executives, principals (of partnerships and sole proprietorships), general managers, safety managers, engineers, architects, estimators, attorneys, auditors, accountants, purchasing and contracting agents, expeditors, timekeepers, clerks, and other personnel employed by Contractor, whether at the Site or in Contractor's principal or branch office for general administration of the Work and not specifically included in the agreed upon schedule of job classifications referred to in Paragraph 11.01.A.1 or specifically covered by Paragraph 11.01.A.4, all of which are to be considered administrative costs covered by the Contractor's fee.
2. Expenses of Contractor's principal and branch offices other than Contractor's office at the Site.
3. Any part of Contractor's capital expenses, including interest on Contractor's capital employed for the Work and charges against Contractor for delinquent payments.
4. Costs due to the negligence of Contractor, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, including but not

limited to, the correction of defective Work, disposal of materials or equipment wrongly supplied, and making good any damage to property.

5. Other overhead or general expense costs of any kind and the costs of any item not specifically and expressly included in Paragraphs 11.01.A.
- C. *Contractor's Fee:* When all the Work is performed on the basis of cost-plus, Contractor's fee shall be determined as set forth in the Agreement. When the value of any Work covered by a Change Order or when a Claim for an adjustment in Contract Price is determined on the basis of Cost of the Work, Contractor's fee shall be determined as set forth in Paragraph 12.01.C.
- D. *Documentation:* Whenever the Cost of the Work for any purpose is to be determined pursuant to Paragraphs 11.01.A and 11.01.B, Contractor will establish and maintain records thereof in accordance with generally accepted accounting practices and submit in a form acceptable to Engineer an itemized cost breakdown together with supporting data.

11.02 *Allowances*

- A. It is understood that Contractor has included in the Contract Price all allowances so named in the Contract Documents and shall cause the Work so covered to be performed for such sums and by such persons or entities as may be acceptable to Owner and Engineer.
- B. *Cash Allowances:*
 1. Contractor agrees that:
 - a. the cash allowances include the cost to Contractor (less any applicable trade discounts) of materials and equipment required by the allowances to be delivered at the Site, and all applicable taxes; and
 - b. Contractor's costs for unloading and handling on the Site, labor, installation, overhead, profit, and other expenses contemplated for the cash allowances have been included in the Contract Price and not in the allowances, and no demand for additional payment on account of any of the foregoing will be valid.
- C. *Contingency Allowance:*
 1. Contractor agrees that a contingency allowance, if any, is for the sole use of Owner to cover unanticipated costs.
- D. Prior to final payment, an appropriate Change Order will be issued as recommended by Engineer to reflect actual amounts due Contractor on account of Work covered by allowances, and the Contract Price shall be correspondingly adjusted.

11.03 *Unit Price Work*

- A. Where the Contract Documents provide that all or part of the Work is to be Unit Price Work, initially the Contract Price will be deemed to include for all Unit Price Work an amount equal to

the sum of the unit price for each separately identified item of Unit Price Work times the estimated quantity of each item as indicated in the Agreement.

- B. The estimated quantities of items of Unit Price Work are not guaranteed and are solely for the purpose of comparison of Bids and determining an initial Contract Price. Determinations of the actual quantities and classifications of Unit Price Work performed by Contractor will be made by Engineer subject to the provisions of Paragraph 9.07.
- C. Each unit price will be deemed to include an amount considered by Contractor to be adequate to cover Contractor's overhead and profit for each separately identified item.
- D. Owner or Contractor may make a Claim for an adjustment in the Contract Price in accordance with Paragraph 10.05 if:
 - 1. the quantity of any item of Unit Price Work performed by Contractor differs materially and significantly from the estimated quantity of such item indicated in the Agreement; and
 - 2. there is no corresponding adjustment with respect to any other item of Work; and
 - 3. Contractor believes that Contractor is entitled to an increase in Contract Price as a result of having incurred additional expense or Owner believes that Owner is entitled to a decrease in Contract Price and the parties are unable to agree as to the amount of any such increase or decrease.

ARTICLE 12 – CHANGE OF CONTRACT PRICE; CHANGE OF CONTRACT TIMES

12.01 *Change of Contract Price*

- A. The Contract Price may only be changed by a Change Order. Any Claim for an adjustment in the Contract Price shall be based on written notice submitted by the party making the Claim to the Engineer and the other party to the Contract in accordance with the provisions of Paragraph 10.05.
- B. The value of any Work covered by a Change Order or of any Claim for an adjustment in the Contract Price will be determined as follows:
 - 1. where the Work involved is covered by unit prices contained in the Contract Documents, by application of such unit prices to the quantities of the items involved (subject to the provisions of Paragraph 11.03); or
 - 2. where the Work involved is not covered by unit prices contained in the Contract Documents, by a mutually agreed lump sum (which may include an allowance for overhead and profit not necessarily in accordance with Paragraph 12.01.C.2); or
 - 3. where the Work involved is not covered by unit prices contained in the Contract Documents and agreement to a lump sum is not reached under Paragraph 12.01.B.2, on the basis of the Cost of the Work (determined as provided in Paragraph 11.01) plus a Contractor's fee for overhead and profit (determined as provided in Paragraph 12.01.C).

C. *Contractor's Fee*: The Contractor's fee for overhead and profit shall be determined as follows:

1. a mutually acceptable fixed fee; or
2. if a fixed fee is not agreed upon, then a fee based on the following percentages of the various portions of the Cost of the Work:
 - a. for costs incurred under Paragraphs 11.01.A.1 and 11.01.A.2, the Contractor's fee shall be 15 percent;
 - b. for costs incurred under Paragraph 11.01.A.3, the Contractor's fee shall be five percent;
 - c. where one or more tiers of subcontracts are on the basis of Cost of the Work plus a fee and no fixed fee is agreed upon, the intent of Paragraphs 12.01.C.2.a and 12.01.C.2.b is that the Subcontractor who actually performs the Work, at whatever tier, will be paid a fee of 15 percent of the costs incurred by such Subcontractor under Paragraphs 11.01.A.1 and 11.01.A.2 and that any higher tier Subcontractor and Contractor will each be paid a fee of five percent of the amount paid to the next lower tier Subcontractor;
 - d. no fee shall be payable on the basis of costs itemized under Paragraphs 11.01.A.4, 11.01.A.5, and 11.01.B;
 - e. the amount of credit to be allowed by Contractor to Owner for any change which results in a net decrease in cost will be the amount of the actual net decrease in cost plus a deduction in Contractor's fee by an amount equal to five percent of such net decrease; and
 - f. when both additions and credits are involved in any one change, the adjustment in Contractor's fee shall be computed on the basis of the net change in accordance with Paragraphs 12.01.C.2.a through 12.01.C.2.e, inclusive.

12.02 *Change of Contract Times*

- A. The Contract Times may only be changed by a Change Order. Any Claim for an adjustment in the Contract Times shall be based on written notice submitted by the party making the Claim to the Engineer and the other party to the Contract in accordance with the provisions of Paragraph 10.05.
- B. Any adjustment of the Contract Times covered by a Change Order or any Claim for an adjustment in the Contract Times will be determined in accordance with the provisions of this Article 12.

12.03 *Delays*

- A. Where Contractor is prevented from completing any part of the Work within the Contract Times due to delay beyond the control of Contractor, the Contract Times will be extended in an amount equal to the time lost due to such delay if a Claim is made therefor as provided in Paragraph 12.02.A. Delays beyond the control of Contractor shall include, but not be limited to, acts or

neglect by Owner, acts or neglect of utility owners or other contractors performing other work as contemplated by Article 7, fires, floods, epidemics, abnormal weather conditions, or acts of God.

- B. If Owner, Engineer, or other contractors or utility owners performing other work for Owner as contemplated by Article 7, or anyone for whom Owner is responsible, delays, disrupts, or interferes with the performance or progress of the Work, then Contractor shall be entitled to an equitable adjustment in the Contract Price or the Contract Times, or both. Contractor's entitlement to an adjustment of the Contract Times is conditioned on such adjustment being essential to Contractor's ability to complete the Work within the Contract Times.
- C. If Contractor is delayed in the performance or progress of the Work by fire, flood, epidemic, abnormal weather conditions, acts of God, acts or failures to act of utility owners not under the control of Owner, or other causes not the fault of and beyond control of Owner and Contractor, then Contractor shall be entitled to an equitable adjustment in Contract Times, if such adjustment is essential to Contractor's ability to complete the Work within the Contract Times. Such an adjustment shall be Contractor's sole and exclusive remedy for the delays described in this Paragraph 12.03.C.
- D. Owner, Engineer, and their officers, directors, members, partners, employees, agents, consultants, or subcontractors shall not be liable to Contractor for any claims, costs, losses, or damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Contractor on or in connection with any other project or anticipated project.
- E. Contractor shall not be entitled to an adjustment in Contract Price or Contract Times for delays within the control of Contractor. Delays attributable to and within the control of a Subcontractor or Supplier shall be deemed to be delays within the control of Contractor.

ARTICLE 13 – TESTS AND INSPECTIONS; CORRECTION, REMOVAL OR ACCEPTANCE OF DEFECTIVE WORK

13.01 Notice of Defects

- A. Prompt notice of all defective Work of which Owner or Engineer has actual knowledge will be given to Contractor. Defective Work may be rejected, corrected, or accepted as provided in this Article 13.

13.02 Access to Work

- A. Owner, Engineer, their consultants and other representatives and personnel of Owner, independent testing laboratories, and governmental agencies with jurisdictional interests will have access to the Site and the Work at reasonable times for their observation, inspection, and testing. Contractor shall provide them proper and safe conditions for such access and advise them of Contractor's safety procedures and programs so that they may comply therewith as applicable.

13.03 *Tests and Inspections*

- A. Contractor shall give Engineer timely notice of readiness of the Work for all required inspections, tests, or approvals and shall cooperate with inspection and testing personnel to facilitate required inspections or tests.
- B. Owner shall employ and pay for the services of an independent testing laboratory to perform all inspections, tests, or approvals required by the Contract Documents except:
 - 1. for inspections, tests, or approvals covered by Paragraphs 13.03.C and 13.03.D below;
 - 2. that costs incurred in connection with tests or inspections conducted pursuant to Paragraph 13.04.B shall be paid as provided in Paragraph 13.04.C; and
 - 3. as otherwise specifically provided in the Contract Documents.
- C. If Laws or Regulations of any public body having jurisdiction require any Work (or part thereof) specifically to be inspected, tested, or approved by an employee or other representative of such public body, Contractor shall assume full responsibility for arranging and obtaining such inspections, tests, or approvals, pay all costs in connection therewith, and furnish Engineer the required certificates of inspection or approval.
- D. Contractor shall be responsible for arranging and obtaining and shall pay all costs in connection with any inspections, tests, or approvals required for Owner's and Engineer's acceptance of materials or equipment to be incorporated in the Work; or acceptance of materials, mix designs, or equipment submitted for approval prior to Contractor's purchase thereof for incorporation in the Work. Such inspections, tests, or approvals shall be performed by organizations acceptable to Owner and Engineer.
- E. If any Work (or the work of others) that is to be inspected, tested, or approved is covered by Contractor without written concurrence of Engineer, Contractor shall, if requested by Engineer, uncover such Work for observation.
- F. Uncovering Work as provided in Paragraph 13.03.E shall be at Contractor's expense unless Contractor has given Engineer timely notice of Contractor's intention to cover the same and Engineer has not acted with reasonable promptness in response to such notice.

13.04 *Uncovering Work*

- A. If any Work is covered contrary to the written request of Engineer, it must, if requested by Engineer, be uncovered for Engineer's observation and replaced at Contractor's expense.
- B. If Engineer considers it necessary or advisable that covered Work be observed by Engineer or inspected or tested by others, Contractor, at Engineer's request, shall uncover, expose, or otherwise make available for observation, inspection, or testing as Engineer may require, that portion of the Work in question, furnishing all necessary labor, material, and equipment.

- C. If it is found that the uncovered Work is defective, Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such uncovering, exposure, observation, inspection, and testing, and of satisfactory replacement or reconstruction (including but not limited to all costs of repair or replacement of work of others); and Owner shall be entitled to an appropriate decrease in the Contract Price. If the parties are unable to agree as to the amount thereof, Owner may make a Claim therefor as provided in Paragraph 10.05.
- D. If the uncovered Work is not found to be defective, Contractor shall be allowed an increase in the Contract Price or an extension of the Contract Times, or both, directly attributable to such uncovering, exposure, observation, inspection, testing, replacement, and reconstruction. If the parties are unable to agree as to the amount or extent thereof, Contractor may make a Claim therefor as provided in Paragraph 10.05.

13.05 *Owner May Stop the Work*

- A. If the Work is defective, or Contractor fails to supply sufficient skilled workers or suitable materials or equipment, or fails to perform the Work in such a way that the completed Work will conform to the Contract Documents, Owner may order Contractor to stop the Work, or any portion thereof, until the cause for such order has been eliminated; however, this right of Owner to stop the Work shall not give rise to any duty on the part of Owner to exercise this right for the benefit of Contractor, any Subcontractor, any Supplier, any other individual or entity, or any surety for, or employee or agent of any of them.

13.06 *Correction or Removal of Defective Work*

- A. Promptly after receipt of written notice, Contractor shall correct all defective Work, whether or not fabricated, installed, or completed, or, if the Work has been rejected by Engineer, remove it from the Project and replace it with Work that is not defective. Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such correction or removal (including but not limited to all costs of repair or replacement of work of others).
- B. When correcting defective Work under the terms of this Paragraph 13.06 or Paragraph 13.07, Contractor shall take no action that would void or otherwise impair Owner's special warranty and guarantee, if any, on said Work.

13.07 *Correction Period*

- A. If within one year after the date of Substantial Completion (or such longer period of time as may be prescribed by the terms of any applicable special guarantee required by the Contract Documents) or by any specific provision of the Contract Documents, any Work is found to be defective, or if the repair of any damages to the land or areas made available for Contractor's use by Owner or permitted by Laws and Regulations as contemplated in Paragraph 6.11.A is found to be defective, Contractor shall promptly, without cost to Owner and in accordance with Owner's written instructions:

1. repair such defective land or areas; or
 2. correct such defective Work; or
 3. if the defective Work has been rejected by Owner, remove it from the Project and replace it with Work that is not defective, and
 4. satisfactorily correct or repair or remove and replace any damage to other Work, to the work of others or other land or areas resulting therefrom.
- B. If Contractor does not promptly comply with the terms of Owner's written instructions, or in an emergency where delay would cause serious risk of loss or damage, Owner may have the defective Work corrected or repaired or may have the rejected Work removed and replaced. All claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out of or relating to such correction or repair or such removal and replacement (including but not limited to all costs of repair or replacement of work of others) will be paid by Contractor.
- C. In special circumstances where a particular item of equipment is placed in continuous service before Substantial Completion of all the Work, the correction period for that item may start to run from an earlier date if so provided in the Specifications.
- D. Where defective Work (and damage to other Work resulting therefrom) has been corrected or removed and replaced under this Paragraph 13.07, the correction period hereunder with respect to such Work will be extended for an additional period of one year after such correction or removal and replacement has been satisfactorily completed.
- E. Contractor's obligations under this Paragraph 13.07 are in addition to any other obligation or warranty. The provisions of this Paragraph 13.07 shall not be construed as a substitute for, or a waiver of, the provisions of any applicable statute of limitation or repose.

13.08 *Acceptance of Defective Work*

- A. If, instead of requiring correction or removal and replacement of defective Work, Owner (and, prior to Engineer's recommendation of final payment, Engineer) prefers to accept it, Owner may do so. Contractor shall pay all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) attributable to Owner's evaluation of and determination to accept such defective Work (such costs to be approved by Engineer as to reasonableness) and for the diminished value of the Work to the extent not otherwise paid by Contractor pursuant to this sentence. If any such acceptance occurs prior to Engineer's recommendation of final payment, a Change Order will be issued incorporating the necessary revisions in the Contract Documents with respect to the Work, and Owner shall be entitled to an appropriate decrease in the Contract Price, reflecting the diminished value of Work so accepted. If the parties are unable to agree as to the amount thereof, Owner may make a Claim therefor as provided in Paragraph 10.05. If the acceptance occurs after such recommendation, an appropriate amount will be paid by Contractor to Owner.

13.09 *Owner May Correct Defective Work*

- A. If Contractor fails within a reasonable time after written notice from Engineer to correct defective Work, or to remove and replace rejected Work as required by Engineer in accordance with Paragraph 13.06.A, or if Contractor fails to perform the Work in accordance with the Contract Documents, or if Contractor fails to comply with any other provision of the Contract Documents, Owner may, after seven days written notice to Contractor, correct, or remedy any such deficiency.
- B. In exercising the rights and remedies under this Paragraph 13.09, Owner shall proceed expeditiously. In connection with such corrective or remedial action, Owner may exclude Contractor from all or part of the Site, take possession of all or part of the Work and suspend Contractor's services related thereto, take possession of Contractor's tools, appliances, construction equipment and machinery at the Site, and incorporate in the Work all materials and equipment stored at the Site or for which Owner has paid Contractor but which are stored elsewhere. Contractor shall allow Owner, Owner's representatives, agents and employees, Owner's other contractors, and Engineer and Engineer's consultants access to the Site to enable Owner to exercise the rights and remedies under this Paragraph.
- C. All claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) incurred or sustained by Owner in exercising the rights and remedies under this Paragraph 13.09 will be charged against Contractor, and a Change Order will be issued incorporating the necessary revisions in the Contract Documents with respect to the Work; and Owner shall be entitled to an appropriate decrease in the Contract Price. If the parties are unable to agree as to the amount of the adjustment, Owner may make a Claim therefor as provided in Paragraph 10.05. Such claims, costs, losses and damages will include but not be limited to all costs of repair, or replacement of work of others destroyed or damaged by correction, removal, or replacement of Contractor's defective Work.
- D. Contractor shall not be allowed an extension of the Contract Times because of any delay in the performance of the Work attributable to the exercise by Owner of Owner's rights and remedies under this Paragraph 13.09.

ARTICLE 14 – PAYMENTS TO CONTRACTOR AND COMPLETION

14.01 *Schedule of Values*

- A. The Schedule of Values established as provided in Paragraph 2.07.A will serve as the basis for progress payments and will be incorporated into a form of Application for Payment acceptable to Engineer. Progress payments on account of Unit Price Work will be based on the number of units completed.

14.02 *Progress Payments*

A. *Applications for Payments:*

- 1. At least 20 days before the date established in the Agreement for each progress payment (but not more often than once a month), Contractor shall submit to Engineer for review an

Application for Payment filled out and signed by Contractor covering the Work completed as of the date of the Application and accompanied by such supporting documentation as is required by the Contract Documents. If payment is requested on the basis of materials and equipment not incorporated in the Work but delivered and suitably stored at the Site or at another location agreed to in writing, the Application for Payment shall also be accompanied by a bill of sale, invoice, or other documentation warranting that Owner has received the materials and equipment free and clear of all Liens and evidence that the materials and equipment are covered by appropriate property insurance or other arrangements to protect Owner's interest therein, all of which must be satisfactory to Owner.

2. Beginning with the second Application for Payment, each Application shall include an affidavit of Contractor stating that all previous progress payments received on account of the Work have been applied on account to discharge Contractor's legitimate obligations associated with prior Applications for Payment.
3. The amount of retainage with respect to progress payments will be as stipulated in the Agreement.

B. *Review of Applications:*

1. Engineer will, within 10 days after receipt of each Application for Payment, either indicate in writing a recommendation of payment and present the Application to Owner or return the Application to Contractor indicating in writing Engineer's reasons for refusing to recommend payment. In the latter case, Contractor may make the necessary corrections and resubmit the Application.
2. Engineer's recommendation of any payment requested in an Application for Payment will constitute a representation by Engineer to Owner, based on Engineer's observations of the executed Work as an experienced and qualified design professional, and on Engineer's review of the Application for Payment and the accompanying data and schedules, that to the best of Engineer's knowledge, information and belief:
 - a. the Work has progressed to the point indicated;
 - b. the quality of the Work is generally in accordance with the Contract Documents (subject to an evaluation of the Work as a functioning whole prior to or upon Substantial Completion, the results of any subsequent tests called for in the Contract Documents, a final determination of quantities and classifications for Unit Price Work under Paragraph 9.07, and any other qualifications stated in the recommendation); and
 - c. the conditions precedent to Contractor's being entitled to such payment appear to have been fulfilled in so far as it is Engineer's responsibility to observe the Work.
3. By recommending any such payment Engineer will not thereby be deemed to have represented that:
 - a. inspections made to check the quality or the quantity of the Work as it has been performed have been exhaustive, extended to every aspect of the Work in progress, or

- involved detailed inspections of the Work beyond the responsibilities specifically assigned to Engineer in the Contract Documents; or
- b. there may not be other matters or issues between the parties that might entitle Contractor to be paid additionally by Owner or entitle Owner to withhold payment to Contractor.
4. Neither Engineer's review of Contractor's Work for the purposes of recommending payments nor Engineer's recommendation of any payment, including final payment, will impose responsibility on Engineer:
 - a. to supervise, direct, or control the Work, or
 - b. for the means, methods, techniques, sequences, or procedures of construction, or the safety precautions and programs incident thereto, or
 - c. for Contractor's failure to comply with Laws and Regulations applicable to Contractor's performance of the Work, or
 - d. to make any examination to ascertain how or for what purposes Contractor has used the moneys paid on account of the Contract Price, or
 - e. to determine that title to any of the Work, materials, or equipment has passed to Owner free and clear of any Liens.
 5. Engineer may refuse to recommend the whole or any part of any payment if, in Engineer's opinion, it would be incorrect to make the representations to Owner stated in Paragraph 14.02.B.2. Engineer may also refuse to recommend any such payment or, because of subsequently discovered evidence or the results of subsequent inspections or tests, revise or revoke any such payment recommendation previously made, to such extent as may be necessary in Engineer's opinion to protect Owner from loss because:
 - a. the Work is defective, or completed Work has been damaged, requiring correction or replacement;
 - b. the Contract Price has been reduced by Change Orders;
 - c. Owner has been required to correct defective Work or complete Work in accordance with Paragraph 13.09; or
 - d. Engineer has actual knowledge of the occurrence of any of the events enumerated in Paragraph 15.02.A.

C. Payment Becomes Due:

1. Ten days after presentation of the Application for Payment to Owner with Engineer's recommendation, the amount recommended will (subject to the provisions of Paragraph 14.02.D) become due, and when due will be paid by Owner to Contractor.

D. *Reduction in Payment:*

1. Owner may refuse to make payment of the full amount recommended by Engineer because:
 - a. claims have been made against Owner on account of Contractor's performance or furnishing of the Work;
 - b. Liens have been filed in connection with the Work, except where Contractor has delivered a specific bond satisfactory to Owner to secure the satisfaction and discharge of such Liens;
 - c. there are other items entitling Owner to a set-off against the amount recommended; or
 - d. Owner has actual knowledge of the occurrence of any of the events enumerated in Paragraphs 14.02.B.5.a through 14.02.B.5.c or Paragraph 15.02.A.
2. If Owner refuses to make payment of the full amount recommended by Engineer, Owner will give Contractor immediate written notice (with a copy to Engineer) stating the reasons for such action and promptly pay Contractor any amount remaining after deduction of the amount so withheld. Owner shall promptly pay Contractor the amount so withheld, or any adjustment thereto agreed to by Owner and Contractor, when Contractor remedies the reasons for such action.
3. Upon a subsequent determination that Owner's refusal of payment was not justified, the amount wrongfully withheld shall be treated as an amount due as determined by Paragraph 14.02.C.1 and subject to interest as provided in the Agreement.

14.03 *Contractor's Warranty of Title*

- A. Contractor warrants and guarantees that title to all Work, materials, and equipment covered by any Application for Payment, whether incorporated in the Project or not, will pass to Owner no later than the time of payment free and clear of all Liens.

14.04 *Substantial Completion*

- A. When Contractor considers the entire Work ready for its intended use Contractor shall notify Owner and Engineer in writing that the entire Work is substantially complete (except for items specifically listed by Contractor as incomplete) and request that Engineer issue a certificate of Substantial Completion.
- B. Promptly after Contractor's notification, Owner, Contractor, and Engineer shall make an inspection of the Work to determine the status of completion. If Engineer does not consider the Work substantially complete, Engineer will notify Contractor in writing giving the reasons therefor.
- C. If Engineer considers the Work substantially complete, Engineer will deliver to Owner a tentative certificate of Substantial Completion which shall fix the date of Substantial Completion. There shall be attached to the certificate a tentative list of items to be completed or corrected before

final payment. Owner shall have seven days after receipt of the tentative certificate during which to make written objection to Engineer as to any provisions of the certificate or attached list. If, after considering such objections, Engineer concludes that the Work is not substantially complete, Engineer will, within 14 days after submission of the tentative certificate to Owner, notify Contractor in writing, stating the reasons therefor. If, after consideration of Owner's objections, Engineer considers the Work substantially complete, Engineer will, within said 14 days, execute and deliver to Owner and Contractor a definitive certificate of Substantial Completion (with a revised tentative list of items to be completed or corrected) reflecting such changes from the tentative certificate as Engineer believes justified after consideration of any objections from Owner.

- D. At the time of delivery of the tentative certificate of Substantial Completion, Engineer will deliver to Owner and Contractor a written recommendation as to division of responsibilities pending final payment between Owner and Contractor with respect to security, operation, safety, and protection of the Work, maintenance, heat, utilities, insurance, and warranties and guarantees. Unless Owner and Contractor agree otherwise in writing and so inform Engineer in writing prior to Engineer's issuing the definitive certificate of Substantial Completion, Engineer's aforesaid recommendation will be binding on Owner and Contractor until final payment.
- E. Owner shall have the right to exclude Contractor from the Site after the date of Substantial Completion subject to allowing Contractor reasonable access to remove its property and complete or correct items on the tentative list.

14.05 *Partial Utilization*

- A. Prior to Substantial Completion of all the Work, Owner may use or occupy any substantially completed part of the Work which has specifically been identified in the Contract Documents, or which Owner, Engineer, and Contractor agree constitutes a separately functioning and usable part of the Work that can be used by Owner for its intended purpose without significant interference with Contractor's performance of the remainder of the Work, subject to the following conditions:
 - 1. Owner at any time may request Contractor in writing to permit Owner to use or occupy any such part of the Work which Owner believes to be ready for its intended use and substantially complete. If and when Contractor agrees that such part of the Work is substantially complete, Contractor, Owner, and Engineer will follow the procedures of Paragraph 14.04.A through D for that part of the Work.
 - 2. Contractor at any time may notify Owner and Engineer in writing that Contractor considers any such part of the Work ready for its intended use and substantially complete and request Engineer to issue a certificate of Substantial Completion for that part of the Work.
 - 3. Within a reasonable time after either such request, Owner, Contractor, and Engineer shall make an inspection of that part of the Work to determine its status of completion. If Engineer does not consider that part of the Work to be substantially complete, Engineer will notify Owner and Contractor in writing giving the reasons therefor. If Engineer considers that part of the Work to be substantially complete, the provisions of Paragraph 14.04 will apply with respect to certification of Substantial Completion of that part of the Work and the division of responsibility in respect thereof and access thereto.

4. No use or occupancy or separate operation of part of the Work may occur prior to compliance with the requirements of Paragraph 5.10 regarding property insurance.

14.06 *Final Inspection*

- A. Upon written notice from Contractor that the entire Work or an agreed portion thereof is complete, Engineer will promptly make a final inspection with Owner and Contractor and will notify Contractor in writing of all particulars in which this inspection reveals that the Work is incomplete or defective. Contractor shall immediately take such measures as are necessary to complete such Work or remedy such deficiencies.

14.07 *Final Payment*

A. *Application for Payment:*

1. After Contractor has, in the opinion of Engineer, satisfactorily completed all corrections identified during the final inspection and has delivered, in accordance with the Contract Documents, all maintenance and operating instructions, schedules, guarantees, bonds, certificates or other evidence of insurance, certificates of inspection, marked-up record documents (as provided in Paragraph 6.12), and other documents, Contractor may make application for final payment following the procedure for progress payments.
2. The final Application for Payment shall be accompanied (except as previously delivered) by:
 - a. all documentation called for in the Contract Documents, including but not limited to the evidence of insurance required by Paragraph 5.04.B.6;
 - b. consent of the surety, if any, to final payment;
 - c. a list of all Claims against Owner that Contractor believes are unsettled; and
 - d. complete and legally effective releases or waivers (satisfactory to Owner) of all Lien rights arising out of or Liens filed in connection with the Work.
3. In lieu of the releases or waivers of Liens specified in Paragraph 14.07.A.2 and as approved by Owner, Contractor may furnish receipts or releases in full and an affidavit of Contractor that: (i) the releases and receipts include all labor, services, material, and equipment for which a Lien could be filed; and (ii) all payrolls, material and equipment bills, and other indebtedness connected with the Work for which Owner might in any way be responsible, or which might in any way result in liens or other burdens on Owner's property, have been paid or otherwise satisfied. If any Subcontractor or Supplier fails to furnish such a release or receipt in full, Contractor may furnish a bond or other collateral satisfactory to Owner to indemnify Owner against any Lien.

B. *Engineer's Review of Application and Acceptance:*

1. If, on the basis of Engineer's observation of the Work during construction and final inspection, and Engineer's review of the final Application for Payment and accompanying

documentation as required by the Contract Documents, Engineer is satisfied that the Work has been completed and Contractor's other obligations under the Contract Documents have been fulfilled, Engineer will, within ten days after receipt of the final Application for Payment, indicate in writing Engineer's recommendation of payment and present the Application for Payment to Owner for payment. At the same time Engineer will also give written notice to Owner and Contractor that the Work is acceptable subject to the provisions of Paragraph 14.09. Otherwise, Engineer will return the Application for Payment to Contractor, indicating in writing the reasons for refusing to recommend final payment, in which case Contractor shall make the necessary corrections and resubmit the Application for Payment.

C. *Payment Becomes Due:*

1. Thirty days after the presentation to Owner of the Application for Payment and accompanying documentation, the amount recommended by Engineer, less any sum Owner is entitled to set off against Engineer's recommendation, including but not limited to liquidated damages, will become due and will be paid by Owner to Contractor.

14.08 *Final Completion Delayed*

- A. If, through no fault of Contractor, final completion of the Work is significantly delayed, and if Engineer so confirms, Owner shall, upon receipt of Contractor's final Application for Payment (for Work fully completed and accepted) and recommendation of Engineer, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed and accepted. If the remaining balance to be held by Owner for Work not fully completed or corrected is less than the retainage stipulated in the Agreement, and if bonds have been furnished as required in Paragraph 5.01, the written consent of the surety to the payment of the balance due for that portion of the Work fully completed and accepted shall be submitted by Contractor to Engineer with the Application for such payment. Such payment shall be made under the terms and conditions governing final payment, except that it shall not constitute a waiver of Claims.

14.09 *Waiver of Claims*

- A. The making and acceptance of final payment will constitute:
 1. a waiver of all Claims by Owner against Contractor, except Claims arising from unsettled Liens, from defective Work appearing after final inspection pursuant to Paragraph 14.06, from failure to comply with the Contract Documents or the terms of any special guarantees specified therein, or from Contractor's continuing obligations under the Contract Documents; and
 2. a waiver of all Claims by Contractor against Owner other than those previously made in accordance with the requirements herein and expressly acknowledged by Owner in writing as still unsettled.

ARTICLE 15 – SUSPENSION OF WORK AND TERMINATION

15.01 *Owner May Suspend Work*

- A. At any time and without cause, Owner may suspend the Work or any portion thereof for a period of not more than 90 consecutive days by notice in writing to Contractor and Engineer which will fix the date on which Work will be resumed. Contractor shall resume the Work on the date so fixed. Contractor shall be granted an adjustment in the Contract Price or an extension of the Contract Times, or both, directly attributable to any such suspension if Contractor makes a Claim therefor as provided in Paragraph 10.05.

15.02 *Owner May Terminate for Cause*

- A. The occurrence of any one or more of the following events will justify termination for cause:
1. Contractor's persistent failure to perform the Work in accordance with the Contract Documents (including, but not limited to, failure to supply sufficient skilled workers or suitable materials or equipment or failure to adhere to the Progress Schedule established under Paragraph 2.07 as adjusted from time to time pursuant to Paragraph 6.04);
 2. Contractor's disregard of Laws or Regulations of any public body having jurisdiction;
 3. Contractor's repeated disregard of the authority of Engineer; or
 4. Contractor's violation in any substantial way of any provisions of the Contract Documents.
- B. If one or more of the events identified in Paragraph 15.02.A occur, Owner may, after giving Contractor (and surety) seven days written notice of its intent to terminate the services of Contractor:
1. exclude Contractor from the Site, and take possession of the Work and of all Contractor's tools, appliances, construction equipment, and machinery at the Site, and use the same to the full extent they could be used by Contractor (without liability to Contractor for trespass or conversion);
 2. incorporate in the Work all materials and equipment stored at the Site or for which Owner has paid Contractor but which are stored elsewhere; and
 3. complete the Work as Owner may deem expedient.
- C. If Owner proceeds as provided in Paragraph 15.02.B, Contractor shall not be entitled to receive any further payment until the Work is completed. If the unpaid balance of the Contract Price exceeds all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) sustained by Owner arising out of or relating to completing the Work, such excess will be paid to Contractor. If such claims, costs, losses, and damages exceed such unpaid balance, Contractor shall pay the difference to Owner. Such claims, costs, losses, and damages incurred by Owner will be reviewed by Engineer as to their reasonableness and, when

so approved by Engineer, incorporated in a Change Order. When exercising any rights or remedies under this Paragraph, Owner shall not be required to obtain the lowest price for the Work performed.

- D. Notwithstanding Paragraphs 15.02.B and 15.02.C, Contractor's services will not be terminated if Contractor begins within seven days of receipt of notice of intent to terminate to correct its failure to perform and proceeds diligently to cure such failure within no more than 30 days of receipt of said notice.
- E. Where Contractor's services have been so terminated by Owner, the termination will not affect any rights or remedies of Owner against Contractor then existing or which may thereafter accrue. Any retention or payment of moneys due Contractor by Owner will not release Contractor from liability.
- F. If and to the extent that Contractor has provided a performance bond under the provisions of Paragraph 5.01.A, the termination procedures of that bond shall supersede the provisions of Paragraphs 15.02.B and 15.02.C.

15.03 *Owner May Terminate For Convenience*

- A. Upon seven days written notice to Contractor and Engineer, Owner may, without cause and without prejudice to any other right or remedy of Owner, terminate the Contract. In such case, Contractor shall be paid for (without duplication of any items):
 - 1. completed and acceptable Work executed in accordance with the Contract Documents prior to the effective date of termination, including fair and reasonable sums for overhead and profit on such Work;
 - 2. expenses sustained prior to the effective date of termination in performing services and furnishing labor, materials, or equipment as required by the Contract Documents in connection with uncompleted Work, plus fair and reasonable sums for overhead and profit on such expenses;
 - 3. all claims, costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) incurred in settlement of terminated contracts with Subcontractors, Suppliers, and others; and
 - 4. reasonable expenses directly attributable to termination.
- B. Contractor shall not be paid on account of loss of anticipated profits or revenue or other economic loss arising out of or resulting from such termination.

15.04 *Contractor May Stop Work or Terminate*

- A. If, through no act or fault of Contractor, (i) the Work is suspended for more than 90 consecutive days by Owner or under an order of court or other public authority, or (ii) Engineer fails to act on any Application for Payment within 30 days after it is submitted, or (iii) Owner fails for 30 days

to pay Contractor any sum finally determined to be due, then Contractor may, upon seven days written notice to Owner and Engineer, and provided Owner or Engineer do not remedy such suspension or failure within that time, terminate the Contract and recover from Owner payment on the same terms as provided in Paragraph 15.03.

- B. In lieu of terminating the Contract and without prejudice to any other right or remedy, if Engineer has failed to act on an Application for Payment within 30 days after it is submitted, or Owner has failed for 30 days to pay Contractor any sum finally determined to be due, Contractor may, seven days after written notice to Owner and Engineer, stop the Work until payment is made of all such amounts due Contractor, including interest thereon. The provisions of this Paragraph 15.04 are not intended to preclude Contractor from making a Claim under Paragraph 10.05 for an adjustment in Contract Price or Contract Times or otherwise for expenses or damage directly attributable to Contractor's stopping the Work as permitted by this Paragraph.

ARTICLE 16 – DISPUTE RESOLUTION

16.01 Methods and Procedures

- A. Either Owner or Contractor may request mediation of any Claim submitted to Engineer for a decision under Paragraph 10.05 before such decision becomes final and binding. The mediation will be governed by the Construction Industry Mediation Rules of the American Arbitration Association in effect as of the Effective Date of the Agreement. The request for mediation shall be submitted in writing to the American Arbitration Association and the other party to the Contract. Timely submission of the request shall stay the effect of Paragraph 10.05.E.
- B. Owner and Contractor shall participate in the mediation process in good faith. The process shall be concluded within 60 days of filing of the request. The date of termination of the mediation shall be determined by application of the mediation rules referenced above.
- C. If the Claim is not resolved by mediation, Engineer's action under Paragraph 10.05.C or a denial pursuant to Paragraphs 10.05.C.3 or 10.05.D shall become final and binding 30 days after termination of the mediation unless, within that time period, Owner or Contractor:
1. elects in writing to invoke any dispute resolution process provided for in the Supplementary Conditions; or
 2. agrees with the other party to submit the Claim to another dispute resolution process; or
 3. gives written notice to the other party of the intent to submit the Claim to a court of competent jurisdiction.

ARTICLE 17 – MISCELLANEOUS

17.01 Giving Notice

- A. Whenever any provision of the Contract Documents requires the giving of written notice, it will be deemed to have been validly given if:

1. delivered in person to the individual or to a member of the firm or to an officer of the corporation for whom it is intended; or
2. delivered at or sent by registered or certified mail, postage prepaid, to the last business address known to the giver of the notice.

17.02 *Computation of Times*

- A. When any period of time is referred to in the Contract Documents by days, it will be computed to exclude the first and include the last day of such period. If the last day of any such period falls on a Saturday or Sunday or on a day made a legal holiday by the law of the applicable jurisdiction, such day will be omitted from the computation.

17.03 *Cumulative Remedies*

- A. The duties and obligations imposed by these General Conditions and the rights and remedies available hereunder to the parties hereto are in addition to, and are not to be construed in any way as a limitation of, any rights and remedies available to any or all of them which are otherwise imposed or available by Laws or Regulations, by special warranty or guarantee, or by other provisions of the Contract Documents. The provisions of this Paragraph will be as effective as if repeated specifically in the Contract Documents in connection with each particular duty, obligation, right, and remedy to which they apply.

17.04 *Survival of Obligations*

- A. All representations, indemnifications, warranties, and guarantees made in, required by, or given in accordance with the Contract Documents, as well as all continuing obligations indicated in the Contract Documents, will survive final payment, completion, and acceptance of the Work or termination or completion of the Contract or termination of the services of Contractor.

17.05 *Controlling Law*

- A. This Contract is to be governed by the law of the state in which the Project is located.

17.06 *Headings*

- A. Article and paragraph headings are inserted for convenience only and do not constitute parts of these General Conditions.

D. TECHNICAL SPECIFICATIONS

Unofficial

**SECTION 01001
GENERAL REQUIREMENTS**

PART 1 - GENERAL

1.01 COMMENCEMENTS AND PROSECUTION OF WORK

- A. Contract time shall begin at which time the Owner will issue a written Notice to Proceed. The Contractor must commence construction within ten (10) days of issuance of a written Notice to Proceed. The Contractor shall maintain sufficient labor and supervision on the job until all items have been completed and the Engineer's Final Certification has been issued.

1.02 COOPERATION

- A. The General Contractor and Sub-Contractors shall cooperate with one another and with other Contractors doing related work and shall coordinate their work with the work of other trades and other Contractors so as to facilitate the general progress of the work. Each trade shall afford all other trades and all other Contractors every reasonable opportunity for the installation of their work and for storage of their materials.

1.03 SANITARY FACILITIES, TEMPORARY

- A. Do not allow any sanitary nuisances to be committed in or about work; enforce sanitary regulations of Local and State Health authorities.

1.04 SITE EXAMINATION OF EXISTING CONDITIONS

- A. The Contractor, in undertaking the work under this Contract, is assumed to have visited the premises and to have taken into consideration all conditions which might affect his work. No consideration will be given any claim based on lack of knowledge of existing conditions, except where the Contract Documents make definite provisions for adjustment of cost or extension of time due to existing conditions which cannot be readily ascertained.

1.05 SPECIFICATIONS EXPLANATION

- A. Attention is directed to the fact that the detailed specifications and separate sections may be written in short or abridged form. In regard to every section of the specifications and all parts thereof, mentioned therein or indications on the drawings or articles, materials, operations, or methods required that the Contractor:
 - 1. Provide each item mentioned and indicated (of quality or subject to qualifications notes).
 - 2. Perform (according to conditions stated) each operation prescribed.
 - 3. Provide therefore all necessary labor, equipment, and incidentals.

- B. Wherever in these specifications or on the drawings the words "directed", "required", "ordered", or words of like import are used, it shall be understood that the directions, requirements, permission, or order of the Engineer is intended; and similar words "approved", "accepted", "satisfactory", or words of like import shall mean approved, acceptable to, or satisfactory to the Engineer.
- C. For convenience of reference and to facilitate the letting of Contracts or Sub-Contracts, these specifications are separated into titled sections. Such separation shall not, however, operate to make the Engineer an arbiter to establish limits to the Contracts between the Contractor and Sub-Contractors, nor shall such operation be interpreted as superseding normal union functions.
- D. Notwithstanding the appearance of such language in the various divisions of the specifications as "The Electrical Contractor", "The Roofing Contractor", etc., the Contractor is responsible to the Owner for the entire Contract and the execution of all work referred to in the Contract Documents.

1.06 STANDARD

- A. Wherever reference is made to the standard specifications of nationally known organizations and specific articles, sections, divisions, or headings are not given, such specifications shall apply in full. Standard specifications where included herein by abbreviation or otherwise shall form a part of this specification the same as if quoted in full.
- B. The Engineer may require, and the Contractor shall furnish if required to do so, certificates from manufacturers to the effect that the products or materials furnished by them for use in the work comply with the applicable specified requirements for the materials or products being furnished.

1.07 TELEPHONE, TEMPORARY

- A. Contractor shall provide mobile telephone numbers for the Project Superintendent and Project Foreman either prior to or during the Preconstruction Meeting.

1.08 TEMPORARY UTILITIES

- A. Contractor shall furnish water, electricity, and heating fuel necessary for construction. Contractor shall provide necessary temporary piping, faucets, valves, wiring, switches, outlets, etc., to carry services to the work. The Contractor shall make all temporary utilities connection for his own use and remove temporary services on completion of Contract.

1.09 WORK OUTSIDE OF THE PROPERTY LINE

- A. All work outside of the property line called for by the Contract Documents shall be performed by the Contractor and all cost for same shall be included in the Contract.

1.10 AS-BUILT DRAWINGS

- A. The Contractor shall, upon completion of the work, furnish a marked set of drawings showing field changes affecting the various mechanical trades, utilities and electrical, as actually installed and as specified under those sections of the

specifications, and deliver them to the Engineer. Engineer will furnish prints to Contractor for marking.

1.11 LIQUIDATED DAMAGES

- A. Substantial Completion - If the Contractor neglects, fails or refuses to achieve Substantial Completion of the work by not later than 12 A.M. (Midnight), the Contractor shall pay to the Owner, Liquidated Damages in the amount of three hundred dollars (\$300.00) per calendar day for each and every day that the Contractor is in default after the date indicated on the Notice to Proceed.
- B. Final Completion - If the Contractor neglects, fails, or refuses to complete the work by not later than 12 A.M. (Midnight), the Contractor shall pay to the Owner, Liquidated damages, in the amount of three hundred dollars (\$300.00) per calendar day for each and every day that the Contractor is in default after the date indicated on the Notice to Proceed. Liquidated Damages for Substantial Completion and Final Completion are cumulative.
 - 1. The said amount is fixed and agreed upon by and between the Contractor and the Owner because of the impracticability and extreme difficulty of fixing and ascertaining the actual damages the Owner would in such an event sustain, and said amount is agreed to be the amount of damages which the Owner would sustain and said amount shall be retained from time to time by the Owner from current Progress Payment should the construction progress fall behind schedule.
 - 2. Time is of the essence of each and every portion of this Contract and of the specification wherein a definite and certain length of time is fixed for the performance of any act whatsoever; and where under the Contract an additional time is allowed for the completion of any work, the new time limit fixed by such extension shall be of the essence of this Contract.
 - 3. Extensions of time applies to Liquidated Damages only and shall be allowed only for conditions over which the Contractor has no control, such as acts of God, transportation strikes affecting delivery of materials or equipment which are used in the project, manufacturing strikes affecting the production of materials or equipment which are used in the project, and weather above and beyond the normal expected loss of time based on historical climatological conditions over the last 10 years. For any time requested over what should be expected based on historical climatological conditions the amount of rain or temperature must meet the following conditions. To get credit for delays due to temperature the temperature must at a level that would prevent construction in accordance with the other sections in these specifications. In order to get credit for rain delay the rain event must be persistent for more than four hours during that day and rainfall must be in excess of 0.5" for that 4-hour period or more than 1" during the day.

1.12 MATERIALS PRIOR APPROVAL AND SUBSTITUTIONS

- A. Where items of equipment and/or materials are specifically identified herein by a manufacturer's name, model, or catalog number, only such specific item may be used in the base bid, except as hereinafter provided.

- B. If Contractors wish to use items of equipment and/or materials other than those specifically identified in the Specifications, Contractor shall apply in writing to the Engineer for approval of substitution at least seven (7) days prior to opening of bids, submitting with his request for approval complete descriptive and technical data on the item(s) he proposes to furnish.
- C. Approved substitutions will be listed in an addendum issued to all General Contractors prior to opening of bids.
- D. Unless requests for changes in the Specifications are approved prior to the opening of bids, as defined above, the successful Contractor will be held to furnish specified items. After contract is awarded, changes in specifications will be made only as defined under "Substitution of Equipment".

1.13 SUBSTITUTION OF EQUIPMENT AND MATERIALS

- A. After execution of contract, substitution of equipment and/or materials other than those specifically named in the Contract Documents will be approved by the Engineer for the following reasons only:
 - 1. That the equipment or material is no longer available.
 - 2. That the equipment or material does not perform the function for which it was intended.
 - 3. That the equipment or material cannot be delivered due to conditions beyond the Contractor's control.
- B. To receive consideration, requests for substitutions must be in writing accompanied by documentary proof of equality, and difference in price and delivery, if any.
- C. In case of a difference in price, the Owner shall receive all benefit of the difference in cost involved in any substitutions, and the contract altered by change order to credit the Owner with any savings so obtained.

1.14 INSPECTING AND TESTING OF MATERIALS

- A. Wherever in these Contract Documents inspecting and testing of material is called for, the selection of bureaus, laboratories and/or agencies for such inspecting and testing shall be made by the Engineer, and the character of the test shall be stipulated by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required inspection and tests must be furnished in quadruplicate to the Engineer by the bureau, agency or laboratory selected. Materials satisfactorily meeting the requirements of the inspection or tests shall be approved by the Engineer and the Contractor notified of the results. The cost of such inspecting and testing shall be paid for by the Contractor.

1.15 ON SITE TESTING AND INSPECTING

- A. Wherever in these Contract Documents testing or inspecting is called for, the selection of bureaus, laboratories and/or agencies for such testing or inspecting shall be made by the Engineer. Documentary evidence satisfactory to the Engineer that the materials have passed the required tests or inspections shall be furnished

in quadruplicate to the Engineer. **The cost of such tests and inspection shall be paid for by the Contractor.**

1.16 MEASUREMENTS AND DIMENSIONS

- A. Before ordering materials or doing work which is dependent for proper size of installation upon coordination with site conditions, the Contractor shall verify all dimensions by taking measurements at the site and shall be responsible for the correctness of same. No consideration will be given any claim based on differences between the actual dimensions and those indicated on the drawings. Any discrepancies between the drawings and/or specifications and the existing conditions shall be referred to the Engineer for adjustment before any work affected thereby is begun.

1.17 SHOP DRAWINGS

- A. Shop drawings shall be dated and contain: Name of project; description and names of equipment, materials, and items; and complete identification of locations at which material or equipment is to be installed, reference to the section of the specifications where it is specified and drawings number, where shown. In addition to the above, the Shop drawings shall: (1) show complete information for checking and for fabrication, installation and erection, without reference to other drawings or note; (2) shall be of drafting line work and lettering that is easily readable under field conditions; (3) have plane oriented the same as plans on the Contract Drawings; (4) list grade, class, or strength of materials; (5) be checked and initialed by the suppliers drafting room checker; (6) be checked and coordinated with other phases of the work, by a person in the Contractor's employ who is experienced and qualified in the checking and coordination of shop drawings.
- B. Shop drawings shall not, after having been submitted, be later issued with revised or additional materials, except for items corrected during the checking by the Contractor or reviewed by the Engineer.
- C. The following notation will be used by the Engineer in his review.
 - 1. No exceptions taken. (If checked here, fabrication may be undertaken. Approval does not authorize change to contract sums unless stated in a separate letter or by change order.)
 - 2. Note markings. (If checked here, fabrication may be undertaken. Contractor is to coordinate markings noted.)
 - 3. Revise and resubmit.
 - 4. Rejected.
 - 5. Engineer review is for conformance with the design concept of the project and compliance with the information given within the Contract Documents only. The Contractor is responsible for dimensions being confirmed and correlated at the site; for information that pertains solely to the fabrication processes or to means, method, techniques, sequence, and procedures of construction; and for coordination of the work of all trades.

6. Failure to note a noncompliance will not prevent later rejection when the noncompliance is disclosed.
- D. Submission of Shop drawings shall be accompanied by a transmittal letter in duplicate, containing project name, Owner's project number, Contractor's name, and number of drawings, title, and other pertinent data.
- E. The Contractor shall promptly submit to the Engineer, five copies for Architectural items and six copies for Engineering items, required by the Contract Documents in accordance with the aforesaid schedule so as to cause no delay in his work or in work of any other Contractor.
- F. For standard items not requiring special shop drawings for manufacture, submit six copies of manufacturer's product data showing illustrated cuts of the items to be furnished, scaled details, size dimensions, performance characteristics, capabilities, wiring diagrams, control, and all other pertinent information.
- G. The Contractor shall: (1) check, coordinate, correct, stamp, date, and sign all copies of each drawing, and deliver them to the Engineer for his review; (2) identify the set of drawings he has checked; this set shall be shown by checked marks or correction that every item has been verified and with the requirements of the Contract Documents.

1.18 MAINTENANCE MANUAL

- A. Contractor shall, prior to completion of contract, deliver to the Engineer, three copies of manual, assembled and bound with a hard cover, for the Owner's guidance, full details for care and maintenance of visible surfaces and of equipment included in contract.
- B. Contractor shall, for this manual, obtain from subcontractor, literature of manufacturers relating to equipment, including motors; also furnish cuts, wiring diagrams, control diagrams, instruction sheets and other information pertaining to same that will be useful to Owner in overall operation and maintenance.
- C. Where the above-described manuals and data are called for under separate sections of the specifications, they are to be included in the manual description in this article.

1.19 ELECTRONIC MEDIA

- A. Contractor may request an electronic file of construction plans in its native AutoCAD format for convenience during construction. The initial cost for preparation of the file shall be \$1,000.00, due prior to receipt of the file. Contractor must subscribe to obtain all updates to the file when and if plans are modified. The cost for each update provided to the Contractor shall be \$200.00. Prior to receipt of file, the Contractor must execute an Indemnification Agreement with M.E. Sack Engineering. Transmission of the file to, or use by, any third party is prohibited.

END OF SECTION

6. Failure to note a noncompliance will not prevent later rejection when the noncompliance is disclosed.
- D. Submission of Shop drawings shall be accompanied by a transmittal letter in duplicate, containing project name, Owner's project number, Contractor's name, and number of drawings, title, and other pertinent data.
- E. The Contractor shall promptly submit to the Engineer, five copies for Architectural items and six copies for Engineering items, required by the Contract Documents in accordance with the aforesaid schedule so as to cause no delay in his work or in work of any other Contractor.
- F. For standard items not requiring special shop drawings for manufacture, submit six copies of manufacturer's product data showing illustrated cuts of the items to be furnished, scaled details, size dimensions, performance characteristics, capabilities, wiring diagrams, control, and all other pertinent information.
- G. The Contractor shall: (1) check, coordinate, correct, stamp, date, and sign all copies of each drawing, and deliver them to the Engineer for his review; (2) identify the set of drawings he has checked; this set shall be shown by checked marks or correction that every item has been verified and with the requirements of the Contract Documents.

1.18 MAINTENANCE MANUAL

- A. Contractor shall, prior to completion of contract, deliver to the Engineer, three copies of manual, assembled and bound with a hard cover, for the Owner's guidance, full details for care and maintenance of visible surfaces and of equipment included in contract.
- B. Contractor shall, for this manual, obtain from subcontractor, literature of manufacturers relating to equipment, including motors; also furnish cuts, wiring diagrams, control diagrams, instruction sheets and other information pertaining to same that will be useful to Owner in overall operation and maintenance.
- C. Where the above-described manuals and data are called for under separate sections of the specifications, they are to be included in the manual description in this article.

1.19 ELECTRONIC MEDIA

- A. Contractor may request an electronic file of construction plans in its native AutoCAD format for convenience during construction. The initial cost for preparation of the file shall be \$1,000.00, due prior to receipt of the file. Contractor must subscribe to obtain all updates to the file when and if plans are modified. The cost for each update provided to the Contractor shall be \$200.00. Prior to receipt of file, the Contractor must execute an Indemnification Agreement with P.C. Simonton and Associates, Inc. Transmission of the file to, or use by, any third party is prohibited.

END OF SECTION

**SECTION 01150
MEASUREMENT AND PAYMENT**

PART 1 - GENERAL

1.01 QUANTITIES

- A. Quantities: Quantities listed in the Proposal are approximate only and are intended to serve as a guide in comparing bids, and may be increased or decreased without invalidating the unit price bid.
- B. Payment: Contractor shall be paid for actual in place quantities as determined by the Engineer field measurements.
- C. Discrepancies: In case of discrepancies between the figures shown in the unit prices and totals, the unit prices shall apply and the totals shall be corrected to agree with the unit price.

PART 2 - MEASUREMENT AND PAYMENT

2.01 CLEARING & GRUBBING

- A. Measurement: Measurement shall be made on the basis of the percentage completed of the task in accordance with the plans and specifications.
- B. Payment: Payment will be made at the lump sum stated in the bid. The price bid shall include furnishing all labor, materials, and equipment necessary to complete this item. Work shall include, but is not limited to, the removal of all trees, shrubs, and undergrowth that presently exist, preventing the construction of this project. All material removed, including vegetation, roots, and organic mat, shall be removed from the site and disposed of at a permitted site. The contractor shall take special care not to disturb the roots of trees that are marked to remain. Trees to be saved shall be marked and approved by the engineer prior. Trees to be saved shall have the appropriate tree protection installed.

2.02 GRADING

- A. Measurement: Measurement will be made on the basis of the percent completion of the item of work. All cut and fill quantities are based on the difference between initial topographic data and proposed contours shown on the plans.
- B. Payment: Payment will be made at the price bid for each item. Work shall include all equipment, labor, and material to complete each task. This item will include but is not limited to, excavation, material transportation and placement, grading to the lines and grades shown on the plans, compaction, and stabilization.

2.03 POWER POLE RELOCATION

- A. Measurement: Measurement will be made on the basis of each electric power pole relocated to the location designated on the construction plans per local utility guidance.
- B. Payment: Payment will be made on the basis of each power pole relocated at the unit price bid. The unit price bid shall be included furnishing all labor, materials, and the necessary equipment to complete the item of work. Work shall include, but not be limited to, disconnection/de-energization of connected power lines, excavation for new pole location, excavation of existing pole, removal of existing pole, installation of pole at new location, reattachment of power lines, inspections of connection, and backfill and compaction of the old hole. These steps shall be coordinated with local utilities.

2.04 ELECTRIC UTILITY OVERHEAD LINE RELOCATION

- A. Measurement: Measurement will be made on the basis of the completed item of work. The length of the required overhead line shall be measured and coordinated with local utilities to determine if the existing line can be used.
- B. Payment: Payment will be made on the basis of the completed item of work. The lump sum price shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, site assessment, planning & permitting, completing safety procedures, disconnection/de-energization of indicated power lines, coordination of power outages, reconnection of power line at the relocated pole. This shall be completed by qualified professionals and coordinated with local utilities.

2.05 STRUCTURE RELOCATION

- A. Measurement: Measurement shall be made on the basis of the lump sum of the items to be removed or relocated in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made on the basis of the lump sum bid and the completion of the project. Partial payments will not be made. The project's completion will be determined by the engineer. Work shall include but is not limited to, relocating existing structures to include mailboxes, signage, posts, residential landscaping, and other structures that may impede construction, and includes the provision of temporary mailboxes throughout the construction process, and the replacement of damaged mailboxes throughout the construction process, and the replacement of damaged mailboxes or signs and posts, cleanup, and surface restoration.

2.06 TRAFFIC CONTROL

- A. Measurement: Measurement shall be made on the basis of the percentage complete of the lump sum bid in accordance with the construction plans and bid items.
- B. Payment: Payment shall be made on the basis of the percentage complete of the lump sum price stated in the bid as determined by the project engineer. The lump sum shall include furnishing all labor, materials, and equipment necessary to complete the task. The task shall include, but is not limited to, the placing, moving, and maintenance of all signage, barricades, cones, barrels, flagging, flag men, and guide vehicles throughout the construction process to safely reroute traffic from existing traffic patterns. Traffic control shall be done in a manner to safely warn, reroute, and lead vehicles to their destination while ensuring the access for local traffic to residents which will ensure they can reach their homes. Additional signage will be required if the engineer deems that the traffic control in place does not fully meet the required intent of the task. Changing the existing traffic patterns shall be communicated with the engineer no less than 48 hours prior to.

2.07 EROSION CONTROL AND GRASSING

- A. Measurement: Measurement will be made on the basis of the completed item of work. All silt fence will be measured by the linear foot of the silt fence properly installed and trenched in.
- B. Payment: Payment will be made on the basis of the completed item of work. The lump sum price shall include all equipment, material, and labor to complete the installation. This item will include but is not limited to trenching, grading, furnishing, and installing silt fence; temporary and final stabilization; maintaining erosion and sediment control structures and facilities, and establishing a final stand of cover in accordance with the plans and specifications. Retainage on final grassing will be based on the engineer's estimate of the cost to complete the task, which may not be reflected in the contractor's bid price.

2.08 DEMOLITION

- A. Measurement: Measurement shall be made on the basis of the percentage of completed items in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made on the basis of the completed item of work. The lump sum price shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, removal of any storm pipe, drainage structures, rip rap, trees, or other material that

exist and will not be used as part of this project, excavation, disposal at an approved site, backfill, compaction and surface restoration.

2.09 ASPHALT PAVEMENT REMOVAL

- A. Measurement: Measurement shall be made on the basis of each square yard of asphalt removed in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made on the basis of the unit price stated in the bid. The work shall include, but is not limited to marking, cutting, and removal of pavement, or other materials that exist and will not be used as part of this project, excavation, and disposal at an approved site.

2.10 AGGREGATE BASE REMOVAL

- A. Measurement: Measurement shall be made on the basis of each square yard of aggregate removed in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made on the basis of the unit price stated in the bid. The work shall include, but is not limited to, excavation and removal of aggregate, or other materials that exist and will not be used as part of this project, excavation, and storage at an approved location for use on regraded road.

2.11 ROLLED CONCRETE CURB & GUTTER

- A. Measurement: Measurement shall be made on the basis of each linear foot of rolled concrete curb & gutter installed to the lines and grades shown on the plan. The size of the curb and gutter will be shown on the plans and indicated on the bid documents.
- B. Payment: Payment will be made on the basis of the unit price stated in the bid. The price shall include all materials, labor, and equipment necessary to complete the installation. Work shall include, but is not limited to, all excavation, forming, grade staking, compaction, curb and gutter installation, dewatering, form wrecking, cleanup, and surface restoration.

2.12 ASPHALT PAVING

- A. Measurement: Measurement will be made on the basis of each square yard of asphalt in place, in accordance with the plans and specifications and accepted by the Engineer.

- B. Payment: Payment will be made on the basis of the number of square yards of asphalt in place, in accordance with the unit price bid as stated in contract. Work shall include, but is not limited to, the furnishing, hauling, placing, and compaction of the asphalt in order to bring the pavement to the lines, grades, and cross sections as designated on the construction plans. The unit price shall also include all surface cleaning, prime, tack, and pavement markings. All striping shall be in accordance with the current MUTCD and local specifications- following the same markings as current exists.

2.13 GRANULAR ROADWAY BASE

- A. Measurement: Measurement shall be made on the basis of the number of square yards of graded aggregate base applied to the roadway at the specified thickness as shown on the construction plans. Any removed aggregate base in good condition shall be reused. Irregular areas such as turnouts, filler strips, and intersections will be measured to the closest square yard.
- B. Payment: Payment will be made on the basis of the number of square yards of granite crusher run (graded aggregate) base at the specified thickness applied to the roadway with new and reused material at the unit price stated in the bid. The price shall include all labor, equipment, and material to complete the task. Work shall include, but not be limited to, the furnishing hauling, placing, and compaction of the crusher run base in order to bring the base to the lines, grades, and cross sections shown on the construction plans or established by the Engineer.

2.14 FEATHER ASPHALT PAVING AT INTERSECTION

- A. Measurement: Measurement shall be made on the basis of the percentage complete of the lump sum bid in accordance with the construction plans and bid items.
- B. Payment: Payment shall be made on the basis of the percentage complete of the lump sum price stated in the bid as determined by the project engineer. The lump sum shall include furnishing all labor, materials, and equipment necessary to complete the task. The task shall include, but is not limited to, the furnishing, hauling, placing, and feathering of the asphalt in order to bring the pavement to the existing elevation at the intersection as designated on the construction plans.

2.15 CONCRETE APRON WITH SMOOTH ROCK TRANSITION (DRIVEWAYS)

- A. Measurement: Measurement shall be made on the basis of each square yard of concrete in place, in accordance with the construction plans and specifications and accepted by the Engineer.

- B. Payment: Payment will be made on the basis of the number of square yards of concrete in place, in accordance with the unit price bid, as stated in the contract. The unit price shall include all labor, materials, and equipment necessary to complete the task. Work shall include, but is not limited to, the furnishing, hauling, placing, compaction and leveling of the subbase and concrete in order to bring the concrete to the lines and grades as designated on the construction plans, and compaction of the additional rock installed as a smooth transition to the existing material of the driveway in order to bring the material of the existing lines and grades as designated on the construction plans.

2.16 GRAVEL REPLACEMENT (DRIVEWAYS)

- A. Measurement: Measurement will be made on the basis of each square yard of gravel in place, in accordance with the plans and specifications and accepted by the Engineer.
- B. Payment: Payment will be made on the basis of the number of square yards of gravel in place, in accordance with the unit price bid, as stated in contract. The unit price bid, as stated in contract. The unit price shall include all labor, materials, and equipment necessary to complete the task. Work shall include, but is not limited to, the furnishing, hauling, placing, and compaction of the gravel and subbase in order to bring the gravel to the lines and grades as designated on the construction plans.

2.17 SPEED BUMP REMOVAL AND REINSTALLATION

- A. Measurement: Measurement shall be made on the basis of each speed bump placed at the locations shown on the plans and in accordance with MUTCD and local specifications.
- B. Payment: Payment will be made at the unit price bid. The unit price bid shall include all material, labor, and equipment necessary to accomplish the task. Work shall include, but not be limited to, marking the location, removing the existing speed bump, drilling the holes in the new pavement, replacing the speed bump in accordance with construction plans, surface restoration, and cleanup. All speed bump locations shall be approved by the Engineer prior to installation. No payment will be made for speed bump installed without approval of Engineer.

2.18 PAINT AND BEAD PAVEMENT MARKING

- A. Measurement: Measurement shall be made on the basis of each linear foot of pavement markings in place in accordance with the plans and specifications.
- B. Payment: Payment shall be made at the linear footage stated in the bid. The unit price bid shall include all labor, materials, and equipment necessary to complete

the task. The task shall include, but is not limited to, supplying and installing all paint and bead pavement markings to replace existing in accordance with construction plans, surface restoration, and cleanup.

2.19 CULVERT PIPE REMOVAL

- A. Measurement: Measurement shall be made on the basis of each linear foot of culvert pipe abandoned in place in accordance with the plans and specifications.
- B. Payment: Payment shall be made at the linear footage stated in the bid. The unit price bid shall include all labor, materials, and equipment necessary to complete the task. The task shall include, but is not limited to, excavation, pipe removal, backfill, compaction, surface restoration, and cleanup.

2.20 DRAINAGE STRUCTURE (Junction Box, Headwall, Precast rolled curb inlet, Grated inlet, Flared end section)

- A. Measurement: Measurement will be made on the basis of each drainage structure installed at the elevation and location designated on the construction plans.
- B. Payment: Payment will be made on the basis of each structure installed at the unit price bid. The unit price bid shall include furnishing all labor, materials, and necessary equipment to complete the item of work. Work shall include, but not be limited to, excavation, necessary shoring and sheeting, dewatering, forming, form wrecking, foundations as required, furnishing and installing the structure, placement of grates, rings and covers as applicable, grouting around pipe, 6" underdrain connection, backfill, compaction, grading, complete surface restoration, and cleanup.

2.21 FRENCH UNDERDRAIN PIPE

- A. Measurement: Measurement will be made on the basis of each linear foot of French underdrain pipe installed at the elevation, grade, and alignment as designated on the construction plans.
- B. Payment: Payment will be made on the basis of each linear foot of French underdrain pipe installed at the elevation, grade, and alignment as designated on the construction plans at the unit price bids as stated in the contract. Work shall but not be limited to, all excavation, trenching, necessary shoring and sheeting, all pipe bidding, furnishing and installing pipe, backfill, compaction, complete surface restoration, and cleanup.

2.22 DRAINAGE PIPE

- A. Measurement: Measurement will be made on the basis of each linear foot of drainage pipe installed at the elevation, grade, and alignment as designated on the construction plans.
- B. Payment: Payment will be made on the basis of each linear foot of drainage pipe installed at the elevation, grade, and alignment as designated on the construction plans at the unit price bids as stated in the contract. Work shall but not be limited to, all excavation, trenching, necessary shoring and sheeting, all pipe bidding, furnishing and installing pipe, backfill, compaction, complete surface restoration, and cleanup.

2.23 CONNECTIONS TO EXISTING SEWER SYSTEM

- A. Measurement: Measurement shall be made on the basis of each completed connection to the existing sewer manhole.
- B. Payment: Payment will be made on the basis of the unit price stated in the bid. The unit price bid shall include all materials, equipment, and labor necessary to complete the task. The task shall include, but is not limited to, locating the manhole, excavation, connection to the existing manhole including any fittings or clean outs required, manhole cored with boot (required), complete backfill and compactions and preparation of the surface for stabilization.

2.24 GRAVITY SEWERS

- A. Measurement: Measurement shall be made on the basis of each linear foot of gravity sewer line installed at the elevation and location designated on the construction plans.
- B. Payment: Payment for gravity sewers will be made at the unit price bid per linear foot. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete the installation of the sewer, including, but not limited to, trenching, bedding, PVC, or ductile iron sewer pipe, shoring and sheeting, dewatering, testing, backfill, trench compaction, and complete surface restoration.

2.25 MANHOLES AND RISER SECTIONS

- A. Measurement: Measurement shall be made on the basis of each manhole installed. Each complete manhole will be measured from the invert to the top of the cast iron frame and cover. A deduction of six feet (6') for the standard manhole and a deduction for the height of the frame and cover will be made. The remainder will be considered an additional riser section.

- B. Payment: Payment will be made for each manhole installed and for each additional vertical foot of riser installed at the unit prices stated in the bid. The unit price bid shall include all labor, materials, and equipment necessary, including, but not limited to, excavation, shoring, sheeting, dewatering, gravel bedding, manholes, riser sections, castings, inverts, stub outs, plugs, pipe connections, concrete manhole markers (if applicable), backfill, compaction, and complete surface restoration.

2.26 TIE INTO EXISTING WET WELL

- A. Measurement: Measurement shall be made on the basis of the complete connection in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made at the lump sum stated in the bid. Work shall include furnishing all labor, materials, and equipment necessary to complete the task. The price shall include, but is not limited to, locating the receiving wet well, excavation, connection to the receiving wet well- including any fittings and sealants required, blocking, excavation, trenching, backfill, compaction, shoring, sheeting, fittings, grouting, dewatering, bedding, and preparation of the surface for stabilization.

2.27 RECONNECT SANITARY SEWER SERVICE LATERALS

- A. Measurement: Measurement shall be made on the basis of the complete all connections in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made at the lump sum stated in the bid. Work shall include furnishing all labor, materials, and equipment necessary to complete the task. The price shall include, but is not limited to, identifying the existing sewer service laterals, excavation, trenching, installation of cleanouts as necessary, extension of sewer laterals, extension of lateral to installed main as specified on the construction plans, backfill, compaction, shoring, sheeting, fittings or couplings, sealants, dewatering, bedding, surface restoration, and cleanup.

2.28 SANITARY SEWER SERVICE LATERALS CONNECTIONS

- A. Measurement: Measurement shall be made on the basis of the complete all connections in accordance with the plans, specifications, and bid documents.
- B. Payment: Payment will be made at the lump sum stated in the bid. Work shall include furnishing all labor, materials, and equipment necessary to complete the task. The price shall include, but is not limited to, identifying the existing sewer service house connections, excavation, trenching, by passing of existing private

pump stations as necessary, installation of cleanouts as necessary, installation of sewer laterals, extension of lateral to installed main as specified on the construction plans, backfill, compaction, shoring, sheeting, fittings or couplings, sealants, dewatering, bedding, surface restoration, and cleanup.

2.29 CUT, FILL, AND REMOVE EXISTING, SEWER LINE

- A. Measurement: Measurement shall be made on the basis of each linear foot of sewer line capped, filled, and removed at the location designated on the construction plans.
- B. Payment: Payment for sewer line removal will be made at the unit price per linear foot. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, excavation, cut the indicated sewer line, any required disinfection, plugging the sewer line where cut, removal of designated sewer line, disposal at approved site, backfill, compaction, and surface restoration.

2.30 DEMOLISH AND REMOVE EXISTING SEWER MANHOLE

- A. Measurement: Measurement shall be made on the basis of each manhole unit removed in accordance with the construction plans and specifications.
- B. Payment: Payment for manhole removal will be made at the unit price per item. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, excavation, removal of designated manhole, debris removal, disposal at approved site, backfill, compaction, and surface restoration.

2.31 FILL & ABANDON SEWER LINE

- A. Measurement: Measurement shall be made on the basis of each linear foot of sewer line abandoned at the location designated on the construction plans.
- B. Payment: Payment for abandoned gravity sewer line will be made at the unit price bid per linear foot. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, excavation, filling indicated sewer line with concrete, sealing manhole connections, backfill, compaction, and surface restoration.

2.32 ABANDON PRIVATE PUMP STATIONS

- A. Measurement: Measurement shall be made on the basis each unit abandoned in accordance with the construction plans and local ordinances.
- B. Payment: Payment for will be made at the unit price bid per private pump station abandoned. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, dewatering, sludge removal and disposal, power disconnections, removal and disposal of mechanical equipment (returned to owner if requested), concrete and steel structure removal and disposal (three feet below ground surface), gravel placement, backfill, compaction, cleanup, surface restoration, grassing, and EPD notification.

2.33 CUT, FILL, AND REMOVE WATER LINE

- A. Measurement: Measurement shall be made on the basis of each linear foot of water line capped, filled, and removed at the location designated on the construction plans.
- B. Payment: Payment for removed water line will be made at the unit price bid per linear foot. Unit price bid shall include furnishing all labor, materials, and equipment necessary to complete this item of work. Work shall include, but is not limited to, excavation, cutting and capping the indicated water line, any required disinfection, plugging the water line where cut, removal of designated water line, disposal at approved site, backfill, compaction, and surface restoration.

2.35 WATERMAINS

- A. Measurement: Measurement will be made along the centerline of the pipe trench and through fittings and specials. No deduction in length will be made for fittings or specials.
- B. Payment: Payment will be made on the basis of unit price bid per linear foot for specific line size. Unit price bid shall include all materials, labor, and equipment necessary to complete the water main installation. Work shall include, but not be limited to, trenching and excavation, necessary shoring and sheeting, furnishing and installing pipe, tracer wire, marker tape, backfilling and compaction, concrete blocking, bedding, pressure testing, disinfection, complete surface restoration, and cleanup.

2.36 GATE VALVES

- A. Measurement: Measurement shall be made on the basis of each unit installed in accordance with the construction plans and specifications.
- B. Payment: Payment will be made at the unit price bid for a specific valve size. Unit price bid shall include furnishing all materials, labor, and equipment necessary to complete the gate valve installation. Work shall include, but not be limited to, excavation, necessary shoring, sheeting, backfilling, concrete valve box collar, furnishing and installing gate valves, valve boxes, pressure testing, disinfection, and complete surface restoration and cleanup.

2.37 FITTINGS

- A. Measurement: Measurement will be made on the basis of each ton of fittings installed based on the weight of the fitting and the accessory kit.
- B. Payment: Payment will be made at the unit price bid per ton of fittings installed in accordance with the plans or directed by the engineer. The price shall include all labor, equipment, and materials to complete the task. Work shall include, but is not limited to, furnishing the fitting, all bolts, accessories, trench, excavation, thrust blocking, pressure testing, surface restoration, and stabilization

2.38 MOBILIZATION

- A. Payment: Payment will be made for the price as stated in the Contract once the Contractor has established his construction yard and met the requirements established in the Contract Documents. Mobilization will be recognized as complete once the Contractor has provided a construction schedule and moved his equipment and a substantial amount of material to the job site. Construction must be underway and progressing. Payment for mobilization will be limited to a maximum amount not to exceed 5.0% of the bid price.

END OF SECTION

**SECTION 02100
CLEARING AND GRUBBING**

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Clearing shall consist of the felling, trimming, cutting and disposal of trees and other vegetation designated for removal, including down timber, snags, brush, and rubbish occurring within the area to be cleared. Grubbing shall consist of the removal and disposal of stumps, roots larger than 1.5 inches in diameter and matted roots.

PART 2 - EXECUTION

- 2.01 Trees, down timber, stumps, roots, brush, and other vegetation in areas to be cleared shall be removed completely, except such trees and vegetation as may be indicated or directed to be left standing. Trees to be left standing within the cleared areas shall be trimmed of dead branches 1.5 inches or more in diameter.
- 2.02 Limbs and branches to be trimmed shall be neatly cut close to the bore of the tree or main branches. Cuts more than 1.5 inches in diameter shall be painted with commercial tree-wound paint.
- 2.03 All organic materials, masonry, concrete, or metallic debris in the clearing and grubbing areas shall be excavated and removed to a depth of not less than 12 inches below grade where original grade is to remain level and two feet below finish grade, bottom of pavement base and bottom of footings.
- 2.04 Depressions made by grubbing shall be backfilled and compacted with fill material to meet the requirement for trenching and structural backfilling.
- 2.05 Machine grubbing shall not be done under trees left standing in the area covered by the branches, nor in any manner which might damage the trees or any new work.
- 2.06 Trees and vegetation to be left standing shall be protected from damage during clearing, grubbing and construction operations, by the erection of barriers.
- 2.07 Damages caused by the execution of clearing and grubbing shall be paid for by the Contractor.
- 2.08 Objects above or below grade interfering with construction to be removed as directed by the Engineer.
- 2.09 DISPOSAL OF MATERIALS
 - A. Cleared and grubbed materials to be disposed of to an approved off-site disposal area.
 - B. On site burning will not be allowed, without written permission of local authorities.

END OF SECTION

**SECTION 02210
SITE GRADING**

PART 1 – GENERAL

1.01 QUALITY ASSURANCE

A. Reference Standards:

1. Standards of American Society for Testing and Materials:

ASTM-D-698 Moisture-Density Relations of Soils Using 5.5 lb. (2.5 KG) Hammer and 12 inch (304.8 mm) Drop.

2. Methods of Sampling and Testing of American Association of State Highway and Transportation Officials (AASHTO), latest edition.

1.02 TESTING

A. All soil testing shall be performed by an Independent Testing Laboratory selected by the Engineer and paid for by the Contractor.

1.03 EXCESS EXCAVATED MATERIALS

A. Excess excavated materials shall be wasted off site by the Contractor at no expense to Owner, or as directed by the Engineer.

1.04 BORROW MATERIAL

A. Any borrow material required to accomplish all levels, lines and grades indicated shall be furnished by the Contractor at no expense to the Owner.

B. Borrow material shall be obtained from borrow pits off site.

C. The Contractor shall pay for all soil analysis for borrow material.

1.05 EXCAVATED MATERIAL

A. All material to be excavated shall be classified as earth.

1.06 UNSUITABLE BEARING MATERIALS

A. Should unsuitable bearing materials be encountered at levels indicated and found to have insufficient bearing values the Engineer may order the excavation carried to lower depths.

B. Compensation for the removal and/or replacement of unsuitable materials shall be in accordance with the General Conditions, Article 10.01.

C. Excavation of unsuitable bearing materials shall not proceed until the conditions have been observed by the Engineer and written approval has been given by the Owner.

PART 2 – EXECUTION

2.01 TOPSOIL

- A. Areas to be stripped shall first be scraped clean of all brush, weeds, grass, roots, and other material.
- B. Remove topsoil from areas to be graded and stockpile in locations where it will not interfere with structures, roads, or utility operations.
- C. Topsoil shall be free from subsoil, debris, and stones larger than 2 inches in diameter. The stored topsoil shall be left in piles to be used for finished grading. Contractor shall install a minimum of 4 inch thick topsoil across pervious areas of the site prior to planting. If topsoil from site is unsuitable or insufficient to achieve 4 inch thickness, additional material is to be provided by the Contractor at no additional cost to owner and from a source approved by Engineer.
- D. Stockpiles shall be protected from contamination by undesirable foreign matter and shall be graded to shed water.

2.02 EXCAVATION

- A. Excavations shall be accomplished to bring surface to the levels, lines and grades as indicated.
- B. Excavated material to be used for fill or backfill material shall be stockpiled on the site as directed by the Engineer. Stockpiles shall be graded to shed water.

2.03 FILLING

- A. All fill material required to bring areas to the levels, lines and grades indicated shall be selected and approved materials from approved borrow areas.
- B. Sub-grades on which fill material is to be placed shall be scarified to a depth of not less than 4 inches by plowing or discing. A layer of suitable fill material, approximately 3 inches in depth, shall be spread over the scarified surface and compacted.
- C. Fill material shall be spread and compacted in successive uniform layers not exceeding 8 inches in depth (loose measure) until the total thickness of fill is completed.

2.04 COMPACTION

- A. Compaction required for material fill shall be 95% of Standard Proctor, maximum dry density as determined by the procedures of ASTM D-698. Fill areas shall be crowned and sloped to drainage ditches or as required to prevent ponding of surface water.
- B. Compaction by flooding of any material is not acceptable. In the event that any flooding takes place, the material and all adjacent softened material shall be removed and replaced with compacted fill at no cost to the Owner.

2.05 FINISH GRADE

- A. Distribute topsoil evenly to levels, lines and grades shown.
- B. Finish grade to be trimmed and raked true to line and grade to avoid surface ponding.
- C. Remove stone two inches or greater in diameter and debris from soil.
- D. Finish grade tolerance to +/- 0.05 foot for roadways and +/- 0.10 foot for other areas.

END OF SECTION

Unofficial

SECTION 02221
TRENCH EXCAVATION, BACKFILL, AND COMPACTION

PART 1 - GENERAL

1.01 SCOPE, STANDARDS & DEFINITIONS

- A. Work under this section shall consist of furnishing all materials, equipment and labor for excavation, trenching and backfilling for utility systems. "Utility systems" shall include underground piping and appurtenances for water distribution systems, storm water drains, sewage collection systems, force mains, spray irrigation system and all other pipes and appurtenances shown on the drawings.
- B. Applicable Standards and Reference
 - I. ASTM D2321 Soil Classification and Restrictions
 - a. Class IA = Manufactured crushed stone, shell, crushed slag or rock, open graded, clean, large voids, contains no fines, can allow sand migration to create excessive settling. Suitable as drainage blanket.
 - b. Class IB = Manufactured aggregate dense graded, clean, crushed stone with sand and gradation present. Closer void so little migration of sand, little fines. Minimal migration of sand. Suitable as drainage blanket.
 - c. Class II = Coarse grained soils and sand, graded gravel and sandy mix, minimal migration of silt or sand, Use as drainage blanket and drains limited.
 - d. Class III = Coarse grain sand with fines, silty gravel, gravel-sand-silt mixture, clayey gravels, silty sand mixture. Not to be used in the presence of water.
 - e. Class IVA = Fine grain soils, inorganic, Inorganic silts and very fine sand, silty clayey fine sands, inorganic clay with minor plasticity, lean clay. Use only where no water exists and shallow fills.
 - f. Class IVB = Fine Grained soils inorganic, micaceous fine sand, silty soil, fat clay, clay with high plasticity. Use requires geotechnical evaluation.
 - g. Class V = Organic soils, clay and silt with organics. No permitted use other than top 6" outside roadways for soil amendment for grassing.

1.02 EXISTING UTILITIES

- A. Before opening trenches, the Contractor shall examine all available records and explore for the location of all sub-surface pipes, valves or other structures and reference such locations on the surface.
- B. In opening trenches, every effort shall be made not to interfere with these utilities' structures. Expose existing piping by hand before excavating by machine. Excavate existing utilities sufficiently in advance of pipe laying to determine crossing arrangement. Slight deviations may be permitted in order to clear such structures.

The Contractor shall be entirely responsible for the preservation of all underground or overhead utility lines and structures, such as gas, water, sewer lines, telephone conduit, power lines, etc., and shall replace, adjust or repair, without additional compensation, any such lines damaged or interfered with as a result of this construction.

- C. Schedule work to keep roads and utilities in usable condition; coordinating all operation with the Owner to avoid inconvenience insofar as practicable.

1.03 EXCAVATED MATERIAL

- A. All material to be excavated shall be classified as earth.

1.04 BORROW MATERIAL

- A. Any borrow material required to accomplish all levels, lines and grades indicated shall be furnished by the Contractor at no expense to the Owner.
- B. Borrow material shall be obtained from borrow pits off site.
- C. The Contractor shall pay for all soils analysis for borrow material.

1.05 TESTING

- A. All soil testing shall be performed by an Independent Testing Laboratory selected by the Engineer and paid for by the Contractor.

1.06 QUALITY ASSURANCE

- A. All excavation within the rights of way of city streets and county, State or Federal roadways, shall be backfilled in accordance with the then prevailing requirements of the Georgia Department of Transportation, Highway Division.
- B. Reference Standards: Methods of Sampling and Testing of American Association of State Highway and Transportation Officials (AASHTO).

PART 2 - EXECUTION

2.01 GENERAL EXCAVATION

- A. The Contractor shall do all excavation of whatever substances encountered to depth shown on plans. Excavated materials not required for fill or backfill shall be removed from site as directed by the Engineer.
- B. Contractor is to excavate to provide 3-foot minimum cover over utility.
- C. Excavation for manholes and other accessories to have 12 inches minimum and 24-inch maximum clearance on all sides.
- D. Excavation shall not be carried below the required level.
- E. Where excavation is carried below grades indicated, the Contractor shall refill same to the proper grade with compacted earth or stone, or as directed by the Engineer.


- F. Banks of trenches shall be vertical.
- G. Width of trench shall be as shown on the plans. The bottom of trench for sewers and culverts shall be rounded so that an arc of the circumference equal to 0.6 of the outside diameter of the pipe rests on undisturbed soil.
- H. Bell holes shall be excavated accurately to size by hand.

2.02 UNSUITABLE BEARING MATERIALS

- A. Should unsuitable bearing materials be encountered at levels indicated and found to have insufficient bearing values the Engineer may order the excavation carried to lower depth.
- B. Compensation for the removal and/or replacement of unsuitable bearing materials shall be in accordance ASTM D2321 requirements.
- C. Excavation of unsuitable bearing materials shall not proceed until the conditions have been observed by the Engineer and written approval is given by the Owner.

2.03 PIPE BEDDING

- A. The following detail provides trench & pipe zone terminology.



PIPE BEDDING DETAIL
N.T.S.

- B. The trench floor should be constructed to provide firm, stable, and uniform support for the full length of the pipe. This can be accomplished by bringing the entire trench floor level grade and then creating bell holes at each joint to permit proper joint assembly, alignment and support. Portions of the trench that are excavated below grade should be returned to grade and compacted as required to provide proper support. If native trench soil is not suitable for pipe bedding, the trench should be over excavated and refilled with suitable foundation material either local sandy material compacted to 90% Std. Proctor or #57 stone depending on the presence of water and, as approved by the engineer. Bedding material shall be Class IB or II as defined in ASTM D2321. Large rocks or hard material should not be contained in the bedding area (minimum of 6") below the pipe.
- C. The most important factor in assuring proper pipe-soil interaction is the haunching material and its density. This material provides the majority of the support that the pipe requires to function properly in regards to deflection and performance. The haunching material shall be placed and compacted under the pipe haunches as shown in the detail above. Proper control should be exercised to avoid deflecting the pipe from proper alignment. The same material that is used for bedding should be used for haunching and compacted to the same standards. Haunching material shall be Class IB or II as defined in ASTM D2321.
- D. Initial backfill, as shown in the detail above, shall be accomplished with suitable, compactable material and compacted in 6" layers. Material shall meet the requirements of Class Ib, II or III as restricted in ASTM D2321.
- E. Final Backfill will be accomplished by placing material in 12" lifts and compacting to a level determined by the final use of the area above the pipe. Final backfill in roadways shall require placement of suitable Class IA, IB, II and III backfill material, placed in 12" lifts and compacted to 100% standard proctor (ASTM Test D-698). Final Backfill outside of roadways shall be Class II, III or IVA and lightly compacted to avoid settling in the future. The top 6" of the final backfill, outside of roadways, shall be suitable for establishing a final grassed surface.
- F. Material used in the "trench & pipe zone" shall be restricted as per the limitations and restrictions as outlined in ASTM D2321

2.04 BRACING AND SHORING

- A. The Contractor shall do all bracing, sheeting and shoring necessary to perform and protect all excavations as required for safety.
- B. Sheeting driven alongside the pipe should be cut off and left in place to an elevation 1.5 feet above the top of the pipe.
- C. All other sheeting shall be removed as directed by the Engineer.

2.05 DEWATERING FOR EXCAVATION

- A. The Contractor shall pump or remove any water accumulated in any excavated area and shall perform all work necessary to keep excavations clear of water while foundations, structures or any masonry are being constructed or while pipe is being laid.

- B. No structure or pipe shall be laid in water, and water shall not be allowed to flow over or rise upon any concrete or masonry or piping until same has been inspected and the mortar or joint material has cured.
- C. No extra compensation will be allowed for removal of water.
- D. All water pumped or bailed from the trenches or other excavation shall be conveyed to a point of discharge where it will neither cause a hazard to the public health, nor damage to the public or private property, or to work completed or in progress.

2.06 BACKFILL

- A. The soil at the sides of a pipe and above it is the backfill.
- B. Prior to backfilling any excavation, all piping and structures shall be observed by the Engineer.
- C. After pipes have been tested and approved, backfilling shall be done with approved material free from large clods or stones.
- D. Backfill shall be placed in uniform layers, four inches thick, on both sides of the pipe and thoroughly compacted with pneumatic or hand tampers. The backfill shall be brought up uniformly on both sides of the pipe and compacted to an elevation of one foot above the top of the pipe, after which the fill shall be placed in eight inch lifts. No rock will be allowed in the backfill within a distance of one foot from the pipe, and rock larger than six inches in the greatest dimension will not be permitted in any part of the trench or backfill.
 - 1. Backfill shall be compacted to not less than 95% of the maximum dry weight per cubic foot as determined by AASHTO Method T-99 (Standard Proctor Test).
 - 2. The top 18 inches of backfill under any paved area shall be compacted to 100% Standard Proctor.
 - 3. Water settling will not be permitted in clay soils. It may be required at the option of the Engineer in sandy soils.

2.07 REPLACING PAVEMENTS

- A. Subgrades shall be compacted with a mechanical tamper.
- B. The minimum width of replaced concrete pavements shall be 4 feet at interiors and 6 feet at joints and constructed as shown on Standard Details. Avoid cutting pavements at joints; if unavoidable, reconstruct same as original joint. Depth shall be equal to the original thickness. Existing pavements edges shall be cut vertical.
- C. Use high-early-strength cement if road is to be opened in less than 3 days.
- D. The minimum width of replaced bituminous pavements shall be 3 feet with 8 inch concrete patch. The existing pavement shall be cut vertically and horizontally to a straight line. The 8 inch concrete patch shall be minimum 3,000 psi concrete containing black dye and shall be flush with the existing pavement.

END OF SECTION

**SECTION 02415
SITE DEMOLITION**

PART 1 - GENERAL

1.01 DESCRIPTION

This section specifies demolition and removal of buildings, portions of buildings, utilities, other structures, and debris from trash dumps shown.

1.02 RELATED WORK

- A. Demolition and removal of roads, walks, curbs, and on-grade slabs outside buildings to be demolished.
- B. Safety Requirements: GENERAL CONDITIONS Article, ACCIDENT PREVENTION.
- C. Disconnecting utility services prior to demolition: Section 01 00 00, GENERAL REQUIREMENTS.
- D. Reserved items that are to remain the property of the Owner.
- E. Asbestos Removal: See Hazardous Material Sections of General Conditions.
- F. Lead Paint: See Hazardous Material Sections of General Conditions.
- G. Environmental Protection: See Erosion and Sedimentation Control Specification.
- H. Construction Waste Management: See General Requirements Specification.

1.03 PROTECTION

- A. Perform demolition in such manner as to eliminate hazards to persons and property; to minimize interference with use of adjacent areas, utilities and structures or interruption of use of such utilities; and to provide free passage to and from such adjacent areas of structures. Comply with requirements of GENERAL CONDITIONS Article, ACCIDENT PREVENTION.
- B. Provide safeguards, including warning signs, barricades, temporary fences, warning lights, and other similar items that are required for protection of all personnel during demolition and removal operations.
- C. Maintain fences, barricades, lights, and other similar items around exposed excavations until such excavations have been completely filled.
- D. Provide enclosed dust chutes with control gates from each floor to carry debris to truck beds and govern flow of material into truck. Provide overhead bridges of tight board or prefabricated metal construction at dust chutes to protect persons and property from falling debris.
- E. Prevent spread of flying particles and dust. Sprinkle rubbish and debris with water to keep dust to a minimum. Do not use water if it results in hazardous or

objectionable condition such as, but not limited to, ice, flooding, or pollution. Vacuum and dust the work area daily.

- F. In addition to previously listed fire and safety rules to be observed in performance of work, include following:
 - 1. No wall or part of wall shall be permitted to fall outwardly from structures.
 - 2. Maintain at least one stairway in each structure in usable condition to highest remaining floor. Keep stairway free of obstructions and debris until that level of structure has been removed.
 - 3. Wherever a cutting torch or other equipment that might cause a fire is used, provide and maintain fire extinguishers nearby ready for immediate use. Instruct all possible users in use of fire extinguishers.
 - 4. Keep hydrants clear and accessible at all times. Prohibit debris from accumulating within a radius of 4500 mm (15 feet) of fire hydrants.
- G. Before beginning any demolition work, the Contractor shall survey the site and examine the drawings and specifications to determine the extent of the work. The contractor shall take necessary precautions to avoid damages to existing items to remain in place, to be reused, or to remain the property of the Owner; any damaged items shall be repaired or replaced as approved by the Resident Engineer. The Contractor shall coordinate the work of this section with all other work and shall construct and maintain shoring, bracing, and supports as required. The Contractor shall ensure that structural elements are not overloaded and shall be responsible for increasing structural supports or adding new supports as may be required as a result of any cutting, removal, or demolition work performed under this contract. Do not overload structural elements. Provide new supports and reinforcement for existing construction weakened by demolition or removal works. Repairs, reinforcement, or structural replacement must have Resident Engineer's approval.
- H. The work shall comply with the requirements of the Erosion and Sediment Control Specification and other sections of this specification.
- I. The work shall comply with the requirements of GENERAL REQUIREMENTS.

1.04 UTILITY SERVICES

- A. Demolish and remove outside utility service lines shown to be removed.
- B. Remove abandoned outside utility lines that would interfere with installation of new utility lines and new construction.

PART 2 - EXECUTION

2.01 DEMOLITION

- A. Completely demolish and remove buildings and structures, including all appurtenances related or connected thereto, as noted below:
 - 1. In accordance with Building Demolition Specification.

2. As required for installation of new utility service lines.
 3. To full depth within an area defined by hypothetical lines located 1500 mm (5 feet) outside building lines of new structures.
- B. Debris, including brick, concrete, stone, metals, and similar materials shall become property of Contractor and shall be disposed of by him daily, off the project site to avoid accumulation at the demolition site. Materials that cannot be removed daily shall be stored in areas specified by the Resident Engineer. Break up concrete slabs below grade that do not require removal from present location into pieces not exceeding 600 mm (24 inches) square to permit drainage. Contractor shall dispose debris in compliance with applicable federal, state, or local permits, rules and/or regulations.
- C. Remove and legally dispose of all materials, other than earth to remain as part of project work, from any trash dumps shown. Materials removed shall become property of contractor and shall be disposed of in compliance with applicable federal, state, or local permits, rules and/or regulations to a permitted site. All materials in the indicated trash dump areas, including above surrounding grade and extending to a depth of 1500mm (5feet) below surrounding grade, shall be included as part of the lump sum compensation for the work of this section. Materials that are located beneath the surface of the surrounding ground more than 1500 mm (5 feet), or materials that are discovered to be hazardous, shall be handled as unforeseen. The removal of hazardous material shall be referred to Hazardous Materials specifications.
- D. Remove existing utilities as indicated or uncovered by work and terminate in a manner conforming to the nationally recognized code covering the specific utility and approved by the Resident Engineer. When Utility lines are encountered that are not indicated on the drawings, the Resident Engineer shall be notified prior to further work in that area.

2.02 CLEAN-UP

On completion of work of this section and after removal of all debris, leave site in clean condition satisfactory to Resident Engineer. Clean-up shall include off the offsite disposal of all items and materials not required to remain property of the Owner as well as all debris and rubbish resulting from demolition operations.

END OF SECTION

**SECTION 02520
STORM DRAINAGE AND APPURTENANCES**

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

- A. Appurtenances shall be constructed in accordance with the referenced Georgia Department of Transportation Standard Drawings.
- B. American Society for Testing and Materials (ASTM):
 - C- 32 Specification for Sewer and Manhole Brick.
 - C- 76 Reinforced Concrete Culvert, Storm Drain and Sewer Pipe.
 - C-144 Aggregate for Masonry Mortar.
 - C-270 Mortar for Unit Masonry
 - C-443 Joints for Circular Concrete Sewer and Culvert Pipe, Using Rubber Gaskets.
 - C-913 Specification for Precast Concrete Water and Wastewater Structures
 - C-536 Test for Continuity of Coatings in Glassed Steel Equipment by Electrical Testing.
- C. Only reinforced concrete pipe will be allowed under roadways or frequently traveled areas.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Roadway Storm Drainage Pipe: Pipe shall be reinforced Concrete Pipe which conforms to ASTM Specification C-76 and shall be of sizes shown. Pipe shall be Class III minimum and as indicated on GA. D.O.T. Standard 1030 D.
- B. Non-Roadway Storm Drainage Pipe: Pipe shall be one of the following:
 - 1. Corrugated metal pipe shall conform to AASHTO designation M-36, AREA Manual 1-4 requirements for corrugated metal culverts, or Federal Specification QQ-C- 806, with the following applicable requirements:
 - a. The outside and inside surfaces of the corrugated metal pipe shall be completely coated with bituminous material with a minimum thickness of 0.05 inch at the crest of the corrugations. Immediately prior to the application of the bituminous coating, the corrugated metal pipe shall be cleaned of all dirt, grease, mill scale, or loose rust and shall be dry.

- b. The outside and inside surfaces of the corrugated metal pipe shall be completely coated with a pure aluminum coating metallurgically bonded by an alloy layer between the steel and the aluminum. The coating shall be applied at a minimum of 1 oz./sq.ft., 2 mils. each side. The weight of aluminum (total both sides) shall be as follows: Minimum check limit triple-spot test=1.00 oz/sq feet, minimum check limit single-spot test=0.90 oz/sq feet. The aluminized steel pipe shall be Armco Aluminized Steel Type 2 or equal.
 - c. All rivets shall be placed in the inside valley of the corrugations. The interior coating shall be protected against damage from insertion or removal of struts or tie wires. Lifting lugs, where used, shall be so placed as to facilitate moving the pipe without damage to the exterior or interior coating. All lateral pipe shall be sixteen (16) gauge. All pipe under possible traffic areas will be twelve (12) or fourteen (14) gauge as indicated.
 - d. To facilitate field jointing, the ends of pipes with helical corrugations shall be rerolled to form circumferential corrugations from the end. The diameter of the reformed ends shall not exceed that of the pipe barrel by more than the depth of the corrugation.
2. Polyvinyl chloride (PVC) pipe shall be manufactured and tested in accordance with specification for "Poly (Vinyl Chloride) PVC Large Diameter Ribbed Gravity Sewer Pipe and Fittings Based on Controlled Inside Diameter." The pipe and fittings shall be made of PVC plastic and shall have a smooth (not ribbed or corrugated) inside surface.
 - a. All pipe shall be bell and spigot. The bell shall consist of an integral wall section or an internal plastic sleeve. The solid cross section rubber ring shall be factory assembled on the spigot. Size and dimensions shall be as shown on the plans. Standard laying length shall be 13 feet \pm 1 inch.
 - b. All fittings and accessories shall be as manufactured and furnished by the pipe supplier or approved equal and have bell and/or spigot configurations compatible with that of the pipe.
 - c. Pipes shall be designed to pass all tests described herein at 73° F (\pm 3° F).
 - d. The pipe stiffness shall equal or exceed 10 psi when tested in accordance with ASTM D 2412.
 3. High density Polyethylene (HDPE) pipe shall be manufactured for use in nonpressure storm sewer. The pipe shall be manufactured to meet AASHTO M294, Type 'S' for 12" through 36" and AASHTO MP6-96, Type 'S' OR 'D' for 42" and 48" pipe. The pipe and fittings shall be made from HDPE material and shall have a smooth (not ribbed or corrugated) inside surface.
 - a. All pipe shall be bell and spigot. The bell shall be an integral part of the pipe. The joint shall use a gasket to form a water tight connection meeting ASTM D3212. Gaskets shall be installed in the bell or in the spigot by the manufacturer. The use of Silt tight fittings may be requested in lieu of water tight connection if approved by the engineer.

- b. All fittings shall conform to AASHTO M294 or MP6-95. Fabricated fittings shall be welded on the interior and exterior at all junctions.
- c. Pipe and fittings material shall be high-density polyethylene meeting ASTM D3350.
- d. Installation shall be in accordance with ASTM D2321.
- e. Pipe may be Advanced Drainage System, Inc., N-12 or N-12 HC or Hancor Sure Lok 10-8 pipe.
- f. HDPE end sections are NOT allowed.

C. Pipe Joints:

- 1. Joints for concrete pipe shall be one of the following types:
 - a. Bell and spigot with rubber gaskets.
 - b. Tongue and groove with rubber gaskets.
 - c. Tongue and groove with preformed plastic gaskets.
- 2. Rubber Gaskets shall conform to ASTM Specification C443. Only a neutral agent shall be used as a lubricant. Preformed Plastic Gaskets shall conform to Federal Specification SS-S210, Type I-rope form.
- 3. Field joints of corrugated steel pipe shall maintain pipe alignment during construction and prevent infiltration of side material during the life of the installation. Circumferential and longitudinal strength shall be provided in accordance with the structural joint performance criteria of Division 2, Section 23 of the AASHTO standard specification for Highway Bridges. The bands shall be constructed in such a manner that will effectively engage the pipe ends. Coupling bands shall not be more than 3 nominal sheet thicknesses lighter than the thickness of the pipe to be connected and in no case lighter than 0.052 inches. Bolts and nuts for coupling bands shall conform to the requirements of ASTM Designation: A307.

Bands shall be furnished to lock with the circumferential corrugations, including rerolled end helical pipe. The corrugated bands shall be not less than 7 inches wide for diameter 4 to 36 inches, inclusive, and not less than 10 1/2 inches wide for all other pipe diameters.

NO DIMPLE BANDS WILL BE ALLOWED.

- 4. Joints for PVC pipe must be an integral bell gasketed joint which forms a silt tight joint.

D. Precast Concrete Manhole Sections:

ASTM C913, except that spacing of manhole steps or ladder rungs shall not exceed 12 inches.

- E. Masonry Manholes: Shall be constructed of the following materials:
 - 1. Brick: ASTM C32, Grade MS
 - 2. Mortar of Masonry: ASTM C279, Type M.
 - 3. Aggregate for Masonry Mortar: ASTM C144.
 - 4. Water for Masonry Mortar shall be fresh, clean, and potable.
- F. METALS
 - 1. Frames, Covers, and Grating: Frames, covers, and grating shall conform to AASHTO M-306-07 and shall be of grey iron castings.
 - 2. Manhole Steps: Manhole steps shall be constructed of a number of 3 reinforcing bar encapsulated in polypropylene plastic with a non-skid tread. Finished dimensions of the steps shall be identical to that of malleable iron manhole steps. Steps to have a minimum tread width of 12 inches.

2.02 DELIVERY AND STORAGE

- A. Storm Drainage Pipe: Care shall be exercised in loading and unloading pipe, fittings, specials and castings at all times in order to avoid shock and damage to the materials. Lifting shall be by hoist or by rolling on skids. Dropping will not be permitted. The Contractor shall be responsible for the safe handling of all materials and no damaged materials shall be used in the work. Materials shall be inspected upon arrival at the site, and any damaged or defective materials shall be immediately removed from the site. All materials shall be stored above grade.
- B. Cementitious Materials: Cementitious materials in bags shall be stored in enclosed structures; floors shall be elevated above the ground a distance sufficient to prevent the absorption of moisture.
- C. Metal Items: Metal items, including reinforcing steel, shall be stored above grade in a manner which will not cause excessive rusting or coating with grease or other objectionable materials.
- D. PVC Pipe: PVC pipe shall be stored protected from sun light by means of covering the pipe or storing inside a building or under a covered shed. Any pipe showing signs of prolonged outside storage (i.e., faded exterior color or signs of drying) shall be rejected.
- E. Aggregates: Aggregates shall be stored on areas to prevent the inclusion of foreign material. Aggregates of different sizes shall be stored in separate piles. Stockpiles of coarse aggregate shall be built in horizontal layers not exceeding 4 feet in depth to minimize segregation. Should the coarse aggregate become segregated, it shall be remixed to conform to the grading requirements.
- F. Brick, Concrete Masonry Units and Precast Concrete Manholes: Brick, concrete masonry units and precast concrete manholes shall be handled with care to avoid chipping and breakage, and shall be stored to protect them from contact with the

earth and exposure to the weather, and shall be kept dry until used. Masonry units or precast concrete containing frost or ice shall not be used.

PART 3 - EXECUTION

3.01 DRAINAGE PIPE

- A. Each section of pipe shall be carefully examined before being laid, and defective or damaged pipe shall not be used.
- B. Under no circumstances shall pipe be laid in water, and no pipe shall be laid when trench conditions or weather are unsuitable for such work. Diversion of drainage or dewatering of trenches during construction shall be provided as necessary. Pipe shall be laid true to line and grades indicated and shall rest upon the pipe bed for the full length of each section. Runs of pipe shall be laid with outside bells or grooved ends up-grade beginning at the lower end of the pipe line. Pipe having its grade and/or joint disturbed after laying shall be removed, cleaned, and relaid.
- C. When pipes are protected by head walls or connect with drainage structures, the exposed ends of the pipe shall be placed or cut flush with the inside face of the structure. After the pipe is cut the rough edges shall be smoothed up in an approved manner. All pipe shall be laid so that markings are on top and the inner surfaces abut neatly, tightly and smoothly.
- D. All pipe in place shall be observed by the Engineer before being covered and concealed unless this requirement is waived by the City Inspector and the Design Engineer. Contractor shall clear all pipe of silt debris prior to final acceptance.

3.02 CORRUGATED METAL PIPE JOINTS

- A. Corrugated metal pipe shall be butted to form a smooth joint; the space between the pipe and coupling bands shall be kept free from dirt and grit so that the corrugations fit snugly. The coupling band while being tightened shall be tapped with a soft head mallet of wood, rubber or plastic to take up slack and insure a tight joint. Coupling band bolts and damaged areas of the coupling bands and pipe shall be given a coating of bituminous cement. Pipe on which the asphalt coating has been damaged to such extent that satisfactory field repairs cannot be made will be replaced.

3.03 CONCRETE PIPE JOINT

- A. Joint installation shall be in accordance with the recommendations of the manufacturer of the joint material. Surfaces to receive lubricants, cements or adhesives shall be clean and dry. Gaskets and jointing materials shall be affixed to the pipe not more than 24 hours prior to the installation of the pipe, and shall be protected from the sun, blowing dust and other deleterious agents at all times. Gaskets and jointing materials shall be inspected before installation of the pipe, and any loose or improperly affixed gaskets and jointing materials shall be removed and replaced.
- B. The pipe shall be aligned with the previously installed pipe, and the joint pulled together. If, while making the joint, the gasket or jointing material becomes loose

and can be seen through the exterior joint recess when the joint is pulled up to within one inch of closure, the pipe shall be removed and the joint remade.

3.04 MASONRY WORK

- A. Mortar for Masonry: Mortar for brick masonry, rubble stone masonry, and for bedding cast iron frames in masonry shall be Type M, conforming to ASTM C270.
- B. Mortar for pargetting Masonry Walls: Mortar for pargetting masonry walls below grade shall be Type M, conforming to ASTM C270.
- C. Brickwork: Brick in circular walls shall be laid in all header courses to form full and close mortar joints, ends and sides in one operation. Vertical joints shall be radial from the center. Brickwork around pipe inlets and outlets shall not be allowed. Gaps shall be poured with concrete.
- D. Masonry Structures: Masonry structure walls shall be constructed of brick, concrete masonry units or precast concrete structural sections.

3.05 PRECAST CONCRETE

- A. Walls shall be constructed on a footing of cast-in-place concrete, except that precast concrete base sections may be used for precast concrete structure risers. Precast base sections shall conform to the applicable requirements for precast risers and tops in ASTM C913. Mortar that has hardened to the extent that it cannot be made workable without the addition of water shall not be used. Thickness of parget shall be not less than 1/2 inch. No pargetting will be permitted on the inside of structures. Pargetting will not be required for precast concrete structures. Joint work inside masonry structures shall be smooth.
- B. One course of brick work is allowed for leveling and adjustment. All other adjustments must be poured in place concrete with a maximum height of 24 inches.
- C. For single and double wing catch basins a concrete pad shall be poured 4 inches thick with a minimum slope of 1" per foot away from the curb and gutter and towards the box.

3.06 METAL WORK

- A. Iron and steel shall be formed to shape and size with sharp lines and angles. Shearing and punching shall produce clean true lines and surfaces. Casting shall be sound and free from warp, cold shuts, and blow holes that may impair their strength or appearance. Exposed surfaces shall have a smooth finish and sharp well-defined lines and arises. The necessary rivets, lugs, and brackets shall be provided.

3.07 FIELD TEST

- A. A light held in a drainage structure shall show a practically full circle of light through the pipe when viewed from the adjoining end of the line.
- B. Lines under pavements shall be tested for infiltration by means of a suitable weir or other measurement device as directed by the Owner. When determination of infiltration is not practicable because of dry trench conditions, an exfiltration test shall

be applied by filling with water so that the hydraulic head will be at least 6 inches above the crown of the upper end and of the section being tested. The amount of leakage (infiltration or exfiltration) shall not exceed 100 gallons per inch of diameter per day per mile of pipe.

END OF SECTION

Unofficial

**SECTION 02540
EROSION CONTROL**

PART 1 - GENERAL

1.01 The work specified in this Section consists of furnishing, installing and maintaining temporary erosion controls and temporary sedimentation controls.

1.02 DEFINITIONS

- A. Temporary erosion controls shall include grassing, mulching, watering and reseeding on-site sloped surfaces, providing berms at the top of the slopes and providing interceptor ditches at the ends of berms and at those locations which will ensure that erosion during construction will be either eliminated or minimized.
- B. Temporary sedimentation controls shall include silt dams, traps, barriers and appurtenances at the toe slopes.

PART 2 - MATERIALS

2.01 Hay bales shall be clean, seed free cereal hay type, securely bound.

2.02 Netting shall be 1/2-inch, galvanized steel chicken wire mesh.

2.03 Filter stone shall be crushed stone conforming to the Department of Transportation - State of Georgia-Standard Specifications – Construction of Transportation Systems - 2013 - Table 800.01, Size Number 3.

2.04 Rolled Erosion Control Products:

- A. Mulch Control Netting. A planar woven natural fiber or extruded geosynthetic mesh used as a temporary degradable rolled erosion product anchor loose fiber mulches
Max. Gradient = 5:1 (H:V) in slope application
C Factor = ≤ 0.10 @ 5:1 in slope application
Max Shear stress 0.25 lb/sf in channel application
Min. Tensile Strength ultra-short (3 mo) and short (12 mo) term = 5 lbs/ft
Min Tensile Strength extended term ((24 mo) = 25 lbs/ft
- B. Open Weave textile. A temporary degradable rolled erosion control product composed of processed natural or polymer yarns woven into a matrix, used to provide erosion control and facilitate vegetation establishment.
Max. Gradient = 3:1 (H:V) in slope application
C Factor = ≤ 0.15 @ 3:1 in slope application
Max Shear stress = 1.5 lb/sf in channel application
Min. Tensile Strength ultra-short (3 mo) and short (12 mo) term = 50 lbs/ft
Min Tensile Strength extended term ((24 mo) = 100lbs/ft
- C. Erosion Control Blanket. A temporary degradable rolled erosion control product composed of processed natural or polymer fibers mechanically, structurally, or chemically bound together to form a continuous matrix to provide erosion control and facilitate vegetation establishment.

Netless Rolled Erosion Control Blankets:

Max. Gradient = 4:1 (H:V) in slope application

C Factor = ≤ 0.10 @ 4:1 in slope application

Max Shear stress = 0.5 lb/sf in channel application

Min. Tensile Strength ultra-short (3 mo) and short (12 mo) term = 5 lbs/ft

Single-net Erosion Control Blankets:

Max. Gradient = 3:1 (H:V) in slope application

C Factor = ≤ 0.15 @ 3:1 in slope application

Max Shear stress = 1.5 lb/sf in channel application

Min. Tensile Strength ultra-short (3 mo) and short (12 mo) term = 50 lbs/ft

Min Tensile Strength extended term ((24 mo) = 100lbs/ft

Double-net Erosion Control Blankets:

Max. Gradient = 2:1 (H:V) in slope application

C Factor = ≤ 0.2 @ 2:1 in slope application

Max Shear stress = 1.75 lb/sf in channel application

Min. Tensile Strength ultra-short (3 mo) and short (12 mo) term = 75 lbs/ft

- D. Turf Reinforcement Mat. A rolled erosion control product composed of non-degradable synthetic fibers, filaments, nets, wire mesh, and/or other elements, processed into a permanent, three-dimensional matrix of sufficient thickness. TRMs, which may be supplemented with degradable components, are designed to impart immediate erosion protection, enhance vegetation establishment, and provide long term functionality by permanently reinforcing vegetation during and after maturation. These products are typically used in hydraulic applications such as high flow ditches, channels, steep slopes, stream banks, and shorelines, where erosive forces may exceed the limits of natural, unreinforced vegetation.
- Slope Application max gradient = 0.5:1 (H:V)
Channel Application Max Shear Stress: 5A, B,C as defined in FHWA guidelines
5A = 6.0 lb/sf, 5B = 8.0 lb/sf, 5C = 10.0 lbs/sf
Min. Tensile Strength: 5A, B,C as defined in FHWA guidelines
5A = 125.0 lb/ft, 5B = 150.0 lb/ft, 5C = 175.0 lbs/ft
5A, B,C as defined in FHWA guidelines

PART 3 - EXECUTION

3.01 SEDIMENTATION CONTROL

- A. Silt dams, traps, barriers, and appurtenances shall be installed and shall be maintained in-place for duration of construction.
- B. Hay bales shall be staked with two (2) 1 x 4 wood stakes per bale driven eighteen (18) inches into the ground and finishing flush with the top of the bale.
1. Install two (2) stakes per bale with the long dimension of the stakes parallel to the long dimension of the bale.
 2. Where bales are installed in multiple layers the bales shall be installed with vertical joints staggered and two (2) 1 x 4 wood stakes per bale driven through all layers, full from top of bale to eighteen inches into the ground.
- C. Hay bales which have deteriorated shall be replaced with new materials.

- D. Erosion and sedimentation controls shall be maintained in a condition which will retain unfiltered water.
- E. The Contractor shall construct the sedimentation ponds and control devices prior to clearing and grubbing the site to insure complete silt control. When the silt or the debris level is greater than 1 foot above the bottom of the pond, the Contractor shall remove the silt or debris to restore the proper elevation for the bottom of the pond.
- F. The Contractor shall have all erosion and sedimentation control devices in service and operating properly prior to completion and final acceptance of the contract.
- G. Two widths of silt fence are available, Type A or C (36" height) and Type B (22" height). In order to determine which to use, the project duration, slope gradient, and slope length must be known (See Table 6-13.1 below). Approved silt fence fabrics are listed in the Georgia Department of Transportation list #36. The manufacturer shall have either an approved color mark yarn in the fabric or label the fabricated silt fence with both the manufacturer and fabric name every 100 feet.

TABLE 6-13.1

Land Slope	Maximum Slope Length Behind Fence
Percent	feet
<2	100
2 to 5	75
5 to 10	50
10 to 20	25
>20	15

All silt fence must meet the minimum standards set forth in Section 171- temporary Silt Fence, of the Department of Transportation, State of Georgia, Standard specification, current edition. See Table 6-13.5 for current Georgia DOT silt fence specifications.

3.02 EROSION CONTROL BALNKET INSTALLATION

- A. Prepare a stable and firm soil surface free of rocks and debris. Apply soil amendments as necessary to prepare seedbed. Place fertilizer, water, seed in accordance with manufacture and specification recommendations. Unroll parallel to the primary direction of flow. Ensure that the product maintains intimate contact with the soil over the entire installation. Do not stretch or allow material to bridge over the surface. Staple/stake blanket to soil such that each staple/stake is flush with the underlying soil. Install anchor trenches, seams and terminal ends as specified.
- B. The Upslope Trench, Seams and Terminal Ends may be secure by anchor trench, checks, slots, or staples as outlined in Erosion Control technology Council (ECTC) standards for upslope security.

- C. Staple installation shall be at a rate of 1.7 staples per square yard minimum. Sandy or silty soils may require more. Wet installations may require a more density securing.
- D. If seaming method is used seams shall overlap at least 4" and staples must be placed at sufficient spacing to avoid separation.
- E. Staples must be placed at 4"x 4" spacing on check slots and check seams.
- F. Consecutive rolls shall have overlaps of at least 6" and secured with staples every 1 foot.

3.03 RESPONSIBILITY

- A. The Contractor shall be solely responsible for ensuring that no silt or debris leaves the immediate construction site. Any silt or debris that does leave the immediate site shall be cleaned up and the area disturbed shall be returned to its natural state as directed by the Engineer at the Contractor's expense.
- B. The Contractor has the option to submit additional control measures in the form of shop drawings.

END OF SECTION

Unofficial

**SECTION 02555
WATER DISTRIBUTION SYSTEM**

PART 1 - GENERAL

1.01 GENERAL

Water distribution systems shall be designed to sustain EPD's standards for safe drinking water quality. Special consideration should be given to distribution main sizing, providing for design of multidirectional flow, adequate valving for distribution system control, and provisions for adequate flushing. Distribution systems should be designed to maximize turnover and to minimize residence times while delivering acceptable pressures and flows.

1.02 REFERENCE STANDARDS

A. American Water Works Association (AWWA):

- C104 Cement-Mortar Lining for Ductile-Iron Pipe and Fittings
- C111 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- C151 Ductile-Iron Pipe, Centrifugally Cast
- C300 Reinforced Concrete Pressure Pipe, Steel-Cylinder Type
- C500 Gate Valves 3" - 48" for Water and Other Liquids
- C502 Dry Barrel Fire Hydrants
- C600 Installation of Cast Iron Water Mains
- C651 Disinfecting Water Mains
- C800 Threads for Underground Service Line Fittings
- C900 Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 4 In. - 60 In.

B. American National Standards Institute (ANSI):

- A 21.10 Gray Iron and Ductile Iron Fittings, 2" - 48" for Water and Other liquids
- A 21.11 Rubber Gasket Joints for Cast Iron and Ductile Iron Pressure Pipe Fittings
- A 21.4 Cement Mortar Lining for Cast Iron and Ductile Iron Pipe and Fittings for Water
- A 21.51 Ductile Iron Pipe, Centrifugally Cast in Metal or Sand Lined Molds, for Water or Other Liquids
- B 18.2 Square and Hex Head Bolts and Screws

C. American Society of Testing and Materials (ASTM):

- A 47 Malleable Iron Castings
- A 48 Gray Iron Casting
- A 88 Seamless Copper Water Tube
- A 240 Chromium and Chromium Nickel Stainless Steel Plate Sheet and Strip for Fusion Welded Uni fired Pressure Vessels
- A 307 Low Carbon Steel Externally and Internally Threaded Standard Fasteners
- D 1784 Rigid Poly (Vinyl chloride) Compounds, and Chlorinated Poly (Vinyl Chloride) Compounds
- D 2239 Polyethylene (PE) Plastic Pipe (SDR PR)
- D 2241 Poly Vinyl Chloride (PVC) Plastic Pipe (SDR PR and Class T)
- D 3139 Joints for Plastic Pressure Pipe Using Flexible Elastomeric Seals

D. Rule for Safe Drinking Water, Georgia State EPD: Chapter 391-3-5.10

1.03 DESCRIPTION

- A. All valves of the same type shall be from a single manufacturer. Parts for valves of the same type and size shall be interchangeable. Spare parts shall be furnished where required in the payment items. Special tools required for repacking or disassembling valves shall be provided.
- B. All valves shall open left (counterclockwise).

1.04 SUBMITTALS

- A. Six copies of the manufacturer's drawings and catalog cuts of the following items shall be submitted for approval of the Design Engineer:
 - 1. Pipe
 - 2. Fittings
 - 3. Joints and Couplings
 - 4. Hydrants
 - 5. Valves

1.05 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Materials delivered to the site shall be inspected for damage, unloaded, and stored with the minimum of handling. Store materials on site in enclosures or under protective coverings. Store plastic piping and rubber gaskets under cover

and protect from exposure to direct sunlight. Store materials above ground. Interior of pipe and fittings shall be kept free of dirt and debris.

- B. Pipe, fittings, valves, hydrants, and other accessories shall be handled to insure delivery to the point of installation in sound undamaged condition. If coatings or linings of pipe or fittings are damaged, such pipe or fittings shall be removed from the site and new materials furnished. Pipe shall not be dragged. Rubber gaskets that are not installed immediately shall not be left in the sunlight but shall be stored under cover and protected from exposure to direct sunlight.

PART 2 – PRODUCTS

2.01 POLYVINYL CHLORIDE PIPE (PVC)

- A. IPS Size PVC Pipe: Class 200 SDR 21 - Polyvinyl chloride water main pipe shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe shall be Class 200, SDR 21. The standard laying length shall be 20 ft. ± 1 inch.
- B. DIP Size PVC Pipe: AWWA C-900
 - 1. C-900 polyvinyl chloride water main pipe 4" TO 12" shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe larger than 4" to 12" shall meet the requirements of AWWA C900, "Poly Vinyl Chloride (PVC) pressure pipe." All pipe shall be class 200 pipe and shall meet the requirements of DR14. The standard laying length shall be 20 ft. ± 1 inch. The FM approved pressure class will be used to determine pressure class.
 - 2. C-905 polyvinyl chloride water main pipe 14" to 30" shall be manufactured from compounds conforming to PVC cell classification of 12454B as defined in ASTM D-1784. The integral bell joint system meets the requirements of ASTM D-3139 and utilizes an elastomeric gasket materials conforming to ASTM F-477. All pipe shall be class 200 pipe and shall meet the requirements of DR18. The standard laying length shall be 20 ft. ± 1 inch.
- C. When DIP size PVC pipe is used two 2" PVC pipe shall be SDR 21, minimum pressure class of 200psi.
- D. Pipe shall have integral bell and spigot joints. Provisions shall be made for contraction and expansion at each joint with an elastomeric ring. Threaded or

solvent welded type joints shall not be used. Bell end pipe and couplings with elastomeric gaskets shall meet the requirements of ASTM 3139.

- E. All fittings such as tees, ells, etc. using welded joints shall be factory welded and shall meet the same specifications as the welded bell section. Lubricants shall be non-toxic, shall not promote biological growth. Solvent cemented joints are not allowed for buried pipes.
- F. The Contractor shall install a continuous run of 14 gauge copper tracer wire with underground coating above the top of the PVC pipe 12 inches above the pipe but no deeper than 48 inches below finished grade. The tracer wire shall be suitable for detection with metal pipe location equipment.
- G. All water pipe shall be blue in color and labeled "water" every three feet as a minimum.
- H. Pipe shall carry National Sanitation Foundation (NSF) seal and be factory marked with manufacturer's identification, pipe size, material and pressure rating. Detection tape shall be placed along all PVC water mains.

2.02 DUCTILE IRON PIPE

- A. Ductile iron pipe shall conform to the requirements of ANSI Standard A21.51 and AWWA C151. All pipe shall class 350. Class designations for the various classes of pipe shall be painted on the outside of each joint of pipe. Weights shall be conspicuously painted in white on each joint of pipe after the bituminous coating has hardened.
- B. All joints shall have the same pressure rating as the pipe with which it is used. Joints shall be rubber gasketed push on or mechanical joint. Joints shall meet the requirements of ANSI A21.11 and AWWA C111.
- C. Pipes shall be cement lined in accordance with the latest edition of AWWA Standard C104.

2.03 GALVANIZED STEEL PIPE

- A. This pipe and fittings shall conform to the requirements of ASTM A120. The pipe shall be "standard weight", unless otherwise specified.

2.04 PLASTIC TUBING

- A. Plastic pipe shall conform to all the requirements of the "Specifications for Polyethylene (PE) Plastic Pipe (ADR PR)", as they apply to PE 3306 of ASTM D2239.
- B. The hydrostatic design stress shall be 630 psi for water at 23° centigrade (73.4° F) and 500 psi for water at 37.8° C (100° F).
- C. The polyethylene extrusion compound from which the pipe is extruded shall meet the requirements of Type III, Grade 3, Class C material as described in "Specification for Polyethylene Molding and Extrusion Materials", ASTM D1248, except that melt index shall be determined under a higher temperature than any of the conditions as listed in Section 6(b) of "Method of Test for Measuring Flow Rates of Thermoplastics by Extrusion Plastometer", ASTM D1238. The test condition shall be the same as for condition J, except that the temperature shall be 310° C (590° F), with a load of 12.5 kilograms. Under these conditions the resin shall extrude at a maximum rate of 0.25 grams per ten (10) minutes. The pipe shall be homogeneous throughout and free of visible cracks, holes, foreign inclusions or other defects. The pipe shall be uniform in color, capacity, density, and other physical properties.
- D. The size, the type of plastic pipe material, dimension ratio, commercial standards with which the pipe complies, the manufacturer's name and the National Sanitation Foundation (NSF) seal of approval, shall be conspicuously marked on the outside of the pipe at intervals of not more than five (5) feet.

2.05 FITTINGS

- A. Fittings shall be ductile iron and shall conform to the latest edition of AWWA Standard C110 or C153. The fittings shall be of the lightest class conforming to the pressure rating of the pipelines in which they are installed. In no case shall the fittings be lighter than class 200.
- B. Fittings for galvanized steel pipe shall be malleable iron conforming to ANSI B16.3 except the nipples and couplings shall be the same material as the pipe. All fittings shall be hot dip galvanized in accordance with ASTM A120.
- C. Pipe having mechanical joints or slip-on joints with rubber gaskets shall be used. Lead-tip gaskets shall not be used.
- D. The mechanical joint shall meet the requirements of AWWA C111 and shall have the same pressure rating as the fitting of which it is a part.

- E. Fittings shall be cement lined in accordance with the latest edition of AWWA Standard C104.

2.06 HYDRANTS

- A. All fire hydrants shall conform to AWWA C502.
- B. All fire hydrants shall have a 6" mechanical joint inlet connection and be equipped with a 5 1/4 inch valve, two 2 1/2 inch hose nozzles, and one 4 1/2 inch pumper connection, all with ANSI (National) standard threads. Operating nuts shall be 1 1/2 inch, pentagon type.
- C. All fire hydrants shall be equipped with "O" ring-type stem seals.
- D. All fire hydrants shall be designed for 150 psi working pressure and 300 psi test pressure.
- E. All fire hydrants shall be equipped with a 6" gate valve, complying with other sections of the specifications, installed on the fire hydrant lead between the hydrant and the main.
- F. The Contractor shall paint the hydrant with XO 14 Tractor Red (Federal Safety Color) paint.
- G. All fire hydrants shall be designed such that clockwise rotation of the stem closes the valve and counterclockwise rotation opens the valve. Hydrant covers shall have the word "Open" and an arrow showing the proper rotation of the operating nut cast in or permanently attached.
- H. An independent drain shall be provided, completely draining the hydrant after use. The drain shall be activated to the open position by the closing of the hydrant valve. The drain rod shall be easily cleaned. The drain shall have a protective shield integral with the hydrant base to minimize clogging and prevent undermining.
- I. All working parts of the hydrant shall be easily removed for inspection or servicing without digging or the use of hoists or derricks or special tools. The hydrant cover and stand pipe shall be removable without requiring the water to be shut off.
- J. Each fire hydrant shall be equipped with a ground line mounted breakaway flange and cast iron safety stem coupling specially designed so that upon sustaining

severe impact the hydrant will shear off at the ground line without loss of water in the main.

- K. All fire hydrants shall be Mueller standard or equal as approved by the Engineer.

2.07 METERS

- A. All meters shall be approved first-line products of recognized manufacturers and shall be compatible with the meter reading system currently being used by the water system owner and operator.
- B. Meters, meter materials, and meter test shall conform to applicable AWWA Specifications and shall meet or exceed current AWWA Specifications.
- C. Each meter shall have manufacturer's serial number on the lid.
- D. All body parts as cases, boxes, and lids shall be of bronze composition.
- E. Meters shall be split case, positive displacement type.
- F. The register shall read in U.S. Gallons and shall be hermetically sealed and driven by permanent magnets.

2.08 METER BOXES

- A. The meter box shall be the approved standard product used by the water system owner and operator.
- B. They shall be rectangular and of adequate dimension to accommodate the specified meters.
- C. Boxes shall have cast iron or polyethylene covers labeled "WATER METER".
- D. Boxes for 5/8" by 3/4" meters shall have inside width not less than 10 inches, inside length not less than 15 inches and overall height not less than 12 inches.
- E. Boxes shall be designed and built to withstand traffic loads typical of yard installations.

2.09 VALVES

- A. All valves 2" in diameter and smaller shall be constructed of brass or bronze except that the hand wheel which shall be of malleable iron construction with screwed ends. All valves 2 1/2" in diameter and larger shall have flanged ends for interior service and mechanical joints for buried service unless otherwise approved. They shall be iron body, bronze mounted, except that in the smaller sizes the valves may be all bronze.
- B. Gate Valves:
1. Gate valves smaller than three inches shall meet the requirements of Fed. Spec. WW V 54, Class A, 125 pounds.
 2. Gate valves three inches and larger shall have nonrising stems and shall meet the requirements of AWWA Standard C 500. Valves for lighter pressures than the AWWA Standard shall meet the requirements of the above specifications except that the requirements for metal thickness and strengths and structural designs shall be adjusted as required to meet hydrostatic test pressures not less than 150 psi.
 3. All gate valves shall have standard stuffing box seals. Bonnet bolts, studs and nuts shall be cadmium plated. Seating devices shall be bronze to iron or bronze to bronze. The glands shall be bronze or bronze bushed. Gland bolts and nuts shall be bronze.
 4. All gate valves shall be of the double disc or wedge type. The wedge or disc shall be totally encapsulated in rubber. The sealing rubber shall be permanently bonded to the wedge or disc to meet ASTM tests for rubber metal bond ASTM D249.
 5. Valves to have two inches square operating nut, with the exception that gate valves in altitude valves pits shall have hand wheels.
 6. Valves buried in ground or located in vaults or structures shall have suitable extensions for socket operation with top of operating nut located two feet below finished grade maximum.
 7. Any valve installed in a vault readily accessible for entry shall be equipped with handle wheels in lieu of operating nuts. No hand wheels are allowed in buried valves.

C. Check Valves:

1. Check valves 2" through 24" shall be iron body, bronze mounted swing check valves meeting the requirements of AWWA Standard C508 76.
2. The check valve shall be metal to metal or composite to metal seat construction with flange ends or screw and coupled ends.

D. Altitude Valves:

1. All altitude valves furnished for use in the systems shall be equipped for showing at all times the position of the valve. Said altitude valves shall be of the size specified on the drawings and suitable for the use intended.
2. The Contractor shall supply the services of a qualified manufacturer's representative to check and calibrate each altitude valve installation for proper working pressure and sequence.

E. Air Release Valves

1. Air release valve shall have all bronze body and bonnet. They shall be the direct acting type.
2. Valves shall be hydrostatically tested to at least 150 psi.
3. The valve shall have stainless steel floats and an internal coating with rust inhibitors.

2.10 BACKFLOW PREVENTERS

- A. The backflow preventers used shall be those specifically designed for use in connections when the danger from backflow presents a health hazard.
- B. All domestic backflow preventers shall be of the reduced pressure type or double check type as shown on plans. All fire protection system backflow preventers shall be of the double check detector type.
- C. Backflow preventers 3/4" to 2" shall be Ames LF 2000 B, LF 4000 B, or equal meeting or exceeding the following specifications:

Mainline Case – Bronze or Copper Alloy
Working Parts Bronze & Stainless Steel

Springs Stainless Steel
Diaphragms Buna N and Mylar
Valve disc Silicone Rubber
Check Valve Enclosure Glass Reinforced Plastic
Maximum Rated Working Pressure 175 psi
Temp. Range 33° 180°F

- D. Backflow Preventers 2½" to 10" shall be Ames M200, M400, or LFM300 Lead Free or equal meeting or exceeding the following specifications:

Body 8" 10" Stainless Steel
Body 2½" 6" Stainless Steel
Working Parts Stainless Steel
Springs 2½" 6" Stainless Steel
Springs 8" 10" Stainless Steel
Valve Disc Silicone Rubber
Maximum Rated Working Pressure 175 psi
Temp. Range 33° 140°F

- E. Backflow preventers larger than 10" shall be designed for conditions that do present a health hazard. It shall be the reduced pressure type and depending on the application, may require detection of leaks or unauthorized use. Detectors above 10" shall be submitted for approval. The submittal shall include complete shop drawings. The submittal will be reviewed based on the product's ability to meet the needs of the project and the Owner.

PART 3 – EXECUTION

3.01 GENERAL

- A. All valves shall be carefully mounted in their respective positions free from distortion and strain. All valves shall be properly packed and left in satisfactory operating condition at the completion of the project.
- B. Valve box, cover, and the concrete pad shall be installed with each valve as shown in miscellaneous details.

3.02 PIPE INSTALLATION

- A. PVC pipe shall be installed in accordance with the Uni Bell Plastic Pipe Association guide for installation of polyvinyl chloride plastic pressure pipe for municipal water main distribution system and the printed recommendations of the manufacturer.

- B. Ductile iron pipe shall be installed in accordance with AWWA C600. Concrete pipe shall meet the latest edition of AWWA Standard C300.
- C. Pipeline alignment and gradient shall be straight or shall follow true curves as near as practicable. Curvature in pipelines, where required, shall be well within the allowable laying radius, horizontal and vertical.
- D. Excavation, cleaning, laying, jointing and backfilling shall follow as closely as is possible so as to progress the work. In no case shall pipe be left in the trench overnight without completing the jointing. The completed pipeline shall not be left exposed in the trench unnecessarily, and the Contractor shall backfill and compact the trench as soon as is possible after laying and jointing is completed. Each day at the close of work, and at all times when laying is not in progress, the exposed end of the pipeline in the trench shall be closed with a head or barrier of wood or metal. If at any time it becomes necessary to cover the end of any uncompleted pipe line with backfill, the end of that pipe shall be closed with a mechanical joint plug.
- E. The Contractor shall keep exposed ends of pipe properly plugged during laying to prevent dirt and other materials from entering the line, and shall also, before the system is accepted, thoroughly clean all lines.
- F. Thrust Blocks (Reaction Blocking) shall be provided as specified AWWA C600. All exposed pipes, valves, hydrants, etc., shall be securely strapped and all ends and bends braced.
- G. Other means of pipe restraining in addition to thrust blocking shall include "mega lug" utilization and all threads bolted through fittings in accordance with AWWA C600. Thrust blocking may not be eliminated with the use of joint restraint.
- H. Mechanical joints shall be made only by experienced mechanics. Sockets and spigots shall be washed with soapy water before slipping gland and gasket over spigot. The spigot shall be inserted in the socket full depth. The gasket shall be brushed with soapy water, and pushed into position making sure the gasket is evenly seated in the socket. The gland shall then be properly positioned for compressing the gasket. All bolts and nuts shall be tightened with a torque wrench to a uniform, permanent tightness. Bolts shall be tightened alternately 180 degrees apart. Sockets, spigots, glands and bolts shall be kept clean and wet with soapy water until each joint is completed.
- I. All water distribution mains shall have a minimum 36" of cover.

3.03 INSTALLATION OF MAINS

- A. Water lines must not be installed in contaminated areas such as sanitary landfill or dump areas.
- B. No water main or pipe shall pass through or come into contact with any part of a sewer or sewer manhole.
- C. A continuous and uniform bedding shall be provided in the trench for all buried pipe.
- D. Backfill material shall be tamped in layers around the pipe and to a sufficient height above the pipe to adequately support and protect pipe.
- E. Thrust restraint shall be provided at all points where hydraulic thrust may develop. This will include providing reaction blocking, tie rods or joints designed to prevent movement to all bends, tees, valves, plugs, hydrants and other points where thrust may develop. Additional restraints may be necessary on fusible pipe at the connection to appurtenances or transitions to different pipe materials to prevent separation of joints. The restraint may be provided in the form of an anchor ring encased in concrete or other methods as approved by the Division.
- F. Whenever a state route or heavily traveled off-system road or a railroad is crossed, the agency that has jurisdiction over the road or the railroad must be notified, prior to the installation of the mains. At the crossing, a steel casing with sufficient diameter must be jacked and bored to accommodate the carrier pipe. Any free boring at low traffic city streets and county roads must conform to the applicable local and/or state requirements.
- G. Installation of water lines and appurtenances along highways, streets and roadways must comply with the applicable regulations of, and permits issued by, the Georgia Department of Transportation, local County and Municipality with reference to construction operations, safety, traffic control, road maintenance and repair.
- H. When non-metallic pipe is installed, detection tape shall be installed.
- I. Any pipe, pipe fittings, plumbing fittings or fixtures, solder, or flux used in the installation or repair of a public water system must meet the new definition of lead free meaning: (a) not containing more than 0.2 percent lead when used with respect to solder; and (b) not more than a weighted average of 0.25 percent lead

when used with respect to the wetted surfaces of pipes, pipe fittings, plumbing fittings, and fixtures.

- J. If soils are found to be aggressive, the water main shall be protected by encasement in polyethylene, the provision of cathodic protection (in very severe instances), or the use of corrosion resistant water main materials.
- K. Stones found in the trench shall be removed for a depth of at least six (6) inches below the bottom of the pipe.
- L. All distribution mains shall be provided with sufficient earth and other suitable cover to prevent freezing. This shall be not less than 24 inches measured above the top of pipe.

3.04 FIRE HYDRANT INSTALLATION

- A. Fire Hydrants shall meet the current AWWA Standard C502.
- B. All fire hydrants shall have 36" minimum pipe cover provided for the branch supply line.
- C. Each fire hydrant shall be set on a stable foundation at least 18 inches square and 6 inches thick and shall be blocked against the end of the trench with concrete and anchored.
- D. Hydrant drainage shall be provided by installing around the hydrant at least 7 cubic feet of gravel or crushed stone below the top of the hydrant supply pipe.
- E. The barrel of the fire hydrant shall be set plumb (perpendicular to the ground) with the lowest discharge outlet at least fifteen (15) inches high but no higher than 24 inches above finished grade. No fire hydrant shall be installed within 10 feet of any private driveway. Hydrants shall be located no closer than 5 feet of a curbing and no further than 12 feet of the curbing.
- F. Immediately before installation of a hydrant, the following operations shall be performed:
 - 1. The hydrant shall be thoroughly inspected.
 - 2. The hydrant interior shall be thoroughly cleaned.

3. The hydrant shall be opened and closed to determine that all parts are in proper working order, with valves seating properly and the drain valve operating freely.

3.05 HYDROSTATIC TEST

- A. Upon completion of backfilling operations and not less than seven (7) days after the last concrete blocking anchor has been poured, the pipe system shall be subject to hydrostatic test.
- B. Pressure and leakage tests shall be performed in accordance with the latest edition of AWWA Standard C600.
 1. For PVC: Allowable leakage shall be no greater than as calculated in $L=ND(P)^{1/2}/7,400$ where L is allowable leakage in gallons/hour, N is the number of joints in the length of pipe tested, D is the nominal diameter of the pipe in inches and P is average test pressure during the leakage test in pounds per square inch (psi-gauge).
 2. For DIP: Allowable leakage shall be no greater than as calculated in $L=SD(P)^{1/2}/133,200$ where L is allowable leakage in gallons/hour, S is the length of pipe tested in feet, D is the nominal diameter of the pipe in inches and P is average test pressure during the leakage test in pounds per square inch (psi gauge).
- C. The system shall be filled with water and all air expelled.
- D. The Contractor shall pressurize the system to 1.5 times the working pressure or 150psi, whichever is greater, at the highest point in the system.
- E. The test pressure shall be maintained for two hours.
- F. If the pressure cannot be maintained, the cause shall be determined, corrected and test repeated until successful.

3.06 LEAKAGE TEST

- A. Following the pressure test, the system shall be subject to a leakage test.
- B. Leakage shall be defined as the quantity of water that must be supplied into the pipe to maintain the design working pressure after all air in the pipe line has been expelled and the pipe has been filled with water.

- C. Leakage shall not exceed the quantity determined by the formula given below:

$$L = ND(\text{Square Root of } P)/7400$$

WHERE	L	=	allowable leakage in gallon/hr.
	N	=	number of joints in pipe line
	D	=	nominal diameter of the pipe inches
	P	=	average test pressure during leakage test in psig

- D. If leakage exceeds the allowable rate, leaks shall be found and repaired and the test repeated until successful.

3.07 CORROSION CONTROL

- A. General:

1. All treated water shall be evaluated to ensure that water quality parameters and characteristics are optimized to obtain the desired water stability throughout the distribution systems of a water supply.
2. The primary approaches to internal corrosion control in drinking water systems are to modify the water chemistry to make it less corrosive and to encourage formation of passivating films on the contacting surface. This is typically accomplished through pH and/or alkalinity adjustment or through the addition of a corrosion inhibitor. Most corrosion control treatment will be beneficial for reducing corrosion of lead, copper, iron, steel and galvanized pipe.
3. Where adjustments to water quality parameters such as chlorine residual, pH, alkalinity or carbonate buffer strength prove insufficient to control corrosion rates, the use of corrosion inhibitors should be considered. Orthophosphate is particularly effective for this purpose in most situations.
4. To control corrosion, certain basic approaches can be utilized:
 - i. Using pipe materials and designing the system so it is not corroded by a given water;
 - ii. Modifying the water quality so it is not corrosive to the pipe material; and
 - iii. Placing a protective barrier or lining between the water and the pipe.

B. Corrosion Control Study:

1. Monitoring/testing equipment shall be provided for determining the effectiveness of stabilization treatment and the chemical residuals at the entry point and in the distribution system, including an acceptable pH probe that utilizes three standards for calibration.
2. A sample site location plan for water quality parameter monitoring. Entry point and distribution system samples shall be collected for water quality data and other system information pertinent to achieving optimum corrosion control. The frequency of sampling and number of sites shall be determined by the Division. The water quality parameters include:

pH	Conductivity
Temperature	Hardness
Alkalinity	Iron
Calcium Manganese	Sulfate Aluminum
Ammonia	Dissolved Oxygen
Total Phosphorus	Natural Organic Matter
Chloride	Total and Free Chlorine Corrosion Control Inhibitors
	Total & Free Chlorine (Orthophosphate, Silica)

3. A summary of all water quality parameter monitoring results. These results should be evaluated considering the location of sample sites within the distribution system and used as the basis for considering corrosion control treatment options.
4. A desktop evaluation utilizing corrosion control computer modeling or regulatory guidance. The evaluation shall recommend optimal corrosion control treatment and water quality parameter performance requirements for the selected treatment.
5. Identification of possible limitations and secondary impacts for treatment options.

C. Adjustments to water quality

1. pH adjustment by the addition of lime, caustic soda or soda ash in order to stabilize the water with regard to calcium carbonate. Advantages of aeration for iron, H₂S or CO₂ removal should be balanced against the fact that dissolved oxygen is a corrosive agent.

2. pH/Alkalinity adjustment includes adding a base or similar chemical to the water to increase pH to a level where the practical lead or copper solubility lowers, acids are neutralized, and less soluble metal compounds are formed on the pipes. Treatment shall be designed to operate within the optimum pH range and alkalinity concentration.
 - i. Caustic Soda- Caustic soda (sodium or potassium hydroxide) will increase the pH with minimal effect on alkalinity and dissolved inorganic carbon (DIC). A stable pH is very difficult to provide when using caustic soda on water having low alkalinity. Caustic soda can cause severe burns and damage the eyes.
 - ii. Soda Ash- Soda ash (sodium or potassium carbonate) will increase the alkalinity, DIC, and moderately increase the pH. Soda ash is relatively safe to handle compared to caustic soda.
3. Aeration
 - i. Aeration can increase the pH and reduce excess DIC by removing carbon dioxide. Aeration is most effective when there is an adequate carbon dioxide concentration in the water.
 - ii. The carbon dioxide content of aggressive water may be reduced by aeration.

3.08 DISINFECTION

- A. Water mains and accessories shall be disinfected in accordance with "Rules for Safe Drinking Water" as published by the Georgia Environmental Protection Division.
- B. The mains shall be flushed into the storm drainage system before disinfecting by maintaining a velocity of at least 2.5 feet per second for a period of ten minutes.
- C. The continuous feed method may be used for any size main or system where satisfactory quantity and quality water is available. The tablet method shall not be acceptable.
- D. Following disinfection of the water system, the system shall be flushed until chlorine concentration is less than 1 milligram per liter. Flushing shall not allow chlorinated water to be discharged into the storm sewer system without first allowing the chlorine in the system to dissipate. The contractor Shall use a Pollard

Water LPD-250 or equal equipment along with LPD-Chlor tablets (Sodium Sulfate or Ascorbic Acid) to de-chlorinate the water using 1 tablet per 2000 gallons of water minimum prior to flushing, then after adequate testing, discharge the de-chlorinated water to the storm sewer system or onto the land surface. During the de-chlorination flushing the flow through the LPD 250 will be maintained at between 200 and 1200 GPM. No flows for de-chlorination or flushing will not be allowed outside this flow specification. The contractor may apply to the owner of the sanitary sewer system to obtain permission to discharge the chlorinated water into the sanitary sewer system for a fee. The contractor shall be charged at the going rate per gallon for treating the water discharged to the sanitary sewer system.

- E. When new water mains are placed in or returned to service, they shall be disinfected in accordance with the latest addition of AWWA Standard C651.
1. Before the main is chlorinated, it shall be filled to eliminate air pockets and shall be flushed to remove particulates. A flushing velocity of not less than 2.5 feet/second is usually maintained in pipe sizes less than 24 inches in diameter. For larger diameter mains, an alternative to flushing, such as broom-sweeping of the main, is acceptable prior to chlorinating the main.
 2. During disinfection of the water mains, an appropriate cross-connection control device, consistent with the degree of hazard, shall be provided for backflow protection of the active distribution system.
 3. The quality of the water used during the disinfection procedures shall meet the required drinking water standards.
 4. The chlorine solution used for the “continuous feed” method of disinfection of water mains shall have a free chlorine residual concentration not less than 25 mg/L. This heavily chlorinated water shall be retained in the main for at least 24 hours, during which time all valves and hydrants shall be operated to ensure disinfection of the appurtenances. At the end of the 24-hour period, the treated water in all portions of the main shall have a residual of not less than 10 mg/L free chlorine. Re- chlorinate if required results are not obtained on all samples.
 5. After the applicable retention period, the heavily chlorinated water must not be disposed in a manner that will harm the environment. Neutralizing chemicals, such as Sulfur Dioxide, Sodium Bisulfite, Sodium Sulfite or Sodium Thiosulfate can be used to neutralize the chlorine residual remaining in the water to be wasted.

6. Flush all lines until residual is equal to existing system. After final flushing and before the water main is placed into service, water samples shall be collected from the main and tested for microbiological quality in accordance with the Georgia Rules for Safe Drinking Water, Chapter 391- 3-5. The laboratory results must show the absence of coliform organisms in the water. Reflush and re-disinfect the lines, as necessary, until satisfactory bacteriological results are obtained.
- F. When cutting into existing mains, for abandonment or reuse, the pipes must be disinfected.
- a. All water mains that are depressurized and/or wholly or partially dewatered shall be disinfected in accordance with the current AWWA C651 Standards, including swabbing with hypochlorite solution, flushing, and/or slug chlorination as appropriate. Leaks or breaks that are repaired with clamping devices while the mains remain full of water under pressure may require no disinfection.
1. Chlorine required to produce 25 mg/L concentration in 100 feet of pipe by diameter:

Pipe Diameter (inches)	100% Chlorine		1% Chlorine Solution	
	(lbs.)	(g)	(gal)	(L)
4	0.013	5.9	0.16	0.6
6	0.030	13.6	0.36	1.4
8	0.054	24.5	0.65	2.5
10	0.085	38.6	1.02	3.9
12	0.120	54.4	1.44	5.4
16	0.217	98.4	2.60	9.8

Note: 1% chlorine solution may be prepared with sodium hypochlorite (contains 5% to 15% available chlorine) or calcium hypochlorite (contains approximately 65% available chlorine by weight). To prepare 1% chlorine solution using calcium hypochlorite, add one (1) pound (454 grams) of calcium hypochlorite in approximately 8 gallons of water.

2. Amounts and types of chemicals advised to be used for neutralizing various residual chlorine concentration in 100,000 gallons of water:

Residual Chlorine Concentration	Chemicals							
	Sulfur Dioxide (SO ₂)		Sodium Bisulfate (NaHSO ₃)		Sodium Sulfite (Na ₂ SO ₃)		Sodium Thiosulfate (Na ₂ S ₂ O ₃ ·5H ₂ O)	
	Lb.	Kg	Lb.	Kg	Lb.	Kg	Lb.	Kg
1	0.8	0.36	1.2	0.54	1.4	0.64	1.2	0.54
2	1.7	0.77	2.5	1.13	2.9	1.32	2.4	1.09
10	8.3	3.76	12.5	5.67	14.6	6.62	12.0	5.44
50	41.7	18.91	62.6	28.39	73.0	33.11	60.0	27.22

- G. Surface water crossings, both over and under water, may present special concerns and should be discussed with the Division before the final plans are prepared.
1. At above water crossings, the pipe shall be adequately supported and anchored, protected from vandalism, damage and freezing, and accessible for repairs or replacement. At underwater crossings, a minimum of 3 feet of cover shall be provided over the pipe.
 2. The installation of ductile iron pipe with restrained push-on joints and encased in concrete, may be considered with the prior approval of the Division. Otherwise, when crossing water courses which are greater than 15 feet in width, only pipes of special construction, having flexible, watertight joints shall be installed.
 3. Valves shall be provided at both ends of water crossings so that the section can be isolated for testing or repair; valves shall be easily accessible and not subject to flooding. Sampling taps shall be installed at each end of the crossing, and permanent taps shall be made for testing and determining leaks.
- H. There shall be no physical connection between the distribution system and any pipes, pumps, hydrants, or tanks whereby unsafe water and other contaminating materials may be discharged or drawn into the system.
1. The approval of the Division shall be obtained for interconnections between potable water supplies.
 2. Neither steam condensate nor cooling water from engine jackets or other heat exchange devices shall be returned to the potable water supply
- I. Water services and plumbing should conform to relevant local and/or state plumbing codes, or to the Standard Plumbing Code, as applicable within the

jurisdiction in which the system is located. The product that is used for the service line must be listed as being certified for conformance with the NSF Standard 61.

1. All new and existing services connected to community and non-transient noncommunity water systems shall be individually metered.
 2. Individual booster pump(s) shall not be allowed for any individual residential service from the public water supply mains. Where permitted for other types of services, booster pumps shall be designed in accordance with AWWA standards.
- J. Water loading stations present special problems since the fill line may be used for filling both potable water vessels and other tanks or contaminated vessels. To prevent contamination of both the public supply and potable water vessels being filled, the following principles shall be met in the design of water loading stations:
1. there shall be no backflow to the public water supply;
 2. the piping arrangement shall prevent contaminant being transferred from a hauling vessel to others subsequently using the station; and
 3. hoses shall not be contaminated by contact with the ground.

3.09 BACTERIOLOGIC TESTS

- A. Bacteriological testing shall be performed after the repairs are complete. However, depending upon the circumstances, the water main may be returned to service prior to completion of testing to minimize the time the customers are out of service.
- B. Tests shall be performed to detect the presence of coliform organisms on samples taken from the end farthest from the point at which chlorine was introduced into the system and at 1000 ft. intervals.
- C. The bacteriological sample shall meet the requirements established by EPD for suitable disinfection for human consumption.
- D. If unsatisfactory samples are produced, disinfection shall be repeated until samples are satisfactory.

END OF SECTION

**SECTION 02611
BASE AND PAVING**

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

- A. When used in this section, the term "Standard Specifications" shall mean the DEPARTMENT OF TRANSPORTATION, STATE OF GEORGIA STANDARD SPECIFICATIONS – CONSTRUCTION OF TRANSPORTATION SYSTEMS 2013 or later edition.
- B. American Society for Testing and Materials (ASTM):
 - D-698 Test for, Moisture-Density Relations for soils
 - D-1557 Test for, Moisture-Density Relations for soils

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Base: The base shall conform to Section 310, Graded Aggregate Construction, of the Standard Specifications.
- B. Prime: The prime coat shall be RC-70 and shall conform with Section 412, Bituminous Prime, of the Standard Specifications.
- C. Tack Coat: The tack coat shall be RC-70 and shall conform with Section 413, Bituminous Tack Coat of the Standard Specifications.
- D. Intermediate Course (Binder): The intermediate course shall be Superpave 12.5 mm or 19 mm Asphaltic Concrete and shall conform with Section 402, Hot Mix Asphaltic Concrete Construction of the Standard Specifications.
- E. Crack Relief Interlayer: The crack relief interlayer shall be OGI Asphaltic Concrete and shall conform with Section 415, Asphaltic Concrete Open Graded Crack Relief Interlayer of the GDOT Standard Specifications and Special Provisions.
- F. Surface Course - Asphalt Plant Mix: The surface course shall be either Superpave 9.5 mm or 12.5 mm Asphaltic Concrete and shall conform with Section 402, Hot Mix Asphaltic Concrete Construction, of the Standard Specifications.
- G. Paint: Paint for pavement marking shall be in conformance with MUTCD publication and shall conform with Section 870, Paint, of the Standard Specifications.
- H. Concrete Curb and Gutter: Shall conform to Section 441 -Concrete Curb, Gutter, Combination Curb and Gutter, Header, and Median of the Standard Specification.

PART 3 - EXECUTION

3.01 COMPACTION

- A. Sub-grade: The upper 24 inches of sub-grade soils in all cut areas and all fill areas that are to receive new pavements shall be scarified and re-compacted until a density equivalent to 95% standard Proctor maximum dry density in accordance with ASTM D698 has been obtained.
- B. Base: All base shall have minimum compaction of 100% of the maximum density obtained by the test procedure present in ASTM D1557, Method D (Modified Proctor). The maximum permissible lift thickness shall be 6 inches (compacted). The contractor shall be required to perform all work necessary to meet the minimum compaction requirements.
- C. Moisture Content: Compaction shall be performed only when the moisture content of the soil is within 4% of the optimum moisture content at the time of compaction as determined by ASTM D698. Soils are to be dried prior to compaction by discing and aeration. An Independent Testing Laboratory shall determine if soils are within the optimum moisture content. The contractor shall be required to perform all work necessary to meet the minimum compaction requirements.

3.02 CONSTRUCTION

- A. Preparation of Sub-grade: Prior to placing of base and pavements, the construction of all utility lines (water, sewer, power, gas, etc.) which are to be placed under the pavements shall have been completed.
- B. Base: The base course shall be constructed in accordance with Section 310 of the Georgia Department of Transportation Standard Specifications to the compacted thickness specified.
- C. Prime: The prime coat shall be applied at a rate of 0.25 gallons per square yard and in accordance with Section 413 of the Georgia Department of Transportation Standard Specifications.
- D. Tack Coat: The tack coat shall be applied at a rate of 0.10 gallons per square yard and in accordance with Section 413 of the Georgia Department of Transportation Standard Specifications.
- E. Crack Relief Interlayer: The crack relief interlayer shall be constructed in accordance with GDOT Section 415 of the Georgia Department of Transportation Standard Specifications and Special Provisions.
- F. Intermediate and Surface Course - Asphalt Plant Mix: The intermediate and surface courses shall be constructed in accordance with Section 402 of the Georgia Department of Transportation Standard Specifications to the thickness indicated. All thicknesses are compacted.
- G. Painting Stripe: Pavement striping is required and shall be in accordance with Georgia Department of Transportation MUTCD publication.
- H. Existing pavement which has pavement markings damaged by this construction shall be repainted.

- I. Concrete Curb and Gutter: Shall be constructed in accordance with Section 441 of the Georgia Department of Transportation Standard Specification.

3.03 TESTING

- A. Compaction testing shall be performed by an approved testing laboratory. Subgrade and base compaction testing shall be performed at a spacing not to exceed 500' staggered for the entire length of the street. On streets shorter than 1,000' the testing spacing shall reduce to 300' and in no case will be less than three tests per street, equally spaced. The Design Engineer and Construction Inspector shall be provided copies of the test information prior to placement of base material or final pavement.
- B. Prior to the installation of any base material a test roll must be performed along the entire roadway length, both sides of the road. The test roll shall be performed utilizing an 18 C.Y. tandem axle dump truck loaded with at least 12 C.Y. of soil or gravel. The same test roll will be required on the base material prior to beginning pavement installation. The Design Engineer and Construction Inspector shall be present during the test roll.
- C. Prior to beginning the installation of any asphalt pavement, the base material shall be tested to determine thickness and graded cross section of the base material. The contractor shall provide labor and equipment to auger through the base material to check to ensure the thickness specified in the plans and specifications has been achieved. In addition, the cross slope of the base and the depth below the gutter face shall be checked, utilizing a string line, to ensure proper crown and asphalt depth at the edge has been achieved with the base grading. If the depth of base material is insufficient the base present will be removed, the subgrade lowered, and adequate base material will be replaced to achieve the required thickness. If the cross slope or edge depth is determined to be less than the specified thickness, the area will be rejected until the area is re-graded to the slope and the thickness specified on the approved plan.
- D. The Owner at his option may check the thickness of the asphalt pavement and base material after the installation is complete. If the Owner finds the materials to be less than specified, the contractor/developer shall take necessary measures to meet the requirements of the approved plans and specifications.
- E. Prior to any striping being performed, the contractor shall prepare a striping plan for approval by the Construction Inspector.

3.04 EXISTING PAVEMENT RESTORATION

- A. Pavement damaged due to construction shall be patched or replaced in accordance Section 400 of the Georgia Department of Transportation Standards and Specifications.
- B. Pavement damaged by new utility trenches shall be restored in accordance with the pavement removal and replacement details. Any pavement removed must be disposed of by the contractor at a permitted site.

- C. Existing inlets, manholes, or valve boxes shall be adjusted by the Contractor to the new grade lines and elevations. All adjustments to structures in areas proposed for pavement shall be accomplished prior to construction of the surface course.
- D. Adjustment to grade of existing frames shall include raising or lowering the upper portion of the structure, including any necessary sleeve extensions, adjustable manhole rings, gaskets, mortar, masonry, or other approved material, to bring the frame to the required grade.

3.05 STRIPING OF PAVEMENT MARKINGS

- A. Striping shall consist of furnishing and applying traffic markings with paint or thermoplastic in accordance with the contract drawings and specifications, and the requirements of the current Federal and State "Manual On Uniform Traffic Control Devices."
- B. Thermoplastic Plastic Stripe shall consist of solid or broken (skip) lines, words and/or symbols of the type, color and the location shown on the plans. It is the intent of these specifications that short lines which are defined to be crosswalks, stop bars, arrow symbols and crosshatching shall be extruded. All other lines, unless otherwise specified, shall be sprayed.
- C. Cleaning: All pavement areas to be striped shall be thoroughly cleaned. Cleaning may be accomplished by the use of hand brooms, rotary brooms, air blasts, scrapers or other approved methods which leave the paving surface thoroughly clean and undamaged. Particular care shall be taken to remove all vegetation and road film from the area to be striped.
- D. Warranty: The Contractor shall transfer to the Governing Authority the warranty on Thermoplastic materials issued by the Manufacturer.

END OF SECTION

**SECTION 02616
PAVEMENT REMOVAL AND REPLACEMENT**

PART 1 - GENERAL

1.01 DEFINITION

- A. When used in this section, the term "Standard Specifications" shall mean the DEPARTMENT OF TRANSPORTATION, STATE OF GEORGIA STANDARD SPECIFICATIONS FOR CONSTRUCTION OF ROADS AND BRIDGES, 2001 Edition or later edition, unless amended herein.

1.02 DESCRIPTION

- A. Related Work Specified Elsewhere:
 - 1. Trench Excavation, Backfill and Compaction-Section 02221.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Base: Granular material to meet the following gradation:

<u>SIEVE SIZE</u>	<u>PERCENT PASSING BY WEIGHT</u>
1-1/2"	100
3/4"	60-100
10	30-55
60	8-35
200	5-20

- B. Concrete: 3000 psi compressive strength
- C. Prime Coat: RC-70 Georgia DOT Specifications
- D. Asphalt Surface Course: The surface course shall be either Superpave 9.5 mm or 12.5 mm Asphaltic Concrete and shall conform with Section 402, Hot Mix Asphaltic Concrete Construction, of the Standard Specifications.

PART 3 - EXECUTION

3.01 CONCRETE PAVEMENT REPLACEMENT (DRIVEWAYS)

- A. Existing pavement shall be removed to a minimum of 12 inches on either side of the trench.
- B. Following trench backfilling and compaction, the depth of concrete pavement replaced shall match the existing pavement or shall be a minimum of 6 inches thick, whichever is greater.
- C. Joints and finish of the concrete slab shall match existing pavement.

- D. Pavement replacement for each driveway shall be accomplished with one pour. Deviation must be approved by the Engineer.
- E. All joints shall have waterproof sealer to avoid water intrusion and deterioration of the patch.

3.02 CONCRETE PAVEMENT REPLACEMENT (ROADWAY)

- A. Existing pavement shall be removed to a minimum of 12 inches on either side of the trench.
- B. A minimum 8 inch concrete slab containing black dye in the top 2 inches (minimum) shall be placed extending 12 inches on either side of the trench and on undisturbed soil.
- C. Depth of concrete pavement replaced shall match the existing pavement or shall be a minimum of 8 inches thick, whichever is greater.
- D. Joints and finish of the slab shall match existing pavement. Joints shall have expansion material between old and new paving.
- E. All slabs shall be installed in one pour unless directed otherwise by the Engineer. If construction joints are required, measures must be taken to avoid deterioration of the patch later by water intrusion.

3.03 ASPHALT PAVEMENT REPLACEMENT

- A. Existing pavement shall be removed to a minimum of 12 inches on either side of the trench.
- B. Granular base material shall be placed to a minimum depth of 8 inches and compacted to 95% maximum dry density following trench backfilling and compaction.
- C. If so directed by the Engineer the base shall be a 6 inch concrete slab extending 12" on either side of the trench and on undisturbed soils, then a 2 inch asphalt surface course shall be placed after a prime coat is applied to the concrete slab at the rate of 0.25 gallons per square foot to bring the paving to grade.

3.04 MAINTENANCE OF SURFACE

- A. Pavement damage due to settlement of backfill: Repair for period of bond.
- B. Depressions more than 6 inches deep in aggregate surfaced areas: Fill to grade for period of bond.

3.05 TESTING

- A. Certified laboratory reports shall be required to ensure the subgrade has been compacted to 95% and the base compacted to 100% standard proctor.

END OF SECTION

**SECTION 02650
SANITARY SEWERS**

PART 1 – GENERAL

1.01 APPLICABLE STANDARDS

A. American National Standards Institute (ANSI):

- A21.4 Cement Mortar Lining for Cast Iron and Ductile Iron Pipe and Fittings for Water
- A21.6 Cast Iron Pipe Centrifugally Cast in Metal Molds, for Water or Other Liquids
- A21.11 Rubber Gasket Joints for Cast Iron and Ductile Iron Pressure Pipe and Fittings
- A21.51 Ductile Iron Pipe, Centrifugally Cast in Metal Molds or Sand Lined Molds, for Water or Other Liquids

B. American Society of Testing and Materials (ASTM):

- A48 Gray Iron Castings
- C12 Installing Vitrified Clay Sewer Pipe
- C425 Compression Joints for Vitrified Clay Bell and Spigot Pipe
- C478 Precast Reinforced Concrete Manhole Sections
- C594 Compression Couplings for Vitrified Clay Plain End Pipe
- C700 Extra Strength and Standard Strength Clay and Perforated Clay Pipe
- D1784 Rigid Poly (Vinyl Chloride) Compounds and Chlorinated Poly (Vinyl Chloride) Compounds
- D2241 Poly (Vinyl Chloride) (PVC) Plastic Pipe (SDR PR and Class T)
- D2321 Underground Installation of Flexible Thermoplastic Sewer Pipe
- D2774 Underground Installation of Thermoplastic Pressure Piping
- D3034 Type PSM Poly (Vinyl Chloride) (PVC) Sewer Pipe and Fittings
- D3139 Joints for Plastic Pressure Pipes using Flexible Elastomeric Seals
- D3212 Sewer Pipe Joints using Elastomeric Seals

C. American Water Works Association (AWWA):

- C 600 Installation of Cast Iron Mains

1.02 SUBMITTALS

- A. Materials used in the sanitary sewer system shall be submitted for approval to the Design Engineer. The Design Engineer shall review the drawings, provide a list of materials and certify compliance to the Owner.
- B. Six copies of shop drawings or manufacturer's standard drawings or catalog cuts shall be submitted for the following:
 - 1. Precast concrete manholes
 - 2. Manholes and Frames
 - 3. Gaskets One of each type
 - 4. Pipe One of each type
 - 5. Valves One of each type

1.03 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. The Contractor shall be responsible for handling and storage of all materials and damaged materials shall not be used in the work. Materials delivered to the site shall be promptly inspected for damage upon arrival. Damaged or defective materials to be immediately removed from the site.
- B. All materials to be stored at least 12 inches above grade. Inside of pipes and fittings shall be kept free of dirt and debris. Rubber gaskets and plastic pipe not used immediately shall be protected from direct sunlight. Manhole units shall be handled with care to avoid chippage or breakage.

PART 2 – PRODUCTS

2.01 POLYVINYL CHLORIDE PIPE AND FITTINGS

- A. Polyvinyl chloride pipe and fittings for gravity sewers shall be SDR 35 for less than 12' bury and SDR – 26 for 12' bury and over, meeting ASTM D3034 for type PSM Polyvinyl Chloride (PVC) sewer pipe. The joints shall be Push On "O" ring gasket type with integral bell and spigot meeting ASTM 3212. Threaded or solvent welded type joints shall not be used.
- B. Polyvinyl chloride pressure pipe shall meet one of the following specifications:
 - 1. IPS Size PVC Pipe: Class 200 SDR 21 - Polyvinyl chloride water main pipe shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC

compound conforming to ASTM D1784. All pipe shall be Class 200, SDR 21. The standard laying length shall be 20 ft. ±1 inch.

2. DIP Size PVC Pipe: AWWA C-900-07

- a. C-900 polyvinyl chloride water main pipe 4" TO 12" shall conform to Designation ASTM D2241 and shall consist of Type I, Grade 1 PVC compound conforming to ASTM D1784. All pipe larger than 4" to 12" shall meet the requirements of AWWA C900, "Poly Vinyl Chloride (PVC) pressure pipe." All pipe shall be class 200 pipe and shall meet the requirements of DR14. The standard laying length shall be 20 ft. ±1 inch. The FM approved pressure class will be used to determine pressure class.
- b. C-905 polyvinyl chloride water main pipe 14" to 30" shall be manufactured from compounds conforming to PVC cell classification of 12454B as defined in ASTM D-1784. The integral bell joint system meets the requirements of ASTM D-3139 and utilizes an elastomeric seal conforming to ASTM F-477. All pipe shall be class 200 pipe and shall meet the requirements of DR18. The standard laying length shall be 20 ft. ±1 inch.
- c. When DIP size PVC pipe is used two 2" PVC pipe shall be SDR 21, 200 PSI pressure class, iron pipe

C. Marking: Pipe shall be clearly marked with:

1. Manufacturer's Identification
2. Nominal Pipe Size
3. Material, Type and Grade
4. SDR or Pressure Rating
5. All gravity sewer pipe shall be green. Force main pipe shall be white or brown.
6. All pipe regardless of color shall be clearly marked "SEWAGE FORCE MAIN" or "GRAVITY SEWER" as appropriate, marked every three feet.

2.02 DUCTILE IRON PIPE AND FITTING

A. Type: Coated Ductile

B. Joints:

1. Push on type in accordance with ANSI A21.11.

2. Mechanical joint in accordance with ANSI A21.11 and fittings may be in accordance with A21.53.
- C. Ductile iron pipe shall conform to ANSI A21.51.
- D. Pipe shall have a Protecto 401 lining or equal. The lining should have a high resistance to fatty oils, detergents and sewage generated hydrogen sulfide.
- E. Pipe shall be coated outside with one mil. thick bituminous coating conforming to ANSI A21.4 and AWWA C110, C115OR C151.

2.03 REINFORCED CONCRETE PIPE AND MANHOLES (WET WELLS OR VALVE PITS)

- A. Precast concrete sections to be manufactured in accordance with provisions of ASTM C478. As a minimum, the interior of all sections shall be coated with two coats of bituminous coating. The first coat shall be spray applied and the second coat should be roller applied. In addition, in extremely corrosive environments, to include force main receiving manholes, wet wells, and the first two manhole from the force main connection shall be lined with sealed HDPE sheet liner. The HDPE liner shall have a watertight seal at all joints and penetrations. The liner shall be Agru Sure Grip Liner or equivalent.
- B. Precast concrete riser sections to be 48 inches in diameter with minimum wall thickness of 4 inches.
- C. Precast concrete base units to have minimum wall thickness of 5 inches.
- D. Jointing material shall be rubber gasket type conforming to ASTM C443 or vulcanized butyl rubber base flexible joint sealer in rope form conforming to Federal Specification SS S 00210, Kent Seal No. 2 or approved equal. The inside and outside of the joint shall be finished with mortar. Mortar shall be one part Portland cement and two parts sand.
- E. Manhole base sections shall provide for a flexible watertight union between pipe and manhole base. Manhole sleeves shall be of high quality synthetic rubber with tensile strength of 1,500 psi, resistant to raw sewage, ozone, acids, and weathering, flexible at temperatures below 0°F and resistant to heat as high as 250°F. A substantial, serrated flange of the sleeve material shall be integrally cast into the wall of the manhole base forming a tight water seal. The sleeve shall protrude through the wall of the base. A watertight union shall be secured with

the end of the pipe with stainless steel strap clamps. Manhole sleeves shall be Interpace Corp. Lock Joint Manhole Sleeves or approved equal.

- F. Pick up holes shall not penetrate the interior walls or the riser.

2.04 MANHOLE FRAMES AND COVERS

- A. Frames and covers to have machined bearing surfaces.
- B. Covers to have checkered top design and marked "Sanitary Sewer" and include the name of the utility owner.
- C. Combined weight of frame and cover shall be approximately 450 pounds.
- D. Frame shall have a depth of approximately 9 inches and an access opening of not less than 20 inches.
- E. Covers shall have two pick holes located at edges.
- F. Materials shall conform to ASTM A48 for Class 30 gray iron castings.

2.05 MANHOLE STEPS

- A. Manhole steps shall be constructed of a number 3 reinforcing bar encapsulated in polypropylene plastic with a non-skid tread.
- B. Finished dimensions of the steps shall be identical to that of malleable iron manhole steps.
- C. Steps to have a minimum tread width of 12 inches.

2.06 NUTS AND BOLTS

- A. Stainless Steel Flanged: Square head MB/SF, hexagon nuts; ASTM 307B; ANSI B18.2, zinc plated.

2.07 GASKETS

- A. Flanged pipe gaskets shall conform to requirements of ASA A21.10 and shall be suitable for the indicated services.

2.08 VALVES

- A. All valves two inches in diameter and smaller shall be constructed of brass or bronze except the hand wheel, which shall be of malleable iron construction. Valves two inches in diameter and smaller shall have screwed ends unless approved otherwise. All valves 2½ inches in diameter and larger shall have flanged ends unless otherwise approved. They shall be iron body, bronze mounted, except that in the smaller sizes the valves may be all bronze at the contractor's option and expense.
- B. The contractor shall prepare and submit for approval complete detailed drawings of all valves in accordance with the requirements of the appropriate section of these specifications. All valves of the same type shall be from a single manufacturer. Parts of valves of the same type and size shall be interchangeable. Spare parts shall be furnished as specified under the proposal items. Special tools required for repacking or disassembling valves shall be provided.
- C. All valves shall be carefully mounted in their respective positions free from all distortion and strain. All valves shall be properly packed and left in satisfactory operating condition at the completion of the project. All valves shall open left.
- D. Gate Valves
 - 1. Gate valves should not be used in raw sewage applications. Gate valves should only be used where primary and partial secondary treatment has already occurred.
 - 2. Unless otherwise specified or directed, gate valves three inches and larger shall have non rising stems and shall meet the requirements of AWWA Standard C 500. Valves for lighter pressures than the AWWA Standard shall meet the requirements of the above specifications except that the requirements for metal thicknesses and strengths and structural designs shall be adjusted as required to meet hydrostatic test pressures not less than 125 psi.
 - 3. Unless otherwise specified or directed, gate valves smaller than three inches shall meet the requirements of Federal Specification WW V 54, Class A, 125 pounds.
 - 4. All gate valves shall have standard stuffing box seals. Bonnet bolts, studs and nuts shall be cadmium plated. Seating devices shall be bronze to iron or

bronze to bronze as specified or required. The glands shall be bronze or bronze brushed. Gland bolts and nuts shall be bronze.

5. All gate valves 2½ inches in diameter and larger shall be of the double disk type. All gate valves two inches in diameter and smaller may be of the double disk or the solid wedge type.

E. Plug Valves

1. All plug valves shall be the two way type.
2. Nonlubricated, eccentric with resilient faced plugs.
3. Port area of 4 to 20 inch valves shall be at least 70 percent of full pipe area.
4. Valves to be designed for 125 psi working pressure.
5. Bodies to be semi-steel with raised seats.
6. Seats to have either a welded in overlay of approximately 90 percent pure nickel on surfaces contacting the plug face or shall be bronze conforming to ASTM B 62 and attached to the body by stainless steel set screws.
7. Upper and lower plug stem bushings to be stainless steel and shall be permanently lubricated.
8. Exposed nuts, bolts and washers to be zinc plated.
9. Flanges to be faced and drilled to ASA 125 pound standard.

F. Check Valves

1. Type: Ball Check
 - a. Static head must exceed 10 feet to use ball check valves.
 - b. No ball check valve will be mounted vertically to compensate for low static head.
 - c. Ball check ends must be flanged.
 - d. The body shall be cast iron, ASTM A159 72, Class 35.
 - e. The ball shall be hollow steel with vulcanized nitrile rubber covering.
 - f. Pressure rating shall be 150 psi.
 - g. Valve to be Flygt HDL or equal.

2. Lever Actuate Spring Check Valve

- a. Where static head is less than 10 feet lever action swing check valves shall be used.
- b. Lever action swing checks may be spring and lever type or weight on lever type as approved by the design engineer and the Owner.
- c. Valves shall be installed in the horizontal position.
- d. The valve body, disc, cover and lever shall be cast iron, ASTM A159 72, Class 35.
- e. The disc arm shall be cast steel
- f. The seat ring shall be bronze or stainless steel.
- g. All studs, bolts or nuts shall be commercial grade steel.
- h. The gate shall be rubber faced.
- i. The hinge shaft shall be stainless steel.
- j. The chamber shall be bronze.
- k. The valve shall be Clow F5340 (outside spring and lever) or Clow F5345 (outside weight and lever) or an approved equal.

G. Automatic Sewage Air Release Valve

- 1. The automatic sewage air release valve shall be designed to allow entrapped air to escape from the sewage force main line. After the air escapes out of the air release valve, the valve shall shut off until more air accumulates in it and the opening cycle will repeat automatically.
- 2. The sewage release valve must have a compound internal linkage of precision molded delfin or stainless steel. All other internals must be stainless steel to positively prevent galvanic action. The float rod shall be 20" long to provide an air gap between the linkage and waste level inside the valve to retard the waste solids from clogging the linkage. The stainless steel float must withstand a minimum 1000 psi pressure. Each valve shall be complete with hose and blow off valves to permit back flushing without dismantling valve.

Body and cover cast iron	ASTM A48 Class 30
Internal Delfin linkage	ASTMD2133 (or Stainless Steel)
Stainless Float	ASTM A240
Buna N	ASTM SB800

3. Typical installation will utilize standard body valve. Valve height 28" with back flushing attachments 33 1/2". If depth of trench is not deep enough, furnish short valve. Valve height 17 1/2" with back flushing attachments 23 1/2".
4. Automatic sewage air release valve to be as manufactured by Crispin, Valmatic, or APCO equal to APCO Series 400 with accessories.

2.09 ACCESSORIES, PLUG, AND GATE VALVES

- A. Valves to have two inch square operating nut unless otherwise indicated.
- B. Valves buried in ground or located in vaults or structures to have suitable extensions for socket operation with top of operating nut located two feet below finished grades maximum.

PART 3 – EXECUTION

3.01 INSTALLATION

- A. Plastic piping installation shall be in accordance with ASTM D2321 Recommended Practice for non-pressure pipe and ASTM D2774 Recommended Practice for pressure pipe.
- B. Ductile iron pressure piping shall be installed in accordance with AWWA Standard C600.
- C. Material selection for piping material shall be as indicated. If piping materials are not indicated the Contractor has the option of selecting materials in accordance with this section.
- D. Service sewer lines shall be constructed of same material as the mains.
- E. Sewer lines shall not be laid closer than 10 feet horizontally to a water main. Pressure sewer lines shall pass beneath water lines, with the top of the sewer being at least 18 inches below the bottom of the water line. Where sanitary sewer lines pass beneath water lines, no joints in the sewer line shall be closer than 10 feet, horizontal the water line. When the vertical or horizontal separation cannot be accomplished, then concrete encasement shall extend a minimum of 10 feet on both sides of crossing.

- F. Pipe laying to proceed upgrade with pipe bells or groove on the upper end. Pipe to be laid with joints close and even, butting all around. Sagging joints will not be tolerated.
- G. Pipe shall be straight and of uniform grade between manholes, laid to line and grade.
- H. All sewer shall be designed and constructed to give velocities of not less than 2.0 FPS. Since the Owner has adopted a low flow plumbing device ordinance, the following slopes will be used.

Minimum Slope in Feet

<u>Sewer Size</u>	<u>Per 100 Feet</u>
8"	0.44
10"	0.30
12"	0.24
15"	0.15
18"	0.12
21"	0.10
24"	0.08
30"	0.058
36"	0.046

- I. An allowable deviation from the design grades will be allowed up to 5% of the grade shown on the plan. If the grade is steeper than allowed 5% deviation the engineer must verify that the project was installed to all minimum requirements and determine the impact of the additional grade. If the grade is flatter than the 5% deviation, then it exceeds the allowable tolerance and the installation of that line is not acceptable and must be replaced. All sewer mains installed will be field checked for grades during preparation of "Record drawings".
- J. Bell holes shall be dug so the pipe barrel will carry the load of the pipe. Pipe shall be bedded in undisturbed earth or, where rock occurs, on a thoroughly compacted layer of #57 stone or sand fill of a minimum thickness of 6 inches under the barrel or bell of the pipe.
- K. Where sewers or force mains are to be connected to existing manholes or other structures, and where no stub or opening has been provided for the connection, the Contractor shall make an opening of minimum diameter through the side wall of the structure utilizing a professional coring machine and installing a boot for

inserting the sewer pipe. The boot and stainless steel strap shall be sized and installed to create a water tight seal.

- L. Lateral connection made to the sewer prior to back filling shall be laid on a slope not exceeding 2 feet vertical to 1 foot horizontal, and not less than 1/8 inch per foot, so that the lateral shall have a solid bearing on undisturbed earth as stipulated for pipe sewers. The lateral shall make such a horizontal angle with the sewer line that a proper connection with the wye or tee branch or slant is obtained without trimming the pipe and with no danger of jointing material being forced into the sewer. All laterals shall be closed by means of suitable stoppers or end caps.
- M. Wye or tee branches shall be field located for service to all subdivided lots or inhabitable structures unless otherwise directed by the Architect/Engineer. Wye branches shall be installed so that the lower lip of the branch is not more than 2 inches below the outside top of the pipe. Tees shall be installed with the branch 45° to vertical. After installation, wye or tee branches shall not be covered with backfill until determination and record has been made of the locations of each with reference to the nearest manhole downstream and the direction in which the wye faces.
- N. All laterals shall be properly marked on ground surface at the point where laterals terminate with treated timber markers. Timber markers shall consist of a 2 inch by 4 inch timber extending from the end of the lateral vertically to within 2 inches of the ground surface. All such markers shall be securely anchored and maintained in a proper vertical position until backfilling has been completed. The top end of such markers shall be marked or left exposed until an "as built" survey has been made.
- O. The top rim of manhole frames and covers shall be set to conform to grades and transverse slopes. Generally, along outfall lines, the manhole frames and covers shall extend approximately 6 inches above finished grade or to a designated elevation for flood protection. Generally, where lines are located along streets, the manhole frames and covers shall be set flush with the surface.
- P. The Contractor shall install a continuous run of plasticized metallic tape above the top of the sewer main at 12 inches to 18 inches below finished grade. Tape shall be suitable for detection with metal pipe location equipment labeled "sewer buried below," and brightly colored to contrast with the soil.
- Q. A 14 gauge copper tracer wire with underground coating shall be installed along the route of pressure sewers. The wire shall be located 12 inches above the pipe but no deeper than 48 inches.

- R. All PVC pressure pipe shall have a minimum of 54" cover. Areas where the cover is not maintained may require the use of extra strength (D.I.) pipe as directed by the engineer.
- S. All sewer mains will be installed at a constant grade and line as shown on the plans. If after video inspection "sags" are found in the line, then the depth of the sag will be determined by the utility owner. If the sag is determined to be deeper than the following chart then the line will be removed and replaced to meet the minimum requirements of these specifications.

<u>Pipe Size</u>	<u>Max. Sag Depth</u>
8"	0.50"
10"	0.50"
12"	0.75"
15"	0.75"
18"	0.75"

3.02 PRESSURE TESTS

- A. **FORCE MAINS:** The Contractor shall test by hydrostatic pressure to 150 pounds per square inch. Each section tested shall be slowly filled with water, care being taken to expel all air from the pipes. The required pressure shall be applied for not less than two hours. No pipe installation will be accepted until the leakage during the pressure test is less than the number of gallons listed below for each 1000 feet of pipe.

6" - 1.5 gallons	12" - 2.75 gallons
8" - 1.75 gallons	14" - 3.00 gallons
10" - 2.75 gallons	16" - 3.5 gallons

- B. **GRAVITY MAINS:** On All sewer mains less than 8' deep, the Contractor shall pressure test the gravity mains with air. Each section including manholes shall be pressurized to 3.5 psi. The allowable pressure drop of 0.5 psi on any portion of the system shall not be less than the times shown on the following chart.

<u>PIPE SIZE</u>	<u>MINIMUM TIME</u>
4"	3 MIN.
6"	4 MIN.
8"	6 MIN.
10"	7 MIN.
12"	8 MIN.

If the main will not maintain the specified pressure, the Contractor will isolate the weak joint and repair. The test will be repeated until successful. The service lines must be installed at least to the back of the curb prior to testing. These pressure drops represent a maximum infiltration/exfiltration rate of 25 gallons per inch of pipe diameter per mile per 24 hour period.

3.03 ALLOWABLE INFILTRATION/EXFILTRATION

- A. If any visible flow is observed in the pipe during installation or final inspection a weir test will be conducted.
- B. The leakage inward or outward (infiltration or exfiltration) of the entire system including the sewer mains, service sewers, manholes and wet wells shall not exceed 25 gallons per inch of pipe diameter per mile per day for any section of the system.
- C. The weir shall be installed in each manhole. The manhole will then be filled with water to a depth of 3' from the top of the pipe, which should be at the bottom of the weir. The water level will stand for one (1) hour to stabilize then filled (if necessary) to the initial level. During the next hour the water level will be observed and the amount flowing through the weir or the amount of water required to maintain the level will be measured. This measured amount should not exceed the allowable.

3.04 INSPECTION

- A. Upon complete installation of the gravity sewer, the Contractor must enter a waiting period of not less than 10 days prior to inspection. In order to initiate the waiting period, the Contractor must notify the Design Engineer and the Owner's inspector in writing of the status of the sewer.
- B. After completion of the waiting period all sewer mains must pass a 5% deflection mandrel pulled by hand. If a 5% deflection mandrel will not pass through any section, that section will be replaced or re-rounded at the expense of the Contractor. Mandrel to be supplied by the Owner's inspector or by the Contractor, if requested by the Owner.
- C. Once the mandrel and physical inspection is complete the contractor will schedule a time when the owner may internally inspect the sewer main utilizing a sewer camera and generating a video inspection of the system. If any defects are found

in the system as a result of the internal inspection, then that section of the sewer main and any mains feeding into that system will not be accepted.

- D. No sewer main will be accepted if there is any evidence of sagging or bowing in the line which will adversely affect the performance of the pipe. Nor will any sewer mains be accepted if they are laid on a grade substantially less than specified on the Construction Plans. No line will be accepted if laid on less grade than the minimum stated in this specification.
- E. All manholes will be inspected for general appearance, cracks, leaks, proper installation of frame and cover, steps and inverts. Any manholes, which do not conform to the specifications, will not be accepted until the deficiency is corrected by the Contractor.
- F. All 4" sewer services will be tested for continuity and minimum bends by passing a standard tennis ball. Each sewer service shall be temporarily capped during construction. During the inspection, a tennis ball will be dropped down the open end of the sewer service. If the ball does not appear in the lower manhole the contractor will excavate the service, correct the blockage and repeat the test until successful.
- G. All manhole and wet well liner systems shall be tested using the "Spark Test" to locate incomplete welds or penetrations in the liner not adequately sealed for gas containment.

3.05 CLEANING

- A. Contractor to clean the completed system of any debris or obstructions prior to Final Inspection.

END OF SECTION

SECTION 02660
SEWER LINE CLEANING AND DISINFECTION

PART 1 - GENERAL

1.01 SCOPE

The Contractor shall furnish all labor, equipment, appliances and materials necessary for cleaning the sewer system including removal of all dirt, sludge, tuberculation and other foreign matter buildup from the interior wall of the sewer line to prepare the lines for television inspection, repair operations, disinfections or sewer rehabilitation.

1.02 DESCRIPTION

The Contractor shall be required to have all materials, equipment and labor necessary to complete the cleaning of the sanitary sewer lines on the jobsite prior to beginning the cleaning process.

The sewer lines and structures shall be cleaned using mechanical, hydraulically-propelled and or high velocity sewer cleaning equipment.

All cleaning equipment and devices shall be operated by experienced personnel. Precautions shall be taken to protect the sewer lines and structures from damage that might be inflicted by the improper use of the cleaning process or equipment. Any damage done to the sewer by the contractor shall be repaired by the contractor at no additional cost and to the satisfaction of the city.

PART 2 - PRODUCTS

2.01 MATERIALS

The Contractor shall use only the type of cleaning material which will not create hazards to health or property or affect the treatment plant processes.

2.02 EQUIPMENT

A. High-Velocity (Hydro-Cleaning) Equipment: Equipment shall be capable of removing all dirt, sludge, tuberculation and other foreign matter buildup from the interior wall and joints of the sewer line.

1. Equipment shall have selection of two or more high-velocity nozzles.

2. Primary equipment shall carry its own water tank, auxiliary engines and high pressure water pump.
 3. The Contractor shall operate the equipment so that the pressurized nozzle continues to move at all times in order to prevent damage to the lines.
 4. The nozzles shall be capable of producing a scouring action from 15 to 45 degrees in all size lines designated to be cleaned.
- B. Mechanical Cleaning Equipment: In addition to normal cleaning when required, shall be with approved equipment and accessories driven by power winching devices.
1. All equipment and devices shall be operated by experienced operators so that they do not damage the pipe in the cleaning process.
 2. Buckets, scapers, scooters, porcupines, kites, heavy duty brushes and other approved equipment shall be used as appropriate and necessary in the field, in conjunction with the approved power machines.
- C. Hydraulically-Propelled Cleaning Equipment: Equipment shall be capable of removing all dirt, sludge, tuberculation and other foreign matter buildup from the interior wall and joints of the sewer line.
1. All equipment and devices shall be operated by experienced operators so that they do not damage the pipe in the cleaning process.
 2. Equipment shall carry its own water tank, auxiliary engines and high pressure water pump.
 3. Pigs shall be able to reverse standard piping configuration such as elbows, tees, wyes and gate valves.

PART 3 - EXECUTION

3.01 FORCE MAIN INTERNAL CLEANING

- A. Pipeline shall be cleaned to remove dirt, sludge, tuberculation and other foreign matter buildup from the interior wall of the pipeline. Precautions shall be taken to prevent damage to the interior wall surfaces or other damage to pipes from the cleaning equipment.

- B. The contractor shall provide all equipment, material and manpower necessary to perform the job in its entirety. Any special mechanical fittings or valving shall be the responsibility of the contractor. The City upon request can provide a list of qualified local utility contractors that can be subcontracted to assist in these areas.
- C. The Contractor shall be responsible for any sewage spills that occur during the execution of the cleaning.
- D. Pigs shall be able to traverse standard piping configuration such as elbows, tees, wyes and gate valves.
- E. Water will be available at no charge during the cleaning process. The contractor must obtain a meter and backflow preventer from the City prior to water usage. The contractor is responsible for any required pumps, temporary piping and valves to access water.
- F. Flush debris downstream and allow it to continue through the 24" outfall line unless it contains large amounts of solids or debris which would cause line stoppages, accumulation of sand in wet wells, or damage pumping equipment. If the debris meets any of these characteristics, the contractor shall remove the debris at the Folker Road collection box and dispose of the material at the Hinesville/Fort Stewart Wastewater Facility. A vacuum truck shall be used to remove and transport the accumulations of materials.
- G. The Contractor shall keep his work area neat, clean, reasonably free of odor, and shall bear all responsibility for the cleanup of any spill which occurs during the cleaning. The contractor shall immediately clean up any such waste or spill. If the contractor fails to cleanup such spill immediately, the City shall have the right to clean up or arrange for its clean up and shall charge to the contractor all costs, including administrative costs and overhead incurred by the City in connection with such clean up. The City shall also charge the contractor any cost incurred or penalties imposed on the City as a result of any spill. Under no circumstances is this material to be discharge into waterways or any place other than where authorized to do so by the appropriate authority.

3.02 GRAVITY SEWER LINE INTERNAL CLEANING

- A. Pipeline shall be cleaned to remove dirt, sludge, tuberculation and other foreign matter buildup from the interior wall of the pipeline. Precautions shall be taken

to prevent damage to the interior wall surfaces or other damage to pipes or manholes from the cleaning equipment.

- B. The Contractor shall provide all equipment, material and manpower necessary to perform the job in its entirety.
- C. The Contractor shall be responsible for any sewage spills that occur during the execution of the cleaning.
- D. Water will be available at no charge during the cleaning process. The contractor must obtain a meter and backflow preventer from the City prior to water usage. The contractor is responsible for any required pumps, temporary piping and valves to access water.
- E. Flush debris downstream and allow it to continue through the Hinesville master pumping station unless it contains large amounts of solids or debris which would cause line stoppages, accumulation of sand in wet wells, or damage pumping equipment. If the debris meets any of these characteristics, the contractor shall remove the debris prior to the Hinesville pumping station and dispose of the material at the Hinesville/Fort Stewart Wastewater Facility. A vacuum truck shall be used to remove and transport the accumulations of the material.
- F. The Contractor shall keep his work area neat, clean, reasonably free of odor and shall bear all responsibility for the cleanup of any spill which occurs during the cleaning. The Contractor shall immediately clean up any such waste or spill. If the Contractor fails to clean up such spill immediately, the City shall have the right to cleanup or arrange for its clean up and shall charge to the Contractor all costs, including administrative costs and overhead incurred by the City in connection with such clean up. The City shall also charge the Contractor any cost incurred or penalties imposed on the City as a result of any spill. Under no circumstances is this material to be discharged into waterways or any place other than where authorized to do so by the appropriate authority.

3.03 DISINFECTION

- A. The mains shall be flushed before disinfecting by maintaining a velocity of at least 2.5 feet per second for a period of ten minutes.
- B. The continuous feed method may be used for disinfection. The recommended dosage for this method is 25 PPM with a 24 hour minimum contact time.

- C. Utilizing pigs to assist in the disinfection. A recommended 500 PPM of chlorine is the dosage for instantaneous contact to achieve disinfection. The chemical batching would be placed between two pigs and launch down the force main.
- D. Following disinfection, the system shall be flushed until chlorine concentration is less than 1 milligram per liter.
- E. Bacteriologic Tests:
 - 1. Tests shall be performed to detect the presence of coliform organisms on samples taken from the end farthest from the point at which chlorine was introduced into the system and at 5000 feet intervals.
 - 2. Test results must be at or below 18 colonies per 100 ml.
 - 3. If unsatisfactory samples are produced, disinfection shall be repeated until samples are satisfactory.

3.04 ACCEPTANCE OF CLEANING OPERATION

- A. In support of Rehabilitation Activities: Acceptance of sewer line cleaning shall be deemed sufficient when pipe is clean enough for installation of the particular rehabilitation method in accordance with manufacturer's recommendations and the City's approval.
- B. In support of Disinfection Activities: Acceptance of sewer line cleaning shall be deemed sufficient when pipe is clean enough to past the bacteriologic tests and the City's approval.
- C. In support of Television Inspection: Acceptance of sewer line cleaning shall be when a minimum amount of debris is observed to be removed from the sewer section.

END OF SECTION

**SECTION 02821
GRASSING**

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

- A. Conform to Section 700 and other applicable articles of the "Standard Specifications Construction of Transportation Systems", of the Department of Transportation, State of Georgia, dated April 18, 2013. Omit all references to measurement and payment.

1.02 SOIL SAMPLES

- A. The Contractor shall take soil samples from several areas of the site to be grassed and have them analyzed by the Georgia Extension Service. The results of the analysis shall determine the best fertilizer mixture to use on the site.

PART 2 - MATERIALS

2.01 FERTILIZER

- A. Commercial Fertilizer: Fertilizer for lawns shall be a complete fertilizer, the nitrogen content of which shall be derived from either organic or inorganic sources and meeting the following minimum requirements of plant food by weight, unless the soil analysis and report indicates a need for a different fertilizer mixture in which case the recommended mixture shall be furnished and applied. All State and Federal laws relative to fertilizer must be complied with.

10% Nitrogen - 12% Phosphoric Acid - 12% Potash

- B. Ground Limestone: Lime shall be ground dolomitic limestone containing not less than 85% of total carbonates and shall be ground to such fineness that 50% will pass through a 20-mesh sieve. Coarser material will be acceptable, provided the specified rates of application are increased proportionately on the basis of quantities passing the 100-mesh sieve.
- C. Sodium Nitrate shall be a commercial product in dry powder form and shall be delivered in the original, unopened containers each bearing the manufacturer's guaranteed statement of analysis. It shall contain not less than 16% Nitrogen.

2.02 LAWN MATERIALS

- A. Kentucky 31 Fescue (Fescue elatior: var. arundinacea): Seed shall be 98% minimum purity and 85% germination.
- B. Bermuda Grass (Cyanodon Dactylon): Seed shall be 98% minimum purity and 85% germination.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Prepare the seed bed by thoroughly cultivating, discing and hand raking as necessary to produce a smooth even grade free from hollows or other inequalities. Before any seeding is attempted the soil must be in a well pulverized, smooth, friable condition of uniformly fine texture.

3.02 FERTILIZING AND LIMING

- A. Approximately two (2) days prior to the start of seeding operations, apply ground limestone at the rate of 20 pounds per 1000 sq. ft. of lawn area. Either in conjunction with the above operation or immediately afterwards apply the specified Commercial Fertilizer over all lawn areas at the rate of 30 pounds per 1000 sq. ft. of lawn area. Work limestone into the top 6 inches of ground and the fertilizer into the top 2 inches of ground.
- B. When the grass has started to cover well (approximately 4 weeks after sowing seed) apply 1-1/2 pounds of Ammonium Nitrate to all lawn areas and immediately water using a fine spray. At the end of the maintenance period and prior to the final inspection apply 10 pounds of the specified Commercial Fertilizer per 1000 sq. ft. of lawn area and immediately water.

3.03 SEEDING

- A. Before any seeding is attempted the soil must be in a well pulverized, smooth, friable condition of uniformly fine texture. Lawn areas shall be seeded evenly with a mechanical spreader at the rate of 2 lbs. of seed per 1000 sq. ft., 50% in one direction and the remainder sown at right angles to first sowing. The seeded areas shall be lightly raked, rolled with a suitable weight roller and watered with a fine spray.
- B. Fescue planting season shall be as approved by Engineer.
- C. Bermuda Grass seeding shall be planted only between May 1 to September 1.
- D. When grassing is required between curbs and sidewalks, behind sidewalks in areas adjacent to private property, the Engineer may change the type of seeding to that required to match any type of grass which may be planted and growing on the adjacent lawn. No increase in the Contract Sum will be made for this substitution.

3.04 WATERING

- A. Soak soil to a minimum depth of 6 inches immediately after seeding. Do not wash away soil or seed. Keep all surfaces continuously moist thereafter until 30 days after the lawn has been seeded. Use fine spray nozzles only.

3.05 RESPONSIBILITY

- A. Maintenance of grass areas shall consist of watering, weeding, cutting, repair of any erosion and reseeding or resodding as necessary to establish a uniform stand of the specified grasses, and shall continue until final acceptance.

- B. All grassed areas that do not show satisfactory growth within 15 days after sowing shall be re-sown and re-fertilized as directed until a satisfactory blanket is established. Approximately 3 weeks after sowing the last seed, but not before the seed has taken hold and the grass is growing well, apply sulfate of ammonia or sodium nitrate at the rate of 300 pounds to the acre and water immediately. The lawns shall be considered established when they are reasonably free from weed, green in appearance and the specified grass is vigorous and growing well on each square foot of lawn area. Full coverage is required in 60 days.
- C. All grassed areas shall be protected until accepted. All eroded and damaged areas, regardless of cause, shall be immediately repaired and reseeded. Protect lawn areas against traffic.
- D. Grassed areas shall be covered evenly with a loose layer of clean wheat, rye, oats, Serecia Lespedeza or Coastal Bermuda Hay. Two tons of dry mulch shall be applied to each acre seeded. Hay shall be placed during calm weather with no wind.
- E. As soon as the grass becomes established, a final inspection of the work will be made, provided a written request for such inspection is given to the Engineer. Satisfactory coverage is defined as coverage of the areas seeded with grass that is alive and growing, leaving no bare spots larger than one (1) square foot with 98% coverage.
- F. All temporary valves, cutoffs and piping shall be removed by the Contractor at final acceptance of the grassing.

END OF SECTION

**SECTION 03300
GENERAL CONCRETE**

PART 1 – GENERAL

1.01 QUALITY STANDARDS

A. Any procedure and material operation specified by reference to the following publications shall comply with the requirements of the current specification or standard:

1. American Society for Testing Materials (ASTM):

A185 Welded Steel Wire Fabric for Concrete Reinforcement.

A615 Deformed Billet Steel Bars for Concrete Reinforcement.

C31 Method of Making and Curing Concrete Compression and Flexure Test Specimens in the Field.

C33 Specification for Concrete Aggregate.

C39 Compressive Strength of Molded Concrete Cylinders.

C94 Specification for Ready Mixed Concrete.

C143 Slump of Portland Cement Concrete.

C150 Portland Cement.

C172 Sampling Fresh Concrete.

C192 Making and Curing Concrete Test Specimens in the Laboratory.

D1751 Preformed Expansion Joint Fillers for Concrete Paving.

2. American Concrete Institute:

ACI 301 Specification for Structural Concrete for Buildings.

ACI 305 Recommended Practice for Hot Weather Concreting.

ACI 318 Building Code Requirements for Reinforced Concrete.

1.02 QUALITY CONTROL

A. The Contractor shall submit to the Engineer, for review a design mix for each class of concrete listed under CLASSES OF CONCRETE, prior to placing any concrete.

B. Verification tests of design mixes and aggregates are required by the Engineer. Verification test specimens shall be made in accordance with ASTM C39 by an

Independent Test Laboratory. Compressive strength shown by verification tests shall be at least fifteen percent in excess of the strengths listed under CLASSES OF CON-CRETE. The Independent Testing Laboratory shall report the test results to the Engineer, in writing and shall note any failure to meet the specification.

- C. Verification tests of design mixes made not more than one year prior to the date of submittal will be acceptable provided they were made from materials identical to those to be used in the project.
- D. Mill Test: Conducted in accordance with ASTM A615 recommendations on each 15 tons, or less reinforcing shipped to the job. Two (2) copies of test to be sent to the Engineer.
- E. Inspection and Testing of Concrete:
 - 1. The cost of slump tests and sampling, molding, storing, materials, transporting concrete test specimens shall be paid by the Contractor. The laboratory or inspection agency shall be selected by the Owner. Costs of all laboratory testing services required because of failure to meet the requirements of these specifications shall be paid by the Contractor.
 - 2. One set of four (4) acceptance cylinders shall be prepared for each day's placing of each strength of concrete and if more than 50 cubic yards of concrete is placed in any day, there shall be an additional set of cylinders prepared for each 50 cubic yards placed or for any fraction thereof. One cylinder shall be broken at seven days and two at twenty-eight days, with one cylinder held in reserve.
 - 3. Responsibilities in Inspection:
 - a. Laboratory's Duties
 - i. The reception and marking of specimens in the laboratory, laboratory curing, preparation for breaking and testing of cylinders shall be the responsibility of the laboratory and shall be performed by qualified laboratory personnel, observing all requirements of applicable ASTM Standards. Compression test specimens shall be tested in accordance with ASTM C39.
 - ii. Prior to the commencement of concrete work, the laboratory shall provide initial instruction in the performance of sampling and testing duties for an employee designated by the Contractor and shall provide him with copies of all ASTM Standards pertinent to his duties.
 - b. Contractor's Duties:
 - i. The Contractor shall deliver to the laboratory all materials to be used in required testing. He shall supply wheelbarrows, shovels, mixing boards, shaded work space and similar equipment required for molding test cylinders. He shall provide stable, insulated storage boxes, equipped with thermostatically controlled heat, for storage of cylinders in the first 24 hours after molding.

- ii. He shall designate an employee, who alone shall perform all operations of sampling concrete, molding test specimens, protecting test specimens for the first 24 hours after molding, and packing and shipping of test specimens. The employee shall make a record of a slump test in connection with each truckload of concrete. The designated employee shall receive initial instruction in the performance of his sampling and testing duties from a representative of the testing laboratory and shall have available copies of all ASTM Standards pertinent to his duties. Sampling shall conform to ASTM C172. Slump tests shall conform to ASTM C143. Compression test specimens shall be made and cured in accordance with ASTM C31.
- iii. Each set of test cylinders shipped to the laboratory shall be accompanied by a report giving information as to location in the structure of concrete sampled, time and date of sampling, air temperature, slump, class designated nominal strength, air content if applicable, temperature of concrete, truck number, and time batched. Each report shall be signed by the employee making the test and by the Contractor or his representative, certifying that the test specimens have been made by the one designated, fully instructed employee and have been made in accordance with applicable standard specifications.
- iv. Should any concrete fail to meet the specified strength, have a slump in excess of that required by the design mix for each class of concrete listed under CLASSES OF CONCRETE, or result in voids, honeycombs or otherwise fail to meet the requirements, the Engineer may order the concrete removed, further tests made, or other remedial measures taken, all at the Contractor's expense.

1.03 SHOP DRAWINGS

- A. After making his check the Contractor shall submit to the Engineer one (1) blue line copy of each of placing plans, bending details and bar lists covering all reinforcing steel.
- B. Full information for checking and for proper installation without reference to other drawings shall be included. At splices the amount of lap shall be shown. Location and arrangement of accessories shall be clearly shown. Elevations shall be drawn for all reinforced masonry and reinforced concrete walls to a scale no smaller than 1/4 inch = 1 foot.
- C. Work shall not proceed before the Contractor has received shop drawings approved by the Engineer. The Contractor shall be responsible for the conformation of all typical and special reinforcing steel details.
- D. Engineer's review is for conformance to the design concept and contract documents. Markings or comments shall not be construed as relieving the Contractor from compliance with the project plans and specifications, nor departures therefrom. The Contractor remains responsible for details and

accuracy, for selecting fabrication processes, for techniques of assembly, and for performing his work in a safe manner.

- E. Proposed construction joint shall be clearly indicated on shop drawings and subject to approval of the Engineer.

1.04 INSPECTION

- A. The Contractor shall give the Engineer 24 hours advance notice before starting to place concrete in any portion of the structure to permit observation. An authorization of the Engineer shall be secured before concrete is placed. Any concrete placed in violation to this provision shall be replaced by new concrete if required by the Engineer.
- B. Prior to notification of the Engineer, the Superintendent shall personally inspect the work and verify that it is ready for observation.
- C. At the time of observation, all reinforcing in the area where concrete is to be poured shall be in place, tied and ready for the placement of concrete. All anchors, sleeves, inserts, etc., shall be securely held in position.

1.05 STORAGE

- A. Reinforcing steel delivered to the job and not immediately placed in forms shall be placed in racks or other supports at least eighteen (18) inches above ground.

PART 2 – MATERIALS

2.01 CEMENT

- A. Portland cement shall conform to ASTM C150, Type I.

2.02 AGGREGATES

- A. Aggregates for standard weight concrete shall conform to ASTM C33, maximum size: 3/4 inch.

2.03 WATER

- A. Mixing water shall be potable.

2.04 REINFORCING STEEL

- A. Reinforcing bars shall be American manufactured conforming to the requirements of ASTM A615 "Deformed Billet Steel Bars for Concrete Reinforcement", Grade 60.
- B. Welded wire fabric or cold drawn wire for concrete reinforcement shall be of American manufacture and shall conform to the requirements of the ASTM A185 "Welded Steel Fabric for Concrete Reinforcement".

- C. Accessories shall conform to the requirements of C.R.S.I. Manual.

2.05 READY MIXED STRUCTURAL CONCRETE:

- A. Ready mix concrete shall be mixed and delivered in accordance with these specifications and requirements set forth in ASTM C94. In addition, these following conditions must be met:
 - 1. Concrete shall be normal weight with an ultimate compressive strength at 28 days, and slump as follows:
 - 2. Air entrained concrete shall be used for all structural concrete with the air content not less than 3 percent and no more than 5 percent.
- B. Classes of Concrete:

Class A f'c = 3000 psi, Slump 4 inches +/- 1 inch
Class AA f'c = 4000 psi, Slump 3 inches +/- 1 inch
Class B f'c = 5000 psi, Slump 5 inches +/- 1 inch

2.06 EXPANSION JOINT MATERIAL

- A. Expansion joint material at slabs on grade shall be premolded asphalt saturated cellulose fiber or mineral strips conforming to ASTM D1751.

2.07 WALL TIES

- A. Ties shall be made with break back ends or other means of removing the tie end to a depth of at least 1 inch from the concrete surface after the forms are removed.

2.08 LIQUID FORM SEALER

- A. Form sealer shall be a standard product compatible with the finish required for exposed concrete and shall contain no paraffin oil or mineral oil.

PART 3 – EXECUTION

3.01 FORMWORK

- A. Forms shall conform to the shapes, lines and dimensions of the members as indicated, and shall be substantial and sufficiently tight to prevent leakage of mortar. They shall be braced or tied together so as to maintain position and shape.
- B. Formwork shall be observed by the Engineer before pouring concrete. Before placing the reinforcement, surfaces of wood forms in contact with the concrete, unless lined, shall receive a thorough coating of form sealer. The Engineer shall have the right to reject any forms that do not appear to him to be sufficient as to

alignment and of producing the required finished surface. Should misalignment of forms or screed, excessive deflection of forms or displacement of reinforcing occur during concrete placing, corrective measures shall be immediately made to the extent, if necessary, that placing operations shall be stopped and concrete removed from within forms. The surfaces to required dimensions and cross section. Exposed lines and surfaces shall not vary from dimensions shown on plans by more than 1/4 inch in twenty feet.

- C. Forms may be constructed of wood or metal. Earth forms for footings may be permitted if local conditions are favorable, and approved by the Engineer. Form work for exposed concrete shall be form grade plywood.
- D. Studs, waler, and ties shall be so spaced that the load of wet concrete will not stress ties beyond the printed working load recommended by the manufacturer not cause spans of form material to deflect from a true surface.
- E. The Contractor shall maintain a continuous check upon formwork during the placing of concrete. An instrument check shall be periodically made or "Tattle Tail" rods or other devices shall be used to detect any settlement in forms.
- F. Conduits in Concrete: Conduits shall not displace reinforcing steel from its intended position, nor impair the strength of the structure.
- G. The Contractor shall assume all responsibility for removal of formwork. Elevated concrete slabs shall attain 70% of the specified ultimate strength before removing the forms. After removing forms, slabs shall be reshored at mid span and at all points under shores supporting forms for the work above. No floor shall be loaded in excess of the live load for which designed unless adequate shores are place beneath members supporting the concrete of load.

3.02 PLACING REINFORCING STEEL

- A. Reinforcement shall be shop fabricated, accurately positioned, and secured with not less than 16-gauge annealed wire or suitable clips.
- B. No bars, partially embedded in concrete shall be field bent, unless noted otherwise.
- C. Reinforcing bars shall be accurately placed and secured in position by approved chairs, spacers, or ties to maintain the position of the reinforcing steel prior to and during placing of concrete.
- D. Reinforcing steel support chairs and bolsters for use in concrete to be exposed shall have galvanized steel leg.
- E. No splices shall be made, except as shown on approved Shop Drawings or approved in writing by the Engineer.
- F. The placement of reinforcement shall be observed by the Engineer before pouring of concrete. Should there be any delay in the work, reinforcement

previously placed shall be reinspected and cleaned, if necessary, before concrete placement is resumed.

- G. Metal reinforcement shall be protected by concrete cover. Where not otherwise shown, the thickness of concrete over the reinforcement shall be as follows:

Footings	3" clear sides and bottom
Slabs	3/4" clear, top, and bottom
Beams	2" clear, all around
Walls	2" clear, both faces
Columns & Piers	2" clear

- H. All splicing or reinforcement not shown shall be approved by the Engineer. Splices shall not be made at a point of maximum stress and shall provide sufficient lap to transfer the stress between bars by bond. Hook and bending details, column tie arrangements, etc., shall be as shown by the S.R.A.I. Manual or the ACI Detail Engineering Manual.
- I. Wire mesh reinforcing shall be placed one inch from top of concrete slabs on ground. Lap all joints 12 inches and extend mesh to within 1 inch of sides and ends of slabs.

3.03 CONCRETE MIXING AND PLACING

- A. Ready mix concrete shall conform to ASTM C94. Not more than one hour shall elapse between the time mixing water is added to the batch and the concrete is poured. No water shall be added on the job.
- B. No concrete shall be placed until all embedded items and reinforcing have been placed in the forms and observed by the Engineer. At least 24-hour notice shall be given the Engineer of an impending pour, so that he may observe the work, prior to placing.
- C. Concrete shall be conveyed from the mixer to the place of final deposit by methods that will prevent segregation or loss of materials.
- D. Concrete shall be deposited in its final position to avoid segregations and separation do to rehandling or flowing. The placing shall be carried on at such a rate that concrete is at all times plastic and flows readily into the spaces between bars. When placing is once started, it shall be carried on as a continuous operation, until placement of that section is completed.
- E. Concrete shall be worked into and around bars and embedded items with spades, rods, trowels, and vibratos, so as to produce a solid homogeneous mass, free of voids, pockets or honeycombs.
- F. Construction joints shall be installed and located as indicated. Where a joint occurs, the surface of the concrete shall be thoroughly cleaned and all laitance removed and shall be left rough or mechanically roughened, thoroughly wetted and slushed with a coat of neat cement grout immediately before placement of new concrete.

- G. All embedded items, including anchor bolts and dowels, shall be in place, preset and held in position, before any concrete is placed.
- H. No concreting shall be performed when ambient temperatures are below 40°F or if the temperature is predicted by the local U.S. Weather Bureau will fall below 40°F within 24 hours after the time of installation.
- I. No concrete shall be installed against frozen ground. All foundation cavities and slab areas that have frozen, shall be thoroughly clean of all loose earth prior to pouring concrete.
- J. All newly poured concrete shall be protected from freezing or near freezing weather during the cure period.
- K. Hot weather precautions shall be taken whenever the maximum air temperature exceeds 80°F during the day. Hot weather concreting shall be performed in accordance with ACI 305.

3.04 EXPANSION/CONTROL JOINT INSTALLATION

- A. Expansion joints shall be placed a maximum of 20 ft. intervals and at all intersections with steps, curbs other walks or abutting structures. Joints shall extend from the surface to the subgrade at right angles to the sidewalk.
- B. Expansion joint filler shall be 1/2 inch thick and as wide as the full width and depth of the sidewalk. All expansion joints shall be filled with semi-rigid epoxy, specifically manufactured for the sealing of control joints in concrete slab construction, to create a water tight slab.
- C. Control joints (tooled or saw-cut) shall be placed at no less than 12 and no more than 15 ft. intervals, in a square grid, throughout the full length and width of the concrete slab. All control joints shall be filled with semi-rigid epoxy, specifically manufactured for the sealing of control joints in concrete slab construction, to create a water tight slab.

3.05 ANCHORAGE

- A. Slots, inserts, and connections elements for anchoring items to concrete shall be built into forms before placing concrete.

3.06 SLABS ON GRADE

- A. Concrete shall be compacted, screeded to grade, and prepared for the specified finish. Slabs shall be placed in panels in alternate checkerboard pattern or in alternate lanes divided into panels. Each panel shall be approximately square terminated by slab joints.
- B. Contraction joints shall be true to line 1/8 inch wide, and of depth equal to approximately 1/4 of the slab thickness. Joints shall be sawed or formed.

3.07 CURING

- A. Provisions shall be made for maintaining concrete in a moist condition for at least 10 days after the placement of the concrete, or by one of the following methods:
 - 1. Spraying with water or ponding.
 - 2. Using moisture retaining covers.
 - 3. Concrete curing compound, W.R. Meadows CS 309 or Guardian Chemical Co., Master Builders or Triple Cure by Cobra Chemicals.
- B. The spraying water shall be applied on unformed surfaces within one hour after the forms are stripped and the spraying shall be continuous. The moisture retaining cover shall be applied on unformed surfaces immediately after the concrete is finished. If there is any delay, the concrete shall be kept moist until the application is made. If the surfaces are formed, the forms shall be removed and the concrete sprayed lightly with water before the cover is applied.
- C. When concrete surfaces are to receive applied finishes of materials, all curing compounds shall be checked for compatibility with other material to be applied to the concrete surfaces before application.

3.08 CONCRETE FINISHES

- A. All poured joints, voids, honeycombs, and other imperfections shall be patched within the same working day that forms are removed.
- B. Troweled Finish:
 - 1. Troweled finish shall be applied to the surface of all floors unless ceramic tile, quarry tile or pavers are called for on finish schedule.
 - 2. Floor slabs shall be screened to an even surface by the use of straight edge and screeding strips accurately set to the proper grade. The concrete shall be floated with a wood float in a manner which will compact it and produce a surface free from depressions or inequalities of any kind. Floors shall be level with a tolerance of 1/8 inch in 10 feet except where drains are indicated. After the concrete has hardened sufficiently to prevent fine materials from working to the top and has been allowed to stand until all water sheen has disappeared, it shall be steel troweled. Final troweling shall be done after the concrete is hard enough that no mortar accumulates on the trowel and a ringing sound is produced as the trowel is drawn over the surface. The drying of the surface moisture before troweling shall proceed naturally and shall not be hastened by the dusting on of dry sand or cement.
- C. Non slip Finish: All exterior platforms and step treads shall be made non slippery by application at not less than 1/4 lb. per sq. ft. of aluminum oxide or emery aggregate graded from particles retained on a #50 mesh screen to particles

passing an 1/8 inch screen placed during the finishing process. Abrasive aggregate shall be sprinkled by hand as soon as the freshly placed cement will support the weight of workmen and floated into the surface.

- D. Unfinished Slabs: Depressed slab areas to receive ceramic quarry tile or pavers shall be finished to remove all laitance and to leave a slightly roughened, surface to insure bond. The surface of the slab shall not vary in any direction more than 1/8 inch when tested with a ten-foot straight edge. The straight edge shall be lapped one half its length as the test is being made.

3.09 CONCRETE FLOOR HARDENER

- A. All concrete floor slabs shall be cured with concrete floor hardener, "Clear Bond", as manufactured by Guardian Chemical, "Triple Cure" by Cobra Chemicals, or "Sealtight Cs 309 by W.R. Meadows. The floor hardener shall be applied in strict accordance with the manufacturer's recommendations.
- B. Walks shall be tooled, full 1 inch deep into separate slabs as indicated. Surface edges of each slab shall be rounded to approximately 1/4 inch radius.
- C. Final finish shall be a medium or light broom finish and all tool marks completely removed.

END OF SECTION

Unofficial

**SECTION 07900
CAULKING AND SEALANTS**

PART 1 - GENERAL

1.01 SCOPE

The work covered by this Section consists of furnishing all labor, equipment and material required to apply all sealants and related work as described herein and/or shown on the Drawings.

1.02 SUBMITTALS

Complete engineering and product data shall be submitted to the Engineer in accordance with the requirements of these Specifications. Color samples shall be submitted for approval by the Owner.

1.03 STORAGE AND DELIVERY

- A. Materials shall be stored in strict conformance with the manufacturer's instructions and in accordance with the requirements of these Specifications.
- B. Materials shall be delivered to the job site in sealed containers, with the manufacturer's original labels attached and accompanied by written certification indicating compliance with the requirements of these Specifications.

1.04 QUALITY ASSURANCE

The manufacturer shall provide the Engineer with written certification that all products furnished comply with all applicable requirements of these Specifications.

1.05 WARRANTY

- A. Provide a warranty against defective materials and workmanship in accordance with the requirements of these Specifications.
- B. The following types of failures will be considered defective work requiring replacement: leakage, hardening, cracking, crumbling, melting, shrinking or running of caulking compound or staining of adjacent work by caulking compound.

PART 2 - PRODUCTS

2.01 SILICONE SEALANT

- A. Acceptable Products: Dow Corning Corporation (#790), or General Electric Company (Silpruf).
- B. Type: One-part low modulus silicone rubber.

- C. Colors: To be selected from manufacturer's standard.

2.02 ONE-PART, NON-SAG POLYURETHANE SEALANT

- A. Acceptable Products: Mameco International, Vulken (#116), Sonneborn Building Products, Sonolastic (NP-1), or Tremco, Inc. (Dymeric).
- B. Colors: To be selected from manufacturer's standard.

2.03 TWO-PART, POURABLE POLYURETHANE SEALANT

- A. Acceptable Products: A.C. Horn, Inc. (Daraseal-U), Memeco International, Vulkem (#245), Tremco, Inc. (THC-900), or W.R. Meadows, Inc. (Pourthane).
- B. Colors: To be selected from manufacturer's standard.

2.04 ACRYLIC SEALANT

- A. Acceptable Products: A.C. Horn, Inc. (Daraseal A.R.), DAP, Inc. (DAP Acrylic), Protective Treatments, Inc. (#737), Tremco, Inc. (Mono), or W.R. Meadows, Inc. (Solaply).
- B. Type: One part acrylic polymer sealant.
- C. Colors: To be selected from manufacturer's standard.

2.05 JOINT BACKING

Joint backing, where indicated or required, shall be equal to "Tremco Joint Backing" by Tremco Mfg. Company or "Ethafoam SB" backer rod by Dow Chemical Company. Application shall be in accordance with sizes listed below:

Joint Size, inches	Rod Diameter, inches
3/16	1/4
1/4	3/8
3/8	1/2
1/2	5/8
5/8	3/4
3/4	1

2.06 COLORS AN DURABILITY

- A. Color of sealant or caulking shall be as selected by M.E. Sack Engineering.
- B. Caulking shall have a minimum life expectancy of 20 years and shall be resistant to the effects of sunlight, abrasion, oils, mild chemicals, cleaning agents and immersion in water.

PART 3 - EXECUTION

3.01 PREPARATION

- A. All joints or channels shall be cleaned and free of dirt, oil, grease, moisture, old paint, loose mortar, and other foreign matter.
- B. Metal surfaces shall be wiped with material equal to Zylol or Mek and then dried.
- C. Masonry surfaces shall be cleaned with a wire brush and then blown clean. Any waterproofing treatments contaminating the joint must be completely removed.
- D. Where joints are 1/2-inch wide, they should be backed to 1/2-inch of the surface. All 3/4-inch-wide joints shall be backed to 1/4-inch of the surface. Size of joint backing shall be large enough so that it can be compressed by at least 30 percent before inserting into the joint.
- E. Surface of concrete or masonry shall be primed in accordance with the manufacturer's printed instructions.

3.02 CAULKING SCHEDULE

- A. Silicone Sealant: All exterior joints and interior expansion and control joints, except horizontal floor joints.
- B. One-Part, Non-Sag Polyurethane Sealant: Interior joints, except as otherwise scheduled.
- C. Two-Part, Pourable Polyurethane Sealant: Horizontal floor and pavement joints.
- D. Acrylic Sealant: Interior sealant joints to be painted, except joints in drywall construction of less than 1/8-inch in width.

3.03 APPLICATION

- A. The Contractor shall caulk all joints (both inside and outside of jambs, heads, and sills) between the metal doors, windows, louvers, etc. and masonry throughout the buildings, as indicated on the Drawings, or otherwise required, so as to leave the building weathertight.
- B. Apply sealant with hand or air gun under sufficient pressure and through nozzle openings of such a diameter so that a full bead of sealant is run into the joint and fills the opening completely.
- C. Apply joint backer with a blunt rounded tool in accordance with manufacturer's instructions so it will not stain the sealant.
- D. All beads should be tooled immediately after application to insure firm and full contact with the interface of the joint.

- E. Work shall be of highest quality and in accordance with the manufacturer's current printed instructions.

3.04 CLEANING

Remove all excess material and smears adjacent to joint as work progresses.

END OF SECTION

Unofficial

**SECTION 15100
VALVES**

PART 1 - GENERAL

1.01 APPLICABLE STANDARDS

A. American Waterworks Association (AWWA):

C-500 Gate Valves-3" through 48" for Water and Other Liquids

C-508 Swing-Check Valves for Waterworks Service, 2" through 24"

B. American Society for Testing and Materials (ASTM):

A48 Gray Iron Casting

A240 Chromium and Chromium-Nickle Stainless Steel Plate Sheet, and Strip for Fusion-Welded Unifired Pressure Vessels

A307 Low Carbon Steel Externally and Internally Threaded Standard Fasteners

C. American National Standards Institute (ANSI):

B18.2 Square and Hex-Head Bolts and Screws

1.02 DESCRIPTION

A. All valves of the same type shall be from a single manufacturer. Parts for valves of the same type and size shall be interchangeable. Spare parts shall be furnished where required in the payment items. Special tools required for repacking or disassembling valves shall be provided.

B. All valves shall open left (counter-clockwise).

1.03 SUBMITTALS

A. The Contractor shall prepare and submit for approval, six (6) copies of complete detailed drawings of all valves.

PART 2 – PRODUCTS

2.01 VALVES

A. All valves 2" in diameter and smaller shall be constructed of brass or bronze except that the hand wheel which shall be of malleable iron construction with screwed ends. All valves 2-1/2" in diameter and larger shall have flanged ends for interior service and mechanical joints for buried service unless otherwise approved. They shall be iron body, bronze mounted, except that in the smaller sizes the valves may be all bronze.

B. Gate Valves:

1. Gate valves smaller than three inches shall meet the requirements of Fed. Spec. WW-V-54, Class A, 125 pounds.
2. Gate valves three inches and larger shall have non-rising stems and shall meet the requirements of AWWA Standard C-500. Valves for lighter pressures than the AWWA Standard shall meet the requirements of the above specifications except that the requirements for metal thickness and strengths and structural designs shall be adjusted as required to meet hydrostatic test pressures not less than 150 psi.
3. All gate valves shall have standard stuffing box seals. Bonnet bolts, studs and nuts shall be cadmium plated. Seating devices shall be bronze to iron or bronze to bronze. The glands shall be bronze or bronze bushed. Gland bolts and nuts shall be bronze.
4. All gate valves 2-1/2 inches in diameter and larger shall be of the double disc type. All gate valves two inches in diameter and smaller shall be of the double disc or the solid wedge type.
5. Valves to have two inches square operating nut, with the exception that gate valves in altitude valves pits shall have hand wheels.
6. Valves buried in ground or located in vaults or structures shall have suitable extensions for socket operation with top of operating nut located six blow finished grades.

C. Check Valves:

1. Check valves 2" through 24" shall be iron body, bronze mounted swing check valves meeting the requirements of AWWA Standard C508-76.
2. The check valve shall be metal to metal or composite to metal seat construction with flange ends or screw and coupled ends.

D. Altitude Valves:

1. Altitude valves shall have bodies and bonnets of cast iron, or semi-steel with Bronze trim unless otherwise noted on the drawings. They shall be of the differential single acting type as designated on the drawings, and in general shall perform the service of maintaining the liquid level of the storage facility(s) to which they are attached within a 3" to 12" variation.
2. The valve must be cushioned by air or water in opening and closing to prevent hammer and shock. A regulating device shall be provided to adjust the speed of valve closing.

3. All altitude valves furnished for use on this project shall be equipped for showing at all times the position of the valve. Said altitude valves shall be of the size specified on the drawings and suitable for the use intended.
4. The Contractor shall supply the services of a qualified manufacturer's representative to check and calibrate each altitude valve installation for proper working pressure and sequence.

E. Air Release Valves

1. Air release valve shall have all bronze body and bonnet. They shall be the direct acting type.
2. Valves shall be hydrostatically tested to at least 150 psi.
3. The valve shall have stainless steel floats and an internal coating with rust inhibitors.

F. Automatic Control Valves

1. Automatic control valves shall be diaphragm actuated. Valve seat design should readily handle low flow and high differential flow, without enhancement devices.
2. Stainless steel main valve body stem shall be guided top and bottom. The ductile iron valve body shall be rated at 250 psi for class 150 flanges; 640 psi for class 300 flanges; and 640 psi for threaded connections.
3. Ductile iron body and body parts shall be ASTM A536 – epoxy coated. Main valve stem and pilot stems shall be AISI 303 stainless. Diaphragm shall be nylon reinforced Buna – N. Pilot bodies, seat ring and Y-strainer shall be B62 cast bronze. Studs, nuts, plugs and stems should be non-rusting.
4. Speed controls and isolation cocks shall be standard and shall be brass. All tubing shall be stainless, and fittings can be a combination of brass and stainless. All valves shall have visual indicators and shall have up-stream and down-stream isolated pressure gauge ports in pilot system.
5. Basic valve port shall be full-port (line size – same as flanges), unless otherwise designated in the written specification. Basic valve and pilot components shall be machined and assembled in the United States.
6. Electric solenoids, utilized as part of the pilot system, shall be commercially distributed throughout the United States, have manual overrides, and they shall be full ported, tube line size, and not piloted in series with accelerators.

PART 3 – EXECUTION

- A. All valves shall be carefully mounted in their respective positions free from distortion and strain. All valves shall be properly packed and left in satisfactory operating condition at the completion of the project.

- B. Valve box and cover shall be installed with each valve as shown in miscellaneous details.
- C. Valves shall be delivered to customer with O&M manual and accompanied with electrical application wiring schematic where applicable.

END OF SECTION

Unofficial