



515 N. Main Street | Hinesville, GA 31313
PO Box 649 | Hinesville, GA 31310
912.368.5212
www.mesack.com
ME Sack Engineering
@mesackengineering
mesack



MEMORANDUM

DATE: September 17, 2025
TO: All Bidders
FROM: Sean Plomaritis, PM *SP*
RE: Jones Street Reclamation
For SNF Holding Company
MES No. 2025-06

The purpose of this memo is to provide clarification on the question listed below:

- 1) *So, the concrete removal bid item was removed per addendum #1 but an answer to a question in addendum #2 indicates that the concrete does need to be removed. Is that correct?*
 - Yes, the concrete does need to be removed. The updated bid items provided in Addendum No. 1 have included the concrete removal areas into the quantity provided for the full depth roadway reclamation bid item, as the areas of existing concrete are to be removed as part of the full depth roadway reclamation process.